


You Can't Run A Plant Using Science!

(Psst...Yes You Can!)

Using Lab, SCADA, Operational, and Design data
to predict and optimize plant performance

Agenda

- Background
- Questions to Answer
- Data Sources
- Solutions
- Conclusions



Dayton Water System

- Ottawa WTP
 - 1952
 - Conventional Treatment
 - Precipitative Lime Softening
 - 96 MGD Design Capacity
 - 40 MGD Average Daily



Lime Reclamation Facility

- Completed in 1957
- 150 tpd Capacity
- Recycle softening residuals
- CaO reused at WTPs

Techniques and Economics of Calcining Softening Sludges

—Joint Discussion—

A joint discussion presented on Jul. 14, 1959, at the Annual Conference, San Francisco, Calif.


Calcination Techniques—William B. Crow

A paper presented by William B. Crow, Cons. Engr., Black & Assocs., Inc., Gainesville, Fla.

RECALCINATION of softening plant sludge is a process in which the sludge, concentrated in a centrifuge to at least 60 per cent solids, is burned at 2,000°F, the calcium carbonate and magnesium hydroxide present being converted to oxides.

The greater portion of the carbonate hardness present in natural waters is normally due to calcium bicarbonate,

20–25 per cent excess lime. The difference between the theoretical conversion and actual recovery is attributable to mechanical losses in the dewatering and dust recovery equipment. The calcium carbonate is decomposed by heat, yielding calcium oxide and carbon dioxide as follows:



Dayton Water System




- Miami WTP
 - 1965
 - Four Up-flow Clarifiers
 - Precipitative Lime Softening
 - 96 MGD Design Capacity
 - 30 MGD Average Daily

LRF Process Flow

Residuals from
Dayton WTP's &
Outside Sources

Lagoon → Mad River



Carbonation



Thickening



Equalization
Tanks



Storage



Centrifuge



Kiln



MWTP &
Sales



Chemistry of the Kiln

Softening residuals from Dayton WTP's

1st Stage : Carbonation



solid

solid


gas from kiln

liquid

process solids

Chemistry of the Kiln


2nd Stage : Calcination



- 2000° F
- CO₂ for Carbonation in Stage 1

2010 Evaluate LRF


ENGINEERING STUDY



Evaluation of Lime Calcination Facilities and Expansion Options

Prepared For:
City of Dayton, Ohio

January 2011

 EE&T, Inc.
ENVIRONMENTAL ENGINEERING & TECHNOLOGY, INC.

Inception of Importing Residuals

- 2010 EE&T Study
- Proposed a residuals-handling facility
- 2012 Demonstration study



2014 LRF Expansion

CITY OF DAYTON, OHIO

PRELIMINARY DESIGN REPORT
LIME RECLAMATION FACILITY EXPANSION

City of Dayton, Ohio Lime Reclamation Expansion PRELIMINARY DESIGN REPORT

Project #200-23773-14001
December 2014

PRESENTED TO

City of Dayton
Department of Water Supply & Treatment
3210 Chuck Wagner Lane
Dayton, Ohio 45414

PRESENTED BY

Tetra Tech, Inc. P +1-513-333-3676
250 W. Court Street, F +1-513-241-0354
Suite 200 W www.tetratech.com
Cincinnati, Ohio 45202

Prepared by:

James Rydquist Date
Project Manager

James Christopher Date
Process Lead

 TETRA TECH

December 2014




New Facilities



New Facility - New Challenges

- No “shake down” period
- Operators asked to operate differently
- New challenges
- Growing pains
- Much frustration
- Task Force met weekly



Questions to Answer

- How many pounds of residuals are produced?
- How many gallons of residuals are we pumping?
- What is the WTP pumping rate and schedule?
- Do storage demands meet capacity?
- How much lime are we producing?
- What are our lime quality goals?
- What are the critical parameters to produce quality lime?
- Were our previous assumptions correct?

Data Sources

- Lab Water Quality Data
 - Raw and Effluent data
 - Stoichiometry of Rx
- Operator Logs
 - Pumping scheme
 - Operational changes
- SCADA iHistorian Query
 - SCADA stores lots of data
 - Administrator can show you

11/16/17 :Date

**Lime Reclamation Plant
Lime Recarb Data**

WEAR WRAP-AROUND SAFETY GLASSES WHILE IN THE LAB.
PLEASE CHECK EYE WASH EQUIPMENT AT THE START OF EACH SHIFT.
REPORT ANY EYE WASH PROBLEM TO MAINTENANCE ASAP.


Every 2 hrs.

Operator Initials	Time	% CaO	North Carb. Basin (pH)	South Carb. Basin (pH)	North 2nd Thick. (pH)	South 2nd Thick. (pH)	Recarb % solid pH											Remarks		
DL	11 P.M.	96.0	9.2	8.9	8.6	8.4													(P) 1.21	0.2
	3 A.M.	96.0	8.2	7.8	8.4	8.3													(N) 1.05	0.2
																			(S) 1.12	0.2
	Slake test	F°	1 minute	2 minute	3 minute	4 minute	5 minute	6 minute	7 minute	8 minute	9 minute	10 minute	RISE F°							
DL	11 P.M.	67.6	78.2	82.7	91.2	108.1	134.7	159.1	171.0	174.3	175.0		107.4							
	3 A.M.	66.4	77.5	81.4	87.8	101.1	126.2	153.4	168.2	172.2	173.2		106.8							
	retest if needed																			
DC	7 A.M.	96.0	7.3	7.6	8.4	8.3													(P)	
	11 A.M.																		(N)	
																			(S)	
	Slake test	F°	1 minute	2 minute	3 minute	4 minute	5 minute	6 minute	7 minute	8 minute	9 minute	10 minute	RISE F°							
	7 A.M.																			
	11 A.M.																			
	retest if needed																			
	3 P.M.																			
	7 P.M.																			
	Slake test	F°	1 minute	2 minute	3 minute	4 minute	5 minute	6 minute	7 minute	8 minute	9 minute	10 minute	RISE F°							
	3 P.M.																			
	7 P.M.																			
	retest if needed																			

ALL DATA IS TO BE ACTUAL AND FACTUAL.

Data Sources

- Plant Diagrams
 - Storage Capacity
 - Piping, valves
- Equipment Specs
 - Pump curves
- Operator's Knowledge
 - Hands-on knowledge
 - Day-to-day Operations knowledge






How Much Solids Are We Producing?

- If You Know:
 - Raw Water Quality
 - Finished Water Quality
 - Water Production
 - Stoichiometry
- Solids Produced



Chemistry of Lime Softening



Lab Data

Sample Collect Start	Water Production, MGD	Total Alkalinity, mg/L CaCO ₃	Calcium Hardness, mg/L CaCO ₃	Mg Hardness, mg/L CaCO ₃	Turbidity, NTU	pH, S.U.	CO ₂ , mg/L CaCO ₃	Ca Hardness, mg/L CaCO ₃	Mg Hardness, mg/L CaCO ₃	Turbidity	OWTP Ca Removal, mg/L CaCO ₃	OWTP Mg Removal, mg/L CaCO ₃	OWTP Turb Removal, NTU	OWTP CO ₂ Removal, mg/L CaCO ₃	OWTP Ca Removal, Tons	OWTP Mg Removal, Tons	OWTP Turb Removal, Tons	OWTP CO ₂ Removal, Tons	OWTP Residual Production, Tons/MG	OWTP Residual Production, Tons	Theoretical CaO Produced, Tons
1-Mar	37.06	276	204	126	3.57	7.52	17.49	72	92	0.029	264	88.4	5.31	17.49	40.80	13.66	0.82	2.70	1.56	57.98	30.50
2-Mar	41.63	276	206	132	6.41	7.5	18.30	58	105	0.03	296	70.2	9.57	18.30	51.38	12.19	1.66	3.18	1.64	68.41	35.60
3-Mar	42.4																				
4-Mar	42.84																				
5-Mar	40.11	272	194	130	2.97	7.55	16.10	44	125	0.023	300	13	4.42	16.10	50.18	2.17	0.74	2.69	1.39	55.78	29.32
6-Mar	37.97	274	194	130	2.64	7.56	15.85	48	114	0.033	292	41.6	3.91	15.85	46.23	6.59	0.62	2.51	1.47	55.95	29.58
7-Mar	36.91	272	202	120	1.72	7.59	14.70	55	114	0.025	294	15.6	2.54	14.70	45.25	2.40	0.39	2.26	1.36	50.31	26.69
8-Mar	35.37																				
9-Mar	40.52	266	200	130	2.56	7.7	11.20	58	114	0.025	284	41.6	3.80	11.20	47.99	7.03	0.64	1.89	1.42	57.55	30.81
10-Mar	42.99																				
11-Mar	44.9																				
12-Mar	45.02	262	180	130	2.63	7.67	11.81	44	113	0.022	272	44.2	3.91	11.81	51.06	8.30	0.73	2.22	1.38	62.31	33.24
13-Mar	39.21																				
14-Mar	37.09	264	194	122	1.4	7.67	11.90	54	103	0.03	280	49.4	2.06	11.90	43.31	7.64	0.32	1.84	1.43	53.11	28.53
15-Mar	38.43	274	202	118	2.21	7.61	14.15	63	103	0.023	278	39	3.28	14.15	44.55	6.25	0.53	2.27	1.39	53.59	28.45
16-Mar	39.78	280	194	130	2.31	7.62	14.14	49	114	0.025	290	41.6	3.43	14.14	48.11	6.90	0.57	2.35	1.46	57.92	30.80
17-Mar	45.31																				
18-Mar	42.61																				
19-Mar	36.48	252	180	128	1.34	7.62	12.72	47	113	0.024	266	39	1.97	12.72	40.46	5.93	0.30	1.94	1.33	48.63	25.98
20-Mar	33.56	270	202	118	2.02	7.61	13.95	49	113	0.033	306	13	2.98	13.95	42.82	1.82	0.42	1.95	1.40	47.01	25.00
21-Mar	33.16	274	198	134	2.65	7.62	13.83	54	107	0.025	288	70.2	3.94	13.83	39.82	9.71	0.54	1.91	1.57	51.99	27.74
22-Mar	35.85	276	198	126	2.15	7.58	15.26	48	114	0.035	300	31.2	3.17	15.26	44.85	4.66	0.47	2.28	1.46	52.27	27.73
23-Mar	38.32	276	210	126	2.18	7.62	13.94	62	96	0.035	296	78	3.22	13.94	47.30	12.46	0.51	2.23	1.63	62.50	33.47
24-Mar	42.29																				
25-Mar	38.2																				
26-Mar	34.27	292	200	134	1.29	7.44	22.18	76	86	0.027	248	124.8	1.89	22.18	35.44	17.83	0.27	3.17	1.65	56.72	29.83
27-Mar	32.03	278	186	142	1.36	7.64	13.41	58	115	0.031	256	70.2	1.99	13.41	34.19	9.38	0.27	1.79	1.42	45.63	24.40
28-Mar	31.12	280	200	122	0.853	7.6	14.79	51	120	0.026	298	5.2	1.24	14.79	38.67	0.67	0.16	1.92	1.33	41.43	22.03
29-Mar	30.85	272	188	136	0.881	7.61	14.05	68	99	0.029	240	96.2	1.28	14.05	30.87	12.38	0.16	1.81	1.47	45.22	24.22
AVG	38.49	272.95	196.42	128.11	2.27	7.60	14.73	55.68	108.42	0.03	281.47	51.18	3.36	14.73	45.18	8.21	0.54	2.36	1.46	56.30	29.90
Std Dev	4.17	8.26	8.21	6.31	1.24	0.06	2.55	9.20	9.88	0.00	19.02	31.58	1.86	2.55	5.76	4.53	0.33	0.43	0.10	6.72	3.46
Median	38.32	274	198	130	2.18	7.61	14.14	54	113	0.027	288	41.6	3.22	14.14	44.55	7.03	0.51	2.23	1.43	53.59	28.53
MIN	30.85	252	180	118	0.853	7.44	11.20	44	86	0.022	240	5.2	1.24	11.20	30.87	0.67	0.16	1.79	1.33	41.43	22.03
MAX	45.31	292	210	142	6.41	7.7	22.18	76	125	0.035	306	124.8	9.57	22.18	51.38	17.83	1.66	3.18	1.65	68.41	35.60

Calculate CO₂ Removed

$$\text{HCO}_3 = \frac{\text{TA} - 5.0 * 10^{(\text{pH}-10)}}{1 + 0.94 * 10^{(\text{pH}-10)}}$$

$$\text{Free CO}_2 = \frac{2 * \text{HCO}_3 * 10^{(6-\text{pH})} * 100}{44 \text{ g/mol CO}_2}$$

- Standard Methods 4500-CO₂ D

Residuals Removed

Softening Residuals / MG =

$$8.34 * [2 * Ca_{\text{removed}} + 2.6 * Mg_{\text{removed}} + 1.5 * NTU_{\text{removed}} + CO_2_{\text{removed}}]$$

*JAWWA March 2008 “Implementing Residuals Management: Cost Implications for Coagulation and Softening Plants”

**CO₂ removal not accounted for in original paper.

Residuals Produced


Ottawa	Influent	Effluent	Removal
35 MGD			
Alkalinity	275 mg/L		
Ca Hardness	204 mg/L	58 mg/L	292 mg/L
Mg Hardness	130 mg/L	109 mg/L	54.6 mg/L
pH	7.59		
CO2	15.36 mg/L		15.36 mg/L
Turbidity	3.66 NTU	0.030 NTU	5.445 NTU
lb/MG			3,064 lb/MG
Tons/day			54 tons/day

Miami	Influent	Effluent	Removal
34 MGD			
Alkalinity	287 mg/L		
Ca Hardness	223 mg/L	71 mg/L	304 mg/L
Mg Hardness	127 mg/L	80 mg/L	122.2 mg/L
pH	7.40		
CO2	23.27 mg/L		23.27 mg/L
Turbidity	1.91 NTU	0.04 NTU	2.655 NTU
lb/MG			3,771 lb/MG
Tons/day			64 tons/day



What is our pumping rate and schedule?

- Joe* says, "Ottawa sludge pumps run 40 min out of 120 min"
 - True for one pump
 - But we have **6 pumps**
- Jack* says, "Miami only pumps sludge at night"
 - Unless the tanks are full
- **Verify, don't assume**
 - Query SCADA
 - 24 hr graph



*Names have been changed to protect the innocent


Query SCADA

- Miami Tank Level
 - Convert to gallons
- Ottawa Pump Speed
 - Convert rpm to gpm
- Ottawa Run Time



How many gallons of residuals are we *really* pumping?

- SCADA: Run Times
 - Query SCADA
 - Run time and frequency
 - Is scale correct?
 - Says 700 gpm, but is it?
- Pump and Motor Specs



What's our *real* pumping rate?

- Primary Sludge Pump Speed
 - Verify Pump Rate
 - Pump Specs
 - 1000 gpm @ 900 rpm
 - Remember SCADA said 700 gpm, but actually rpm

= 700 rpm/900 rpm * 1000 gpm

= **778 gpm** → **11% more**

Dayton, OH WWTP
AS43079

EQUIPMENT LIST

PRIMARY SLUDGE PUMPS
PSL-PO01-01, PSL-PO01-02, PSL-PO01-03

<u>QTY</u>	<u>EQUIPMENT</u>	<u>DESCRIPTION</u>
3	Moyno Model 1K620G1 CDQ ASA, Single Stage Progressive Cavity Pump with Shaft Sleeve	Design Flow: 1000 GPM @ 40 ft Pump Speed: 180 RPM Inlet: 10" 125# FF Discharge: 10" 125# FF Rotor: Tool Steel/Chrome Plated Stator: Nitrile Castings: Cast Iron Bearings: B10 Life Min 30,000 hours Inspection Ports: (2) 180° apart on suction housing
3	60 HP Reliance Electric AC Motor	RPM: 900 Voltage: 230/460 Phase: 3 Cycle: 60 Enclosure: PROT-XE (Energy

What's our *real* pumping rate?

- Secondary Sludge Pump Speed
 - Verify Pump Rate
 - Pump Specs
 - 500 gpm @ 1200 rpm
 - Remember SCADA said 700 gpm, but actually rpm
- = 700 rpm/1200 rpm * 500 gpm
- = **292 gpm**

Dayton, OH WWTP
AS43078

EQUIPMENT LIST

SECONDARY SLUDGE PUMPS
SSL-PO01-01, SSL-PO01-02, SSL-PO01-03

<u>QTY</u>	<u>EQUIPMENT</u>	<u>DESCRIPTION</u>
3	Moyno Model 1J175G1 CDQ ASA, Single Stage Progressive Cavity Pump with Shaft Sleeve	Design Flow: 500 GPM @ 40 ft Pump Speed: 306 RPM Inlet: 10" 125# FF Discharge: 10" 125# FF Rotor: Tool Steel/Chrome Plated Stator: Nitrile Castings: Cast Iron Bearings: B10 Life Min 30,000 hours Inspection Ports: (2) 180° apart on housing
3	25 HP Reliance Electric AC Motor	RPM: 1200 Voltage: 460 Phase: 3 Cycle: 60 Enclosure: Prot-XE (Energy



Query SCADA

	A	B	C	D	E	F	G	H	I	J	K	L
1	start	3/16/18 0:00										
2	end	3/17/18 0:00										
3												
4												
5		MTPSVR.CF-LOC-	MTPSVR.C	OTPSVR.OTF	OTPSVR.O	OTPSVR.O	OTPSVR.O	OTPSVR.O	OTPSVR.OTP_S	LRFSVR.LRF_W	MTPSVR.CF-LO	MTPSVR.CF-LOC
6												
7	Timestamp	MTP Sludge Storage Tank 1 Level	MTP Sludge Storage Tank 2 Level	OTP PRIMARY SLUDGE PUMP 01 SPEED	OTP PRIMARY SLUDGE PUMP 02 SPEED	OTP PRIMARY SLUDGE PUMP 03 SPEED	OTP SECONDARY SLUDGE PUMP 01 SPEED	OTP SECONDARY SLUDGE PUMP 02 SPEED	OTP SECONDARY SLUDGE PUMP 03 SPEED	Wet Resid Transfer Flow to Sludge Blending	Miami Sludge Transfer Pump 1 Status (F_CV)	Miami Sludge Transfer Pump 2 Status (F_CV)
1448												
1449	Max	19.30764395	19.4339	699.9726	699.973	0	0	699.948	699.9475708	510.7722225		
1450	Min	2.258156264	3.90895	579	544	0	0	793	297			
1451	OWTP Pump Eff			77.77%	77.77%	0.00%	0.00%	58.33%	58.33%			
1452		11	11									
1453		3.2	4									
1454		1440	1440	579	544	0	0	793	297	258	859	638
1455		1440	1440	1440	1440	1440	1440	1440	1440	1440	1440	1440
1456	Rated pump gpm			1000	1000	1000	500	500	500		0	392.4077807
1457	actual gpm			777.74733	777.747	0	0	291.645	291.6448212		0	392.4077807
1458	Pump Run Time, min			1123			1090			258		
1459	Feet	24.84948768	22.525									
1460	Gallons	131,320	119,036	315,209	423,095	0	0	231,274	86,619			
1461	WTP Gallons	250,356		1,056,196						131,779		
1462	Total Gallons			1,306,552								
1463	Residuals, Tons	64.00		54.00						104.6433221		
1464	% Solids	6.13%		1.23%	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	17.00%		
1465	% Solids to Recarb	3.88%										
1466		1.040238846	1	1.0077967	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	1.120158724		
1467												
1468										0		
1469												
1470												



WRRB SCADA

The screenshot displays the Proficy iFIX Workspace interface for the WRRB SCADA system. The main window shows a process diagram with a central control panel titled "Offload & Automatic Dilution Contr".

Truck Offload Data:

- Truck Spray Water Flow: 106.0 GPM
- Truck Spray Valve: REMOTE AUTO
- Mud Loading Valve: REMOTE AUTO
- Truck Log: TRUCK LOG
- Truck Offload Pant: OK to Connect / Disconnect (Green), OK to Start (Green)
- Offload Contr: OFFLOAD CONTR
- Loading Flush Valve: REMOTE AUTO INTERLOCK
- Loading Flush Water Flow: -0.5 GPM

Offload & Automatic Dilution Control Panel:

SYSTEM CONTR: START OFFLOAD, START DILUTION, STOP, FILL TANK, FILL TANK

STATUS: Offload in Progress

Required Equipment	READY
Total Spray Volume	433 Gal
Total Flush Volume	0 Gal
Total Dilution Volume	433 Gal

DILUTION VOLUME CALCULATION:

Truckload Volume	4500 Gal
Truckload % Solids	34.3 % Wt
Target % Solids	18.0 % Wt
Calculated Truckload Density	1.6 SG
Calculated Truckload Weight	5941 lbs
Calculated Dilution Volume	6382 Gal

DILUTION VOLUME SETPOINT OVERVIEW:

USE SETPOINT: Dilution Volume Setpoint: 10000 Gal
 (setpoint may not be less than calculated value)

SPRAY SETTINGS:

Spray Water Delay Time	0.0 Min
Spray Water Duration Time	25.0 Min

LARMS:

Low Flow Alarm Setpoint	25.0 GPM
Low Flow During Offload	Off
Truck Volume + Dilution Volume Will Overflow	Off

Other Process Data:

- Holding Tank 2 Influent Flow
- Wet Residuals Transfer Flow: 478.1 GPM
- Wet Residuals Transfer Pressure: 56.4 PSI
- Holding Tank 2 Level: 5.8 Feet
- Wet Residuals Transfer Pressure 2: 56.1 PSI

The interface also shows various valves (e.g., Truck Spray Valve, Mud Loading Valve, Tank 2 Wet Resid Transfer Valve) and pumps (e.g., Vet Resid. Transfer Pump) with their respective control modes (REMOTE, AUTO).

Putting It All Together

16-Mar		to		17-Mar	
Primary Basin, gal		#####		Blending tank	
Outer Tank	770,057	Blending tank,	271,894	Level	13.4
Blending Transfer Pump, gpm	400	Pumps, gpm	400	Gallons	242,892
# Pumps	2	# Pumps	2	%Solids	9.88%
Run Time	425	Run Time	755		
Gallons Pumped	340,000	Gallons	604,000		
Miami Flow, MGD		34		MTP Sludge	
Avg. Residuals	1.91	Pumps, gpm	392.41		
MTP Residuals, Tons	64.82	Run time	1497		
		MTP Gal	250,356		
		MTP % Solids	6.21%		
OttawaFlow, MGD		35		OTP Gal	
Avg. Residuals	1.56	OTP % Solids	1.24%		
Ottawa Residuals, Tons	54.61	Total WTP Gal	1,306,552		
OTP 1^o Sludge Pumps, gpm		777.75			
Primary gal.	738,303				
OTP 2^o Sludge Pumps, gpm		291.64			
Secondary gal.	317,893				
Wet Residuals Building					
Pump, gpm	511	WRRB %	18		
Run Time, min	258	Specific	1.13		
WRRB, gal	131,779	WRRB, Dry	111.59		
North Recarb Basins		Blending Miami	South Recarb Basins	OTP	Flow to 1 Basin
Volume, gal	29,600		29,600		2262
gpm	800	392.41		1069.39	2262
Recarb Det. Time, min	37.00	75.43		27.68	26.17
Solids to Recarb, %					
N. Thickener		S. Thickener	Thickener		
Thickener, gal	281,161	281,161	gpm	1131	
Sludge blanket			Det. time, min	248.62	462038.34
Depth, ft	6	7			
Sludge Blanket, gal	181,928	206,736	gal/day-ft2	491.01	69.65
SOR, gpm/ft2	0.11		WOR, gpm/ft	1.85	173.43
N. Sludge Storage		S. Sludge			
Feet	19	Feet	15		
Gallons	100,408	Gallons	79,269		
Residuals, Dry Tons	231.02	Lime, Calc. Tons	129.37		

- Calculate % Solids
- Detention Time
- Gallons of Residuals
 - Produced
 - Imported
- Tons of Residuals
 - Produced
 - imported
- Estimate CaO produced

How many gallons of residuals are we pumping?

- Ottawa

Primary Sludge Pumps

$$= 778 \text{ gpm} \times 579 \text{ min} = 315,209 \text{ gal}$$

$$= 778 \text{ gpm} \times 544 \text{ min} = 423,095 \text{ gal}$$

Secondary Sludge Pumps

$$= 292 \text{ gpm} \times 793 \text{ min} = 231,274 \text{ gal}$$

$$= 292 \text{ gpm} \times 297 \text{ min} = 86,619 \text{ gal}$$

$$= \underline{\underline{1,056,196 \text{ gal}}}$$

- Miami

Tank diameter: 15 ft

$$= 15^2 \times 3.14 \times 7.48 \text{ gal/ft}^3$$

$$= 5285 \text{ gal/ft per tank}$$

Level Change

- Tank 1 = $(19 - 2) + (11 - 3) = 25 \text{ ft}$

- Tank 2 = $(19 - 4) + (11 - 4) = 23 \text{ ft}$

$$= 5285 \text{ gal/ft} \times 48 \text{ ft}$$



$$= \underline{\underline{250,356 \text{ gal}}}$$

How many gallons of residuals are we pumping?

- Wet Residuals Bldg (WRRB)
 - = 510 gpm x 258 min
 - = **131,779 gal**
- Total Gallons
- = 1,056,196 + 250,356 + 131,779
- Total Gallons = **1,438,331 gal**




Do storage demands meet capacity?



Do storage demands meet capacity?

- Inner Tank = 319,747 gal
 - 2 Pumps @ 400 gpm
- Outer Tank = 722,204 gal
- Primary Basin = 1,041,951 gal
= 1,041,951 gal - 1,438,331 gal
= -396,380 gal

Do you see a problem?




How much lime are we producing?



How much lime are we producing?

- Wait a minute...
 - If we're producing 100 tpd;
 - Then how can storage between all WTP's be full??
 - Production \neq Use + Sales
 - Why?



Are we calculating production correctly?

- Tons/Day Calculation

$$= (\text{Centrifuge} * 1440 * (\% \text{slurry} - \% \text{rej}) / 100 * \underline{8.34} * 0.56) / 2000$$

- But lime slurry is more dense than water isn't it?

YES!


- **Specific Gravity, sg** = $100 / ((\% \text{slurry} / \underline{2.71}) + (100 - \% \text{slurry}))$
 - CaCO₃ is 2.71 g/cm³

New Tons/Day Calculation

$$= (\text{centrifuge} * 1440 * (\% \text{slurry} - \% \text{rej}) / 100 * 8.34 * \text{sg} * 0.56) / 2000$$

- Slurry 14-25% solid
- **10-14% more** Dense = **10-14% more** Production
- Production = Sales + Use!!

What are our lime quality goals?



AWWA Standard B202-13

- >80% CaO
- Minimum of 18°F (10°C) rise within 3 min
- Maximum Slake temperature within 20 min
- <5% insoluble

Slaking Rates

- High Reactive Lime 72°F (40°C) < 3min and finish slaking in 10min.
- **Med. Reactive Lime 72°F (40°C) in 6min and finish slaking within 10-20min.**
- Low Reactive Lime 72°F (40°C) > 6min and finish slaking within 20min.

What are our lime quality goals?

- >88% CaO
- Minimum of 18°F rise within 3 min
- Maximum Slake within 10 min
- <1% insoluble
- 72°F in 6min, and finish slaking within 10 min
- <10% product Pass #20 Sieve



What are the critical parameters to produce quality lime?


- Residuals feed rate
- Gas flow
- Oxygen level
- Draft
- Primary air flow
- Air flow rate
- Venturi differential pressure
- Chains section temperature
- Hood temperature
- Product temperature
- Expansion chamber temperature
- Product bed thickness
- Carbonation pH

Operating Temperatures

- Exp. Chamber: 300 – 400°F
- Hood: 1950 – 2100° F
- Product: 1000 – 1050°F
- Chains : 1100 – 1200°F



Temperature vs Slake




Carbonation pH

- Recarb Basin pH: 7.5-8.5
- <7.5 Dissolve CaCO_3
 - Less product
- > 8.5 Precipitate $\text{Mg}(\text{OH})_2$
 - Lower CaO content
 - “Mud rings”



Carbonation pH

- Current pH not in range
- Adjust flow
- Upgrade CO₂ Blowers
- Add SCADA Trending



What are the critical parameters to produce quality lime?

Bi-weekly	01-Mar-18					Med React Lime	Med React Lime					
Expected Range	0.8-3.5%	1950-2100°	10X tpd	>12,000	>100 gpm	>18°F	>72°F	<10 min.	7.5-8.5 S.U.	7.5-8.5 S.U.	>100 tons	>3.35 mm, >50 %
LCL, UCL='+2σ	Exp. Chamber % O2	Hood Temp, °F	Kiln Speed rpm	Id Fan cfm	Centrifuge gpm	3 min. LRF Slake Δ°C	6 min. LRF Slake Δ°C	Total Slake Time	N Recarb pH	S Recarb pH	Product Tons, Adjusted	Sieve Analysis
AVG	2.25	2049.79	1082.15	14234.33	139.86	25.62	86.15	9.08	8.45	8.63	116.05	60.02
MIN	0.00	1543.98	13.03	9633.39	0.00	16.20	55.70	7.00	7.00	7.10	0.00	51.06
MAX	5.81	2131.95	1144.75	16102.87	149.18	45.90	106.80	10.00	9.90	9.90	139.96	75.12
STDEV	0.56	46.19	83.12	857.09	9.61	5.65	13.60	0.77	0.84	0.84	33.67	8.32
VAR	0.32	2127.35	6888.69	732409.65	92.00	31.46	182.60	0.59	0.69	0.70	1119.91	62.35
LCL	1.13	1957.41	915.90	12520.14	120.65	14.33	58.94	7.53	6.77	6.94	48.72	43.37
UCL	3.38	2142.18	1248.39	15948.52	159.08	36.91	113.35	10.63	10.13	10.31	183.38	76.66
In Spec, %	98.2%	95.5%	99.4%	98.8%	99.4%	94.8%	84.4%	100.0%	22.7%	20.0%	97.4%	100.0%

Quality Control



City of Dayton Division of Water Supply and Treatment
 Central Water Quality Laboratory
 3210 Chuck Wagner Lane
 Dayton, Ohio 45414
 937-333-6093

Lime Quality Results					
Location: Dayton Lime Reclamation Facility					
Date/Time Sampled: 3/12/2018					
Sampler Collector:					
Facility ID Name: OWTP Slaker					
Dayton WQ Laboratory Ohio EPA Approval Numbers: Chemical – 983 Microbiological - 200					
Parameter	Results	Units	Method	Date Analyzed	Analyst
Percent CaO	92.1	%	HCl Titrimetric	3/12/2018	DM
Total Hardness	1,710,000	mg/L	EDTA Titrimetric	3/12/2018	DM
Calcium Hardness	1,610,000	mg/L	EDTA Titrimetric	3/12/2018	DM
Calcium	684,822	mg/L	Calculation	3/12/2018	DM
Percent Calcium as CaCO ₃	94.15	%	Calculation	3/12/2018	DM
Magnesium Hardness	100,000	mg/L	Calculation	3/12/2018	DM
Magnesium	24,331	mg/L	Calculation	3/12/2018	DM
Percent Magnesium as CaCO ₃	5.85	%	Calculation	3/12/2018	DM
Percent Insoluble	0.316	%	Gravimetric	3/12/2018	DM

Slaking Results

Temperature rise (minutes)											
Date	Start (°C)	3	4	5	6	7	8	9	10	Δ °C	Slake Time
3/12/2018	27.1	40.4	52.2	64.5	72.1	75.3	76.4	76.6		49.5	9 Min

Sample Time Date: 4/15/18 1500 Analysis Date : 4/16/18


Sieve Analysis

Sieve Size	Retained	% Passing
1/4"	6.330	255.5
6	3.350	315.4
12	1.700	181.7
20	0.841	60.9
100	0.149	17.1
200	0.074	2.7
325	0.044	0.1
Pan	0.0	0.0
Total	833.3	



Were our previous assumptions correct?

- Some were
- Many were not
- Re-learn
- Plan for future



Solutions

- Coordinate Pumping
- Upgrade CO₂ Blower
- Add Pumps
- Piping
- Training



Conclusions

- The **DA** in **SCADA** stands for **Data Acquisition**
 - Lots of information stored is untapped
- Know your chemistry
 - *Make your teacher proud*
- Put lab data to use
- Reacquaint yourself with **Plant Diagrams**
- Don't be afraid to question high paid consultants
 - They work for you

Conclusions

- Use similar technique for:
 - Residuals management
 - Filter Growth
 - Backwash
 - ???



Acknowledgements

Keshia Kinney

James Blevins

Jeff Dahlin

Shannon Zell

Liz Zelinski

Brandon Turner

Rachel Easter

Rachael Osborne

Mike Rosselet

Lime Reclamation Staff


Emily Fuson

Debbie Herman – Tetra Tech

References

- Roth, Damon K., et al, “Implementing Residuals Management: Cost Implications for Coagulation and Softening Plants”, *JAWWA*, March 2008
- Crowe, William B., “Techniques and Economics of Calcining Softening Sludges”, *JAWWA*, March 1960
- Black, A.P., et al, “Recovery of Calcium and Magnesium Values From Lime-Softening Sludges”, *JAWWA* October 1971
- *Standard Methods for the Examination of Water and Wastewater*, 22nd ed., 2012

??Questions??



- N Recarb pH
- S Recarb pH
- Kiln Speed rpm
- 3 min. LRF Slake Δ°C
- Exp. Chamber % O2
- Id Fan Amps
- 6 min. LRF Slake Δ°C
- Exp. Chamber Temp, Deg F
- N Recarb Inline pH
- Total Slake Δ°C
- Kiln Chain Temp, Deg F
- S Recarb Inline pH
- Total Slake Time
- Hood Temp, Deg F
- Centrifuge gpm



Excel Add-in

The screenshot shows the Microsoft Excel interface with the ribbon set to 'Add-ins'. The 'Historian' dropdown menu is open, listing various options. The spreadsheet below shows data for columns B and C, with dates in row 3 and tag names in row 4.

	B	C
	1/1/2014	
	1/15/2014	
4	Tagname LRPSVR.OLP-P02-AI-3-04.F_CV	LRPSVR.OLP-P02-AI-3-02.F_CV
5		

Search SCADA Tags

The screenshot shows the Microsoft Excel interface with the 'Historian' ribbon selected. The 'Search Tags...' option is highlighted with a red circle. The spreadsheet displays data for tag names and dates.

		B	C	
			1/1/2014	
			1/15/2014	
4	Tagname	LRPSVR.OLP-P02-AI-3-04.F_CV	LRPSVR.OLP-P02-AI-3-02.F_CV	LRPSVR.OLP-F
5				

Search SCADA Tags

The screenshot shows an Excel spreadsheet with the following data:

	A	B	C	D	E
1	Start		1/1/2014		
2	End		1/15/2014		
3					
4	Tagname	LRPSVR.OLP-P02-AI-3-04.F_CV	LRPSVR		LRPSVR.OLP-P02-AI-3-06.F_CV
5					
6	Date	Exp. Chamber % Oxygen	Expans		Hood Temp, Deg F
7			F		
8					
9					

The Proficy Historian Tag Search dialog box is open, showing the following details:

- Description Mask: *oxygen*
- Server: [codhistorian01]
- Use Default Server:
- Available tags: Dissolved Oxygen Influent Channel #3 (F_CV), Dissolved Oxygen Influent Channel #4 (F_CV), Sample Station 10 Dissolved Oxygen, Dissolved Oxygen Influent Channel #1, Dissolved Oxygen Influent Channel #2, Kiln Feed Tube % Oxygen, Exp. Chamber % Oxygen (B_CUALM)
- Selected tags: Exp. Chamber % Oxygen
- Found: 8
- Search Display: Tag Descriptions
- Output With: Selected Tags
- Output Range: Sheet1!\$B\$4
- Output Orientation: Columns
- Output Display: Tagname, Description, Engineering Units

Query SCADA Data

Kiln Sandbox - Excel

File Home Insert Page Layout Formulas Data Review View Add-ins Tell me what you want to do...

Historian ▾

- Search Tags...
- Query Current Values...
- Query Raw Data...
- Query Alarms & Events...
- Query Calculated Data...**
- Query Filtered Data...
- Administration ▸
- Help
- Options
- About

fx LRPSVR.OLP-P01-AI-3-13.F_CV

	B	C	D	
		1/1/2014		
		1/15/2014		
4	Tagname	LRPSVR.OLP-P02-AI-3-04.F_CV	LRPSVR.OLP-P02-AI-3-02.F_CV	LRPSVR.OLP-P02-AI-3-08.F_
5				

Query SCADA Data

Kiln Sandbox - Excel

File Home Insert Page Layout Formulas Data Review View Add-ins Tell me what you want to do...

Historian

Menu Commands

LRPSVR.OLP-P01-AI-3-13.F_CV

	A	B		E
1	Start		1/1/2014	
2	End		1/15/2014	
3				
4	Tagname	LRPSVR.OLP-P02-AI-3-04.F_CV	LRPSVR.OLP-	LRPSVF OLP-P0 AI-3- 06.F_CV
5				
6	Date	Exp. Chamber % Oxygen	Expansion Ch F	Hood Temp, Deg F
7				
8				
9				
10				
11				

Proficy Historian Calculated Data Query

Server[Opt]: [codhistorian01] Use Default Server

Tag Name(s): Sheet1!\$B\$4:\$D\$4

Query Times: Start Time: Sheet1!\$B\$1 End Time: Sheet1!\$B\$2

Query Criteria String:

Sampling Type: Calculated Sampling

Calculation: Average

State Value:

Calculation Interval: By Interval Interval: 1 Time Unit: Minutes By Sample

Output Display: Tagname, Timestamp, Value

Output Range: Sheet1!\$A\$7

Output Sort: Ascending Descending

Output Orientation: Columns Rows

OK Help Cancel

SCADA Data in Excel

Kiln Sandbox - Excel

File Home Insert Page Layout Formulas Data Review View Add-ins Tell me what you want to do...

Historian

Menu Commands

A7 : {=ihQueryData("", \$B\$4, \$B\$1, \$B\$2, "Calculated", "Average", 3600000, 0, "Forward", "", "", "", "", 24, 1, 0, "Timestamp", "Value")}

	A	B	C	D	E
1	Start	1/1/2018			
2	End	1/2/2018			
3					
4	Tagname	LRPSVR.OLP-P02-AI-3-04.F_CV	LRPSVR.OLP-P02-AI-3-02.F_CV	LRPSVR.OLP-P02-AI-3-08.F_CV	LRPSVF OLP-P0; AI-3- 06.F_CV
5					
6	Date	Exp. Chamber % Oxygen	Expansion Chamber Temp, Deg F	Kiln Chain Temp, Deg F	Hood Temp, Deg F
7	01-Jan-18 01:00:00	2.347562513			
8	01-Jan-18 02:00:00	1.791398155			
9	01-Jan-18 03:00:00	1.801497682			
10	01-Jan-18 04:00:00	1.778625003			
11	01-Jan-18 05:00:00	2.039967605			
12	01-Jan-18 06:00:00	2.079710663			
13	01-Jan-18 07:00:00	2.078409738			



Add Excel Formulas

	A	B	C	D	E	F	G	H	I	J	K	
1	start	3/16/18 0:00										
2	end	3/17/18 0:00										
3												
4												
5		MTPSVR.CF-LOC-	MTPSVR.C	OTPSVR.OTF	OTPSVR.O	OTPSVR.O	OTPSVR.O	OTPSVR.O	OTPSVR.OTP_S	LRFSVR.LRF_W	MTPSVR.CF-LO	MTPSV
6												
7	Timestamp	MTP Sludge Storage Tank 1 Level	MTP Sludge Storage Tank 2 Level	OTP PRIMARY SLUDGE PUMP 01 SPEED	OTP PRIMARY SLUDGE PUMP 02 SPEED	OTP PRIMARY SLUDGE PUMP 03 SPEED	OTP SECONDARY SLUDGE PUMP 01 SPEED	OTP SECONDARY SLUDGE PUMP 02 SPEED	OTP SECONDARY SLUDGE PUMP 03 SPEED	Wet Resid Transfer Flow to Sludge Blending	Miami Sludge Transfer Pump 1 Status (F_CV)	Miami Transfer Pump 1 Status (F_CV)
1448												
1449	Max	19.30764395	19.4339	699.9726	699.973	0	0	699.948	699.9475708	510.7722225		
1450	Min	2.258156264	3.90895	579	544	0	0	793	297			
1451	OWTP Pump Eff			77.77%	77.77%	0.00%	0.00%	58.33%	58.33%			
1452		11	11									
1453		3.2	4									
1454		1440	1440	579	544	0	0	793	297	258	859	
1455		1440	1440	1440	1440	1440	1440	1440	1440	1440	1440	
1456	Rated pump gpm			1000	1000	1000	500	500	500		0	392.4
1457	actual gpm			777.74733	777.747	0	0	291.645	291.6448212		0	392.4
1458	Pump Run Time, min			1123			1090			258		
1459	Feet	24.84948768	22.525									
1460	Gallons	131,320	119,036	315,209	423,095	0	0	231,274	86,619			
1461	WTP Gallons	250,356		1,056,196						131,779		
1462	Total Gallons			1,306,552								
1463	Residuals, Tons	64.00		54.00						104.6433221		
1464	% Solids	6.13%		1.23%	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	17.00%		
1465	% Solids to Recarb	3.88%										

