

Operator Training Committee of Ohio Distribution Workshop Disruption of Service Rule/Operator Certification Update

Andrew Barienbrock
November 13, 2018

Disruption of Service Rule

- **Effective November 1, 2018**
- **Specifies responses any time distribution pressure goes below 20 PSI**
- **Transient (TNC) and Non transient non community (NTNC) serving <1000 shall provide bottled water or the equivalent**

Disruption of Service Rule

- All community and non transient non community systems serving 1000 or greater must follow the event response and notification provisions

Disruption of Service Rule

- During an event systems must monitor pressure upstream and downstream of water line repairs
- Pressure monitored by in-line pressure monitors, hydrant pressure recorders, elevated storage tanks, towers or other Director approved methods

Disruption of Service Rule

- **TYPE 1 Event – controlled pipe repair, positive pressure maintained and no sign of contamination intrusion.**

Disruption of Service Rule

- **TYPE 1 Event Response**
 - Excavate below the repair
 - Maintain pit water level below the repair
 - Disinfect in accordance with AWWA C651
 - Repair under positive pressure
 - After repair verify disinfectant presence
 - Document steps taken
 - No boil advisory
 - No Coliform Sampling necessary
 - If all steps not followed the event is elevated to Type 2

Disruption of Service Rule

- **TYPE 1 Reporting Requirements**
 - No notification to Ohio EPA is required provided the event response items are followed
 - An after action report must be maintained by the facility

Disruption of Service Rule

- **Type 2 Event – controlled pipe repair, positive pressure maintained until a controlled shutdown of the affected area can be completed and no signs of contamination. Water line replacement does not exceed one full section of pipe.**

Disruption of Service Rule

- **Type 2 Event Response**
 - Excavate to below the repair
 - Maintain pit water level below the repair
 - Affected critical customers notified
 - Perform controlled shut down
 - Repair the water line
 - Disinfect affected area in accordance with C651

Disruption of Service Rule

- **Type 2 Event Response** (Continued)
 - Flush lines in accordance with C651
 - Verify disinfectant presence
 - Document activities
 - No boil advisory
 - No coliform samples
 - Move to Type 3 if process not followed

Disruption of Service Rule

- **TYPE 2 Reporting Requirements**
 - No notification to Ohio EPA is required provided the event response items are followed
 - An after action report should be maintained by the facility

Disruption of Service Rule

- **Type 3 Event – loss of pressure at the repair site, localized depressurization near repair, an uncontrolled shut down or signs of possible contamination intrusion**

Disruption of Service Rule

- **Type 3 Event Response**
 - Activate the notification procedures in the system's contingency plan
 - Document possible contamination
 - Issue precautionary boil advisory
 - Disinfect, repair and flush in accordance with C651
 - Test for chlorine residual and comply with minimum requirement
 - Move to Type 4 if event becomes a widespread disruption

Disruption of Service Rule

- **Type 3 Event Response** (Continued)
 - After repairs, repressurization and chlorine verification, collect special purpose total coliform samples
 - If samples negative for E. Coli or fecal coliform the boil advisory may be lifted
 - If samples positive for E. Coli or fecal coliform the advisory stays in effect and need consecutive samples 24 hrs apart to lift advisory

Disruption of Service Rule

- **Type 3 Reporting Requirements**
 - If the disruption affects 10 percent of a systems customers or 100 service connections whichever is least, notify the appropriate District office or Ohio EPA hotline (after hours)
 - Must speak with a person at Ohio EPA
 - Document activities in writing. Submit after action report to Ohio EPA w/in 48 hrs

Disruption of Service Rule

- Type 4 Event – Catastrophic failure, widespread depressurization or actual contamination intrusion

Disruption of Service Rule

- **Type 4 Event Response**
 - Activate notification process in contingency plan
 - Document contamination
 - Consult with Ohio EPA
 - Issue boil advisory or “Do Not Drink” advisory
 - Disinfect, repair and flush in accordance with C651
 - Test for chlorine residual and comply with minimum requirement

Disruption of Service Rule

- **Type 4 Event Response** (Continued)
 - After repairs, repressurization and chlorine verification, collect special purpose total coliform samples
 - If samples negative for E. Coli or fecal coliform the boil advisory may be lifted
 - If samples positive for E. Coli or fecal coliform the advisory stays in effect and need consecutive samples 24 hrs apart to lift advisory

Disruption of Service Rule

- **Type 4 Reporting Requirements**
 - If the disruption affects 10 percent of a systems customers or 100 service connections whichever is least, notify the appropriate District office or Ohio EPA hotline (after hours)
 - Must speak with a person at Ohio EPA
 - Document activities in writing. Submit after action report to Ohio EPA w/in 48 hrs

Reporting

- Contact your District Office during normal business hours
- After hours contact Ohio EPA's 24 hour emergency hotline. 1-800-282-9378. Indicate this is a water plant emergency
- Online after action reporting tool. Required to be used for Type 3 and 4. You can use it for Type 1 and 2 and either save or print the report.

Reporting



Press the button and it will take you to the disruption of service web page.

Press it a second time and you will go to the reporting tool

New Operator Certification Rules

- Effective August 15, 2018
 - Congratulations you are all now considered professional operators
 - New definition of operating experience beginning on August 15, 2019
 - Minimum Staffing requirements for distribution systems.
- Reporting of minimum staffing on eDWR

New Operator Certification Rules

- Requirement for electronic submission of renewal applications beginning with certificates that expire December 31, 2018
- Moving official due date for renewals to November 30 of the expiration year.
- Reducing grace period from 1 year to 6 months.

New Operator Certification Rules

- Certify that Ohio EPA Certification Course has been reviewed for all applications
- 3745-7-21 (Contract Operator Rule)
 - Require Director approval for all contract operators and contract operation companies
 - Spells out requirements for contract operations companies
 - Provisions for preventing companies or operators from acting as contract operators

Andy Barienbrock

Phone: 614-728-1216

Email:

andrew.barienbrock@epa.ohio.gov