Room:	Decontamination Area	Circle one:	
Air:	 Humidity / temperature: *see footnote What is the acceptable range? How is it monitored, and on what frequency? Actions to be taken when measures are out of acceptable range? 	Compliant? Non-compliant? BAS monitored Call Facilities	
Air	 Pressures: Positive / Negative How is it monitored, and on what frequency? Actions to be taken when measures are not complaint with expectations? 	Compliant? Non-compliant?	
Ceiling Walls	Clear of water stains / damage?Air vents: dusty / dirty?Intact?	Compliant? Non-compliant?	
vvalis	 Clear of dust / dirt / cobwebs? Stored supplies kept within 18 inches of ceiling? Eyewash station in place? Fire alarms. Shut-off valves not blocked? 	Compliant? Non-compliant? Eyewash station to be checked weekly – ANSI Z358.1-2014	
Sinks	 No cleaning supplies kept in a cabinet under the sink? 	Compliant? Non-compliant?	
Detergents / cleaning solutions	 Any expired solutions? Sufficient warning labels present on any solution re-packaged into a non-manufacturer-produced container? 	Compliant? Non-compliant?	
Doors	 Is door blocked from functioning Barriers blocking door; door jam in place to keep door from closing during a fire Does the spring-hinged door close & latch as expected? 	Compliant? Non-compliant?	
Windows	Intact?Exterior: secure to prevent opening?Interior: operating correctly?	Compliant? Non-compliant?	
Floors	• Intact?	Compliant? Non-compliant?	
Area care	 What is the room cleaning schedule? How is cleaning monitored for completion? 	Compliant? Non-compliant?	
Staff	 Correct PPE / employee dress code expectations in place? 	Compliant? Non-compliant?	

		completion?	·	·		
Staff		Correct PPE / employee dress code expectations in place?	Compliant?	Non-compliant?		
*	* AAMI & ASHRE sources state Temp ranges of 60 °-75° and humidity range of 30%-60% in patient care areas, and 30%-70% in sterile supply storage areas.					
Notes:						