Room:	Medication Room ROOMS INS	PECTED		
Air:	Humidity / temperature: *see footnote	Compliant?	Non-compliant?	
	<ul> <li>What is the acceptable range?</li> <li>How is it monitored, and on what frequency?</li> <li>Actions to be taken when measures are out of acceptable range?</li> </ul>	<ul><li>BAS monitored</li><li>Call Facilities</li></ul>		
Ceiling	<ul><li>Clear of water stains / damage?</li><li>Air vents: dusty / dirty?</li><li>OR lights: dusty / dirty?</li></ul>	Compliant?	Non-compliant?	
Walls	<ul> <li>Intact?</li> <li>Clear of dust / dirt / cobwebs?</li> <li>Stored supplies kept within 18 inches of ceiling?</li> <li>Cabinets: <ul> <li>Dusty found inside?</li> <li>Expired supplies?</li> <li>Cleaning schedule?</li> </ul> </li> <li>Biohazard signs posted inside / outside the room?</li> </ul>	Compliant?	Non-compliant?	
Supplies	Storage containers: items stored in corrugated cardboard shipping containers?     Check:	Compliant?	Non-compliant?	
Doors	<ul> <li>Is door blocked from functioning         <ul> <li>Barriers blocking door; door jam in place to keep door from closing during a fire</li> </ul> </li> <li>What staff are authorized for access</li> </ul>	Only staff deal with medications should have access		
Floors	Intact?	Compliant?	Non-compliant?	
Area care	<ul><li>What is the room cleaning schedule?</li><li>How is cleaning monitored for completion?</li></ul>	Compliant?	Non-compliant?	
Refrigerator	<ul> <li>Temperature log visible / up-to-date?</li> <li>Functioning thermometer in place?</li> <li>Was temp ever out of range?</li> <li>If so, what actions are recorded as being taken?</li> </ul>	Compliant?	Non-compliant?	

<sup>\*</sup> AAMI & ASHRE sources state Temp ranges of 60 °-75° and humidity range of 30%-60% in patient care areas, and 30%-70% in sterile supply storage areas.

Notes:	 	 	