

Non-Patient Care Areas:		ROOM NUMBERS	
<ul style="list-style-type: none"> Lobby Waiting Room Staff Break Room Staff Locker Room 			
Ceiling	<ul style="list-style-type: none"> Clear of water stains / damage? Air vents: dusty / dirty? 	Compliant?	Noncompliant?
Walls	<ul style="list-style-type: none"> Intact? Clear of dust / dirt / cobwebs? 	Compliant?	Noncompliant?
Areas open to the public	<ul style="list-style-type: none"> Is any PHI (Patient Health Information) protected so privacy is not violated? 	Compliant?	Noncompliant?
Floors	<ul style="list-style-type: none"> Intact? 	Compliant?	Noncompliant?
Area care	<ul style="list-style-type: none"> What is the room cleaning schedule? How is cleaning monitored for completion? 	Compliant?	Noncompliant?
Hallways	<ul style="list-style-type: none"> 8-feet clearance available? 	In patient care areas, any object blocking an 8-feet clearance should be mobile, and moved at least every 30 minutes	
	<ul style="list-style-type: none"> Medical gas valves clear? 	No item should be stored or placed to block open access to medical gas safety shut-off valves.	

Nurse's Station		AREAS REVIEWED	
Ceiling	<ul style="list-style-type: none"> Clear of water stains / damage? Air vents: dusty / dirty? 	Compliant?	Noncompliant?
Areas in public view	<ul style="list-style-type: none"> Is any PHI (Patient Health Information) protected so privacy is not violated? 	Compliant?	Noncompliant?
Desks / work areas	<ul style="list-style-type: none"> Food & drink absent from the area per OSHA guideline 1910.1030 (d) (2) (ix) 	Compliant?	Noncompliant?
Floors	<ul style="list-style-type: none"> Intact? Oxygen cylinders appropriately stored? <ul style="list-style-type: none"> Only 12 full cylinders in per room? FULL separated from EMPTY? 	Compliant?	Noncompliant?
Area care	<ul style="list-style-type: none"> Does the room have a cleaning schedule? 	Compliant?	Noncompliant?
	<ul style="list-style-type: none"> Is there a method in place for monitoring the cleaning for completion? 	Compliant?	Noncompliant?

Notes: _____
