

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring and Reporting Requirements Not Met

Moscow Water Department violated drinking water monitoring and reporting requirements. Even though these were not emergencies, as our customers, you have a right to know what happened and what we are doing to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the monitoring periods listed below, we did not collect or submit the required samples or sample results.

Monitoring period	Required monitoring	What occurred
October 1-31, 2025	One monthly bacteriological sample from the distribution system	Zero valid bacteriological sample results were reported.
April 1-June 30, 2025	Endothall and Diquat monitoring at Entry Point A (TP001)	Required Endothall and Diquat sample results were not submitted.
January 1-December 31, 2025	Sodium monitoring at Entry Point A (TP001)	Zero sodium sample results were submitted.

What should I do?

There is nothing you need to do at this time.

What is being done?

Moscow Water Department is revising its bacteriological sampling plan to require one sample each month, establishing a compliance calendar for bacteriological and chemical monitoring, and assigning primary and backup personnel to verify that samples are collected and results are submitted by each deadline. The system will continue monitoring in accordance with its Drinking Water Watch sample and compliance schedules.

For more information, please contact **Carl Stevenson, Certified Operator in Direct Charge** at 901-877-3585 or Moscow Water Department, 14075 Highway 57, Moscow, TN 38057.

Please share this information with all other people who drink this water, especially those who may not have received this notice directly, such as people in apartments, nursing homes, schools, and businesses. You can do this by posting this notice in a public place or distributing copies by hand or mail.

Notice issued by	Moscow Water Department
State Water System ID	TN0000477
Date distributed	6/18/2026