

APPROACH SECTION

APPROACH TABLE

12" Minimum Pipe Cover

	Appr	Width*	Min**
APPROACH TYPE	Min	Max**	Radius
Residential, Three or More	24'	30'	20'
Commercial (One Way)	20'	30'	20'
Commercial (Two Way)	24'	40'	20'

PAVED APPROACH

STRUCTURAL SECTION **

- 2.5" Surfacing (Required)
 - 6" Base
 - 9" Subbase

- Culvert Pipe

- * Does not include required 2' gravel shoulder on each side of approach.
- ** Or based on applicable commercial design vehicle.

SERVING THREE (3) OR MORE PROPERTIES

N.T.S.

NOTES:

- 1. Approaches spacing shall conform to section 3000 of the ACCHD Manual.
- 2. Ingress/Egress by forward motion only.
- 3. Culvert pipe shall be 12" min. diameter. Culvert pipe shall extend to the intersection of the ditch line and the 4:1 approach foreslope. Pipe material shall be either 0.064" thick corrugated steel, 0.060" corrugated Aluminum or Class V reinforced concrete.
- 4. For approach serving primarily commercial trucks refer to section 3061.050.
- 5. Serving One (1) Commercial Property or Three (3) or More Residences.

REVISED 01/22

ASSOCIATION OF CANYON COUNTY HIGHWAY DISTRICTS CANYON COUNTY, IDAHO

COMMERCIAL & MULTIPLE RESIDENTIAL APPROACH

STANDARD DRAWING ACCHD-106