

		STD SETUP	COMPRESSED AIR DRYER	OGDEN MODEL 9090 SETTING
<b>S V</b>	SETPOINT VALUE	160		160
<b>ASP1</b>	ALARM SETPOINT	18		18
<b>rr</b>	RATE RAMP	0		0
<b>ofse</b>	OFFSET	0		0
<b>shif</b>	DISPLAY SHIFT	0		0
<b>pb</b>	PROPORTIONAL BAND	18		40
<b>E1</b>	INTEGRAL	120		20
<b>Ed</b>	DERIVATIVE	30		30
<b>LoCL</b>	LOCKOUT	1		1
<b>SEL</b>	SELECT	0		0
<b>CE</b>	CYCLE TIME	20		1
<b>in</b>	INPUT TYPE	0		0
<b>ALAI</b>	ALARM TYPE	2		2
<b>ANY1</b>	ALARM HYSTERESIS	0.5		0.5
<b>CF</b>	DEGREES C OR F	0		0
<b>rESo</b>	RESOLUTION	0		0
<b>ConA</b>	CONTROL ACTION	1		1
<b>ErPr</b>	ERROR PROTECTION	1		1
<b>HYSE</b>	CONTROL HYSTERESIS	0.5		0.5
<b>LLiE</b>	LOW RANGE	0		
<b>HLiE</b>	HIGH RANGE	400		300

1/10/2007