



**Ottawa County Health Dept.**  
**Environmental Health Services**  
 12251 James Street, Suite 200  
 Holland, MI 49424  
 Phone: (616) 393-5645  
 Fax: (616) 393-5643

**RECORD OF  
 FINAL INSPECTION  
 WATER WELL SYSTEM**

Parcel # 70-03-09-390-019  
 Permit # 13-475  
 Corres. SDS Permit # \_\_\_\_\_

NOTE: Since many factors contribute to the failure of a water well system, this department cannot guarantee any length of service or the quality of water produced.

See attached GIS dated 06/09/2014.

See Attached Sewage Final Dated \_\_\_\_\_

Owner or Builder Roosevelt Ridge Condo's  
 Township Spring Lake  
 Location 17641 Connie Drive  
 City Spring Lake Zip 49456  
 Plat Roosevelt Ridge Condo's Lot \_\_\_\_\_  
 Installed by Central Wells & Pumps, Llc  
 Submit Report to Roosevelt Ridge Condo's  
 Address 17648 Dustin  
 City Spring Lake Zip 49456

Well Data: New  Replacement  Type III Private  Other  Well-Inspection Date: 06/09/2014  
 Existing Well Abandoned: Yes  No  Properly Plugged: Yes  No   
 Depth Measured: Yes ; 37 ft. deep No  Casing Grouted: Yes  No  N/A  Material Used Bentonite Slurry  
 Well Head: Approved Sanitary Well Seal: Yes  No  N/A  Pitless adapted: Yes  No  N/A   
 Pitless Properly Vented: Yes  No  Approved buried horizontal line material: Suction  Pressure   
 Buried horizontal suction line properly protected: Yes  No  NA   
 Location: Basement  Basement offset  Well pit  Well house  Yard (pitless)  Other \_\_\_\_\_  
 Protected from surface water runoff or flooding: Yes  No   
 Isolation Distances: Nearest Property Line >10 ft. On-site Sewage Disposal System >50 ft.  
 Other potential sources of contamination 69 ft. Type: Other

**WATER QUALITY RESULTS**

Sample analyses by:  County Affiliated MDPH Laboratory  
 County Approved Private Laboratory: \_\_\_\_\_

WATER ANALYSIS	DATE SAMPLED	RESULTS	MAXIMUM CONTAMINANT LEVELS
Nitrates (NO <sub>3</sub> as N)			10 PPM (mg/l)
Bacteriological – 1st			0 Coliform/100 ml OR ND
Bacteriological – 2nd			
Bacteriological – 3rd			

**BASED ON THE INFORMATION OBTAINED**  
 Well Construction & Record:  
 ACCEPTABLE  NOT ACCEPTABLE   
 Water Sample Quality:  
 ACCEPTABLE  NOT ACCEPTABLE   
**STATUS OF FINAL WELL APPROVAL**  
 Approved  Disapproved   
 Date: 06/09/2014  
Kellie Mier  
 Inspected By

Comments: Irrigation Well



www.miOttawa.org

# OTTAWA COUNTY HEALTH DEPARTMENT

Irrigation Well Final

**Address:** 17641 Connie Dr.

**Parcel:** 70-03-09-390-019

**Date:** 06/09/2014

**EH Specialist:** Kellie Miller

12251 James Street Holland, Michigan 49424 (616) 393-5645 Fax (616) 393-5643



1: 480

1in. = 40 ft.