

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Inst/SL/01/25-26 Dated: 23/05/25

It is certified that an inspection team headed by Digvijay Singh (Chemist)

(Name of Officers with designation) from CHC Patti PHED inspected

the Ganga Prasad Singh Public School, Tehsil - Sadar (Name & Address

of the school) on 23/05/2025 (date of inspection) and on the basis of Water Test

Report (Attached) bearing no. UPJN(R)PBH/DL/0306 dated 23/05/25 of

District Level Water Analysis Laboratory

V.P. Jal Nigam (Rural) (PHED Lab)

certified that the Ganga Prasad Singh Public School (Name of school) has safe drinking

water facilities for the students and members of staff of the institution. School is also

maintains the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One year

Signature with Seal: 8
Name : Pratapgarh
Designation : Executive Engineer
Name & Address of the Office / Department : Division Office, U.P. Jal Nigam (Rural)

To The Manager

(Name & Address of the Institution)

Ganga Prasad Singh Public School,

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Test Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
Pratapgarh
Address- District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
Sukhpalnagar , Pratapgarh - 230001

Report No:	UPJN(R)/PBH/DL/5306	Issue Date:	23-05-2025		
Remark					
Contact Person:	Digvijay Singh	Address:	UPJN Pratapgarh	Page No	1/1
				Mob:	9169048466

Customer Details

Office Name and Address	Ganga Prasad Singh Public School , Plot No. - 1409- Vill./Post-Gondey, Chanwar , Tehsil-Sadar, Pratapgarh
Ref Letter No & Date	Dated - 20/05/2025

Basic details of sample

District	Pratapgarh	Block	Sadar
Gram Panchayat	Gondey	Village	Gondey
Habitation	-	Location	Plot No. - 1409- Vill./Post-Gondey, Chanwar , Tehsil-Sadar, Pratapgarh
Water Source	Submersible pump	Sample No.	5306
Quantity of Sample	1 ltr.	Date of Collection	20-05-2025
Receiving Date	20-05-2025	S. Collector	Sri Pradeep pandey
Sample Depositor	Sri Shivendra Vikram singh	Sampling Method	As per IS 17614: Part 1 : 2021
Analysis Start Date	21-05-2025	Analysis Completion Date:	21-05-2025
Temperature : 24.8°C		Humidity: 50%	

Technical Data of Analysis

	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.52	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity NTU	0.90	1	5	IS 3025 (Part 10):2023
3	TDS mg/L	302	500	2000	IS 3025 (Part 16):2023
4	Fluoride mg/L	0.400	1	1.5	IS 3025 (Part 60):2008
5	Total Hardness mg/L	240	200	600	IS 3025 (Part 21):2019
6	Total Alkalinity mg/L	54	200	600	IS 3025 (Part 23):2023
7	Chloride mg/L	15	250	1000	IS 3025 (Part 32):2019
8	Iron mg/L	0.10	1	No relaxation	IS 3025 (Part 53):2003
9	Nitrate mg/L	4.12	45	No relaxation	APHA 4500-No3UV Screening method 2017
10	Sulphate mg/L	7.82	200	400	IS 3025 (Part 24):2022

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Analysed By- 
Deputy Technical Manager

Authorized Sign 

