

2025 Stormwater Repair Log List

Job Number	Location	Type of Repair	Work Performed	Date
1	Buttermilk Hollow / Pittsburgh McKeesport Blvd.	Storm Basin Clog	Catch basin overflowing and causing pooling / freezing water at intersection	4/8/2025
2	Cypress Street	Storm Basin Repair	Replaced brick work & repaired curb	4/29/2025
3	Glencairn Street / Outlook Drive	Storm Basin Replacement	Replaced entire storm basin, top, grate & frame	5/1/2025
4	Miller Road	TEMP. Trench Drain Repair	Repaired brick work and secured grates for the time being until full precast repair can be made	5/7/2025
5	Constitution Avenue / Roberta Drive	Storm Basin Repair	Re-bricked & reset new lid on basin top	5/8/2025
6	High Street	Storm Basin Repair	Repaired basin & fixed grate that was falling in	5/13/2025
7	Curry Hollow Road	Storm Basin Repair	Basin top replacment, to repair basin with no frame or grate	5/15/2025
8	Castle Drive	Storm Basin Repair	Replaced grate	6/3/2025
9	Division Street / Cherry Street	Storm Basin Repair	Replaced brick work inside of basin and reset grate	6/4/2025
10	Shady Lane (behind Roses in shopping center)	Storm Basin Repair	Poured a new cement basin to correct and fix corosion & sink hole & replaced storm grate	6/12/2025
11	School Street	Storm Basin Repair	Repaired brick work, & replaced grate & frame	6/26/2025
12	Hoffman Blvd.	Storm Basin Repair	Repairs made to fix sink hole in roadway & installed new basin grate/frame & curb	6/30/2025
13	Division Street	Storm Basin Repair	Replaced broken lid and bick work inside of basin	7/7/2025
14	Hazel Street	Storm Basin Repiar	Replaced existing basin that was collapsing over top of our sewer lnw	7/16/2025
15	Regis Avenue	Storm Culvert	Dredged culvert & removed debris to prevent flooding and help water intake	7/23/2025
16	Inland Avenue	Storm Basin Repiar	Removed & replaced falling bricks, and cleaned out basin	7/23/2025
17	Castle Drive	Storm Basin Repiar	Repairs made to brick work and improvements made to collapsing basin	7/24/2025
18	Edgewood Avenue	Added Curb to Storm Basin	Added curb around storm basin to help with water intake	8/12/2025
19	Municipal Road	Storm Basin Repair	Added new basin grate & frame	8/19/2025
20	Campbell Circle	Storm Basin Repair	Replaced crumbling grate and frame	8/21/2025

21	Majka Street	Storm Basin Repair	Replaced brick work & new basin grate & frame	9/8/2025
22	Joyce Drive	Storm Basin Repair	Repairs made to 2 basins that were collapsing. Replaced brick work, and added new basin grates & frames	9/19/2025
23	Fleetwood Drive	Storm Basin Repair	Replaced grate that was falling apart on basin	10/9/2025
24	Curry Hollow Road	Storm Line Repair	Made repairs to over 100ft of coroded main storm line	10/30/2025
25	Timothy Drive	Storm Basin Replacement	Poured new basin and replaced grate and frame	11/5/2025
26	Kings Road / Saniel Drive	Storm Line Replacement	Replaced storm line, grate & frame, and refinished outfall	11/12/2025
27	Buttermilk Hollow	Cleaned Outfall	Outfall dregged to prevent flooding	11/20/2025

Proposed BMPs per MS4 Permit Requirements

**** all proposed BMPs are pending the approval of grant funding at this time ****

Streets Run

	Shara Drive/Mifflin Hill	Dry Extended Detention Basin	To Be Determined	To Be Determined
	Miller Road	Bioretention (Rain Garden)	To Be Determined	To Be Determined
	Nordeen Drive - Park	Detention Facility OR Bioretention (Rain Garden)	Planning in Progress	To Be Determined
	Fidelity Drive "Soccer Field"	Dry Extended Detention Basin	To Be Determined	To Be Determined

Homestead Run

	Duquesne Avenue	Bioretention (Rain Garden) with Infiltration	To Be Determined	To Be Determined
	Spring Street	Bioretention (Rain Garden)	To Be Determined	To Be Determined
	5th Avenue - Playground	Infiltration Basin	Planning in Progress	To Be Determined

UNT to Mon River

	CCAC South Campus	Bioretention with Bioswale OR Bioretention Only	To Be Determined	To Be Determined
--	-------------------	---	------------------	------------------

UNT to Mon River – New England Road (Total Phosphorus Reduction Requirement Only)

	Pine Creek Run Road	Bioswale	To Be Determined	To Be Determined
--	---------------------	----------	------------------	------------------