

2025 Sanitary Sewer Repair Log List

Job Number	Location	Type of Repair	Work Performed	Date
1	Behind Glencoe Drive - Curry Hollow P.S	Force Main Repair	Repairs made to stop sewage leak coming from force main	1/29/2025
2	Worton Blvd	Sewer Line Repair	Major root ball removed & repairs made to sanitary sewer line	2/12/2025
3	Frank Street	Sewer Line Repair	Repairs made to our collapsed main line	3/11/2025
4	Pine Run Road	Sewer Line Repair	Repairs made to section of line to prevent the restriction of flow	3/14/2025
5	Glencoe Drive	Exploratory Work	Exploratory digging to locate manholes	3/27/2025
6	Antionette Avenue	Sewer Line Repair	Repairs made to prevent future back ups	4/15/2025
7	Greensprings Avenue	Capped Sewer Line	Capped abandoned/collapsed tap to prevent water intake to pump station	6/10/2025
8	Lebanon Church Road	Replacement of Manhole Lid	Removed concrete from manhole & replaced manhole ring	6/11/2025
9	4th Avenue	Sewer Line Repair	Replaced collapsed sewer line that was found while televising for a dye test	6/25/2025
10	Anna Avenue	Sewer Line Maintenance	Cut & cleaned all roots out of our line	7/8/2025
11	Old Elizabeth Road	Replacing Sanitary Main Line	Replaced line that is crumbling and rooted	8/1/2025
12	Homestead Duquesne Road	Raised Manhole	Uncovered a burried manhole & raised	8/4/2025
13	Old Elizabeth Road	Replacing Sanitary Main Line	Replaced main line that had a a massive belly & was rippling	8/8/2025
14	Alberta Drive	Manhole Lid Replacement	Replaced cracked lid and riser on manhole	8/22/2025
15	Bost Drive	Replacing Sanitary Main Line	Replaced collapsed main sanitary line	8/26/2025
16	Pine Run Road	Replaced Manhole	Replaced manhole that was causing back ups	9/9/2025
17	Homestead Duquesne Road	Sewer Line Repair & Raised Manhole	Replaced seperated sewer line, & uncovered / raised manhole	9/18/2025