

Article 13. Miscellaneous Provisions.

Section 13.01 The Authority shall have the right of access at reasonable times to any part of the Improved Property served by the MWS as shall be required for purposes of inspection, measurement, sampling and testing and for performance of other functions relating to service rendered by the Authority through the MWS.

Section 13.02 Policy and Procedure Instructions. The Authority may adopt Policy and Procedure Instructions from time to time as it shall deem necessary and proper in connection with the use and operation of the MWS.

Section 13.03 Variance from Rules. No officer or employee of the Authority is authorized to vary these Rules without action by the Authority.

Section 13.04 Control of Service. The Authority reserves the right to restrict the use of Sewer service whenever the public welfare may require it.

Section 13.05 Notice of Change of Ownership. Each Owner must give the Authority notice of any change of ownership of any Improved Property. Failure of any owner to receive his bills shall not be considered an excuse for non-payment, nor shall such failure result in an extension of the time during which the net bill is payable.

Section 13.06 Drainage of Swimming Pools. Upon request, the pool drain may be connected to the sanitary sewerage system subject to review by the Authority Engineer and approval by the Nazareth Borough Municipal Authority and the following criteria:

A. It shall be unlawful for any person to discharge the contents of a public swimming pool into sanitary sewer except in the manner specified in this section. The size of pipe carrying discharge water shall not be larger than two inches and shall not be under head to exceed twenty (20) feet. If the water is discharged by pumping, the rate of

flow shall not exceed one hundred (100) gallons per minute. Each public swimming pool discharging to a sanitary sewer shall be equipped with an approved separator to preclude any possibility of a backflow of sewage into the public swimming pool piping system.

B. Filter backwash lines shall be connected directly to the sanitary sewer system as follows:

1. Sand filter backwash shall be connected directly to the sanitary sewer.

2. Diatomaceous earth filter backwash shall be connected to the sanitary sewer through settling tanks with four months storage capacity. These tanks shall be readily accessible for removing solid waste for disposal.

C. The chlorine residual shall be made less than 0.5 mg/L. Once the pool is dechlorinated a representative from the Nazareth Borough Municipal Authority must test the pool water to verify chlorine is removed before discharge into the sanitary sewer system. The Authority must be contacted 48 hours in advance of the intended discharge.