



Government of Tripura
Directorate of Fire & Emergency Services
Tripura, Agartala.

Phone: 0381-2326451 Fax: 0381-2324826. Email: dfireservicetripura@gmail.com. Website: www.fireservice.tripura.gov.in

No. 3-8/TFES/2026/ 413-10

Dated, Agartala, the 26th Feb, 2026

To
The Manager,
Garia Academy (Model),
HQ- Garia Hathai, Atharabla, Udaipur, Gomati, Tripura.
E-Mail: gariaacademy@gmail.com, Cont. No. 8787489580

Subject: - Issuance of renewal Fire NOC.

Sir,

With reference to letter dated 05/01/2026, it is hereby certified that the building/premises as per description below has been inspected by the officer concerned of this department on 28.01.2026. In respect of implementation of Fire Safety measures, it was found that said school building have complied with the Fire Prevention and Fire Safety requirements in accordance with provisions of the Part-IV of the latest National Building Code, 2016. Therefore, the school premises/building is issued Temporary NOC with effect from 26-02-2026 for a period of 03(three) months subject to compliance of the conditions for the validity of Fire NOC.

Name & address of the proposed building/premises: - "Garia Academy (Model) ", Garia Hathai, Atharabla, Udaipur, Gomati, Tripura.

Issued on 26-02-2026 at Agartala.

N.B. Department is switching over offline issuance of NOC to online shortly. Therefore provisional/Temporary NOC is issued for period of 03 (Three) months. Thereafter, application to be submitted online (www.edistrict.tripura.gov.in) for Final Fire NOC.

Yours Faithfully


Joint Director

Tripura Fire & Emergency Services.

Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make the owner/management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the Fire Safety Certificates stands null and void.
4. Water reservoir should always be kept full up to the brim.
5. The entrance and exit and the water reservoir should always be free from any obstructions.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

Copy to: -

1. The Divisional Fire Officer, Gomati District, Tripura for favour of information.
2. The OC, Udaipur F & ES Station for information.