

Changzhou Senhong Decorative Materials Co., LTD.

TEST REPORT

SCOPE OF WORK

AQUA FLOOR (Laminate Floor)

REPORT NUMBER

200424005SHF-011

TEST DATE(S)

2020-04-24 - 2020-05-27

ISSUE DATE

2020-05-27

PAGES


5

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2020)

© 2020 INTERTEK

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on assigned page.
- 2.This report is invalid without authorized person's signature.
- 3.This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.
- 6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.
- 7.The report was digital signed by Shang Hai, Intertek Group plc, please using Adobe Acrobat Reader to verify the authenticity.



Test Report

Issue Date: 2020-05-27 Intertek Report No. 200424005SHF-011
 Applicant: Changzhou Senhong Decorative Materials Co., LTD.
 Address: Qinxin Village, Yaoguan Town, Wujin District, Changzhou, Jiangsu, China
 Attn: Tonny
 Test Type : Performance test, samples provided by the applicant.

Product Information

Product Name	AQUA FLOOR (Laminate Floor)	Brand	/
Sample Description	Good Condition	Sample Amount	100 pcs
		Received Date	2020-04-24
Sample ID	Model	Specification	
S200424005SHF.009	/	1215x145mmx12mm	

Test Methods And Standards

Test Standard	ASTM D6007-14
Specification Standard	/
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1.This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.

Report Authorized



 Name: Flora Fan Name: Tod Qian
 Title: Reviewer Title: Project Engineer



Test Report

Issue Date: 2020-05-27

Intertek Report No. 200424005SHF-011

Test Items, Method and Results:

Test Item: Formaldehyde content test

Test Method: As per ASTM D6007-14 small scale chamber method, formaldehyde content was detected by UV-VIS spectrophotometer.

Test condition:

Chamber type:	0.225 m ³ stainless steel chamber
Climatic conditions:	25°C, 50% R.H.
Air exchange rate:	0.5 h ⁻¹
Loading factor:	0.43 m ² /m ³
Test result:	0.06 ppm

Note:

1. ppm = parts of formaldehyde per million parts air
2. Detection limit = 0.02 ppm
3. The sample was conditioned at 24±3 °C, 50±5% relative humidity for seven days before the testing.
4. Test location: Central Chemical Lab of Intertek Testing Services Ltd., Shanghai
Address: Block B, Jinling Business Square, No. 801, Yi Shan Road, Shanghai, China



Test Report


Issue Date: 2020-05-27

Intertek Report No. 200424005SHF-011

Appendix A: Sample Received Photo



Front View(Test Surface)



Back View



Revision:

NO.	Date	Changes	Author	Reviewer
200424005SHF-011	2020-05-27	First issue	Tod Qian	Flora Fan