

# Witness Conformance Certificate

Certificate register No. **246126156-4**

Applicant **PT Indonesian Fire Equipment Systems**  
Jl. MT Haryono No. 22,  
Ruko Haryono Palace – Gn. Samarinda Baru  
Balikpapan Utara – Kalimantan Timur  
Indonesia 76125

Product **Fire Fighting System**  
Agent – KV LITE 3% AFFF (Aqueous Film Forming  
Foam) @9% - 3times Concentration C6 Formulation


Test Standard **ENGINEERED SYSTEM**  
USING IFES SIMULATOR ON SIMULATED 45  
LITER V-12 ENGINE WITH 2.05 x 2.05 M LOWER  
TRAY. SYSTEM DESIGN COMPLIANT TO IFES  
DESIGN RULES.

Test Result Recorded in Report No. 246126156R

The above products has been tested at PT H&H Utama International's Yard, Jl. Mulawarman Batakan Kecil – Balikpapan, Indonesia.

The Certificate is based on single evaluation of the above mentioned products, and it is valid until **23 March 2024** or any modifications apply on above mentioned products.

Jakarta, 17 April 2023

  
**I Nyoman Susila**

PT TUV Rheinland Indonesia  
Menara Karya 10<sup>th</sup> Fl.  
Jl. HR Rasuna Said  
Block X-5 Kav. 1-2,  
Jakarta 12950  
Indonesia

© TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.