

Witness Conformance Certificate

Certificate register No. **246126156-5**

Applicant **PT Indonesian Fire Equipment Systems**
Jl. MT Haryono No. 22,
Ruko Haryono Palace – Gn. Samarinda Baru
Balikpapan Utara – Kalimantan Timur
Indonesia 76125

Product **Fire Fighting System**
Agent – KV LITE ECO - LT
Anti Freezing Foam (Low Temperature)


Test Standard **ENGINEERED SYSTEM**
USING IFES SIMULATOR ON SIMULATED 45
LITER V-12 ENGINE WITH 2.05 x 2.05 M LOWER
TRAY. SYSTEM DESIGN COMPLIANT TO IFES
DESIGN RULES.

Test Result Recorded in Report No. 246126156R

The above products has been tested at PT H&H Utama International's Yard, Jl. Mulawarman Batakan Kecil – Balikpapan, Indonesia.

The Certificate is based on single evaluation of the above mentioned products, and it is valid until **23 March 2024** or any modifications apply on above mentioned products.

Jakarta, 17 April 2023


I Nyoman Susila

PT TUV Rheinland Indonesia
Menara Karya 10th Fl.
Jl. HR Rasuna Said
Block X-5 Kav. 1-2,
Jakarta 12950
Indonesia

© TÜV, TÜEV and TUV are registered trademarks. Utilisation and application requires prior approval.