



ADDENDUM

05 | 250130

School District of Lancaster

McCaskey High School Stadium Projects
Lancaster, PA

Date of Addendum: 30 January, 2025

Marotta/Main Architects Project No.
24-SDL-03

The original Project Manuals and Drawings dated 06 January, 2025 for the project noted above, are amended as noted in this Addendum No. 05.

Receipt of this Addendum shall be acknowledged by inserting its number and date in the space provided on the Bid Form.

This Addendum consists of 2 Pages and all attachments listed.

CLARIFICATIONS

05.01 Bid due date time remains at 3:00pm.

05.02 The clouded notes with quantities on Drawings S1.2 and S1.3 are in addition to the tables.

05.03 Refer to Drawing S1.2, Detail A/S1.2, The vertical and overhead repair material (Note 10B in A/S1.2) applies to repair quantities shown for the underside of bleacher concrete and vertical wall facing the track (refer to 1/S1.2 & 1/S1.3 schedule of restoration for quantities + front of wall repairs, V.I.F.). The horizontal repair material (Note 10A in A/S1.2) refers to the top side of bleacher concrete (refer to 2/S1.2 and 2/S1.3 schedule of restoration for quantities). Depth of repair for top side of concrete bleacher to be verified in field.

SPECIFICATIONS

VOLUME 1 – LEGAL SPECIFICATIONS

05.04 Refer to Specifications Section 04 01 10 MASONRY CLEANING, DELETE ITEM 3.3 AND 3.4 in their entirety.

VOLUME 2 – TECHNICAL SPECIFICATIONS

05.05 Refer to Specifications Section 02 40 00 UNIT MASONRY 2.11, ADD item F to read as follows: 'F. Sealer: Sealer for existing masonry walls shall be Basis-of-Design: W.R. Meadows Intraguard or equal.'

VOLUME 3 – MEP & SITE/CIVIL SPECIFICATIONS

No items.

DRAWINGS

ARCHITECTURAL DRAWINGS

05.06 Refer to Drawing A2.2 HOME EXTERIOR ELEVATIONS, 4/A2.2 Home East Elevation, REVISE note to read as follows: 'CLEAN AND COAT STL. @ BACK ELEVATION (TYP.), INSTALL NEW SEALANT AT JOINTS BETWEEN STEEL AND ADJACENT MASONRY'

STRUCTURAL DRAWINGS

No items.

PLUMBING DRAWINGS

05.07 Refer to Drawing P3.1, ENLARGED PLUMBING PLANS Details # 1 & 2

- a. REVISE Fixture Tag on the exterior fixture at entry way to WOMENS RESTROOMS from DF-1 to be **EW-1**.

05.08 Refer to Drawing P3.2, ENLARGED PLUMBING PLANS Details # 1 & 2

- b. REVISE Fixture Tag on the exterior fixture at entry way to MENS RESTROOMS from DF-1 to be **EW-1**.

MECHANICAL DRAWINGS

No items.

ELECTRICAL DRAWINGS

No items.

END OF ADDENDUM 05

Respectfully Submitted,

Connie King, AIA, ALEP, GGP
Marotta/Main Architects, Inc.

Attachments:

None