

The contents of this Addendum alter and amend the drawings and specifications and take precedence over the related items therein. Bidders shall include the cost of all items in their Bids.

GENERAL INFORMATION

1. BID DUE DATE HAS BEEN PUSHED BACK TO OCTOBER 7, 2024, 2:00 pm EST.

CLARIFICATIONS:

1. Bidders shall assume all 2nd Floor HVAC ductwork is to be run in the ATTIC space, and NOT above the 2nd floor ceilings. Ductwork to be insulated according to HVAC documentation requirements.

REQUESTS FOR INFORMATION:

None.

DRAWINGS:

None.

REQUESTS FOR SUBSTITUTION:

None.

**END.
MG ARCHITECTS, LTD.**

SOG/lev
Attachments:

- None.