

From: Matt Keller <matt@pinnacleengineeringinc.com>

Sent: Monday, June 13, 2022 5:01 PM

To: Beth Werner <glidefire@glidefire.org>

Cc: Paul Bentley <paul@paulbentleyarchitect.com>; Ted Damewood <2201@glidefire.org>

Subject: RE: Glide Fire District: Question - 2nd request

I think the problem is that the Structural plans for the project did not match the architectural plans. The structural plans showed those walls as 2x6 at 16" O.C. without the stagger. With the stagger included, flat blocking can be used between the studs as opposed to full depth blocking. Would that help?

I don't believe I had a message from Mark. Either way I can give him a call back to help answer his questions.

Regards,

Matt Keller, PE, CSI
Registered Geotechnical Engineer
President