

NOTICE ABOUT YOUR DRINKING WATER

Arsenic Maximum Contaminant Level (MCL) Exceedance

Public Water System Name: PILLSBURY LAKE VILL DIST PWS ID: 2462050

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards.

The Running Annual Average (RAA) calculation represents the average of all sample results collected within a one-year period. Your drinking water RAA calculation is above the enforceable MCL for the following:

Contaminant and MCL	Detected Level	Date Sampled	Running Annual Average	Compliance Period
Arsenic 0.0050 mg/L	0.0014 mg/L, 0.0094 mg/L, 0.0027 mg/L, 0.0090 mg/L, 0.0080 mg/L	April 7, 2022, Quarter 2 of 2022	0.0061 mg/L	Quarter 2, 2022
	0.0094 mg/L, 0.0027 mg/L, 0.0090 mg/L, 0.0080 mg/L, 0.011 ng/L	January 6, 2022, Quarter 1 of 2022	0.0080 mg/L	Quarter 1, 2022

This is not an emergency. If it had been you would have been notified immediately. *Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.*

What should I do? It is not necessary to use alternate water; however, if you have specific health concerns, please contact your health care professional. General health-related questions may be directed to the EPA Safe Drinking Water Hotline at 1-800-426-4791.

Steps being taken to correct the situation: Another Arsenic tank will be re-bed with new media and placed in service

Expected Resolution Date: 09/01/22

Contact Name: Craig McGraw Company: Aquamen

Address: 668 1st New Hampshire Turnpike Northwood, NH 03261 Telephone Number: (603)942-6138

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example; people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.