

ELK RIVER PUBLIC UTILITY DISTRICT

BASIC GUIDELINES FOR NEW GAS SERVICE

- ERPUD refers to the current edition of the International Fuel Gas Code and the manufactures instructions when performing safety inspections. (All equipment installed must meet the aforementioned codes and instructions.)
- Gas meter location must maintain 3 feet minimum clearance from any potential ignition source, combustion air intake, vent pipe, foundation vent, window, or crawl space door.
- Gas pipe penetrations thru any masonry wall must be cased to protect piping from corrosion.
- Gas piping shall be installed under no strain or binding and supported by metallic strap and / or hangers.
- ERPUD requires a rough in (visual inspection) to be performed before any piping is concealed. (The customer will be responsible for notifying ERPUD for the completion of a rough in inspection before any piping or vent is concealed.)
- Customer’s gas piping shall withstand an air test performed by the installer of at least 40 psi for 20 minutes verified on site by an ERPUD representative.
- ERPUD recommends if you have any questions, please call us prior to the installation at (931) 455-9311. Every effort will be made to meet specific customer requests.

