



**Making Geothermal a
Reality at the NYCSCA St.
John Village Campus
Redevelopment Project**

Pioneers in Sustainable Geothermal Solutions

- Geothermal consulting and design for nearly 30 years
 - Specialize in the Ground Heat Exchangers (GHX), coordination with the MEP, civil, architect, and building energy modeler
 - Experience in:
 - Campus and District Scale Systems
 - Open Loop
 - Closed Loop
 - Standing Column Wells
 - Energy Piles
- 

Pioneers in Sustainable Geothermal Solutions

- Founding member, LI-GEO established in 2012.
- Founding and Charter member, NY-GEO established in 2014.
- Influential on NYC geothermal Local Law 32 of 2013 and Local Law 6 of 2016
- Member, NYSERDA's Renewable Heating and Cooling department advisory committee.
- IGSPHA geothermal design trainer.
- NYSERDA-certified GSHP rebate contractor.
- Committee member, joint ANSI/CSA C448 GSHP Design and Installation Standards.
- Member, Urban Green Advancing Electrification Advisory Committee.
- Advisor to Mayor's Office, NYC EDC, etc. regarding the viability of greater deployment of geothermal technologies within the five boroughs.

Our Services

- Subsurface Conditions Due Diligence
- Feasibility Study
- Environmental Due Diligence
- Thermal Conductivity Testing
- Geoexchange Modeling
- Ground Heat Exchanger (GHX) Design
- Filings and Notifications
- Construction Administration
- Field Inspection during Construction
- Start-Up and Commissioning Support
- Operation and Maintenance Support
- Troubleshoot Operating Systems




General Overview of Geothermal Energy




PHOTO SOURCE: ADOBE STOCK PHOTOS

What is Geothermal Energy?

- Geothermal energy is a form of renewable energy derived from the heat stored beneath the Earth's surface.



Geothermal: How It Works




Ground Source Heat Pump (GSHP) & Geothermal Boreholes


- A heat pump with a ground heat exchanger transfers heat between the ground and a building by circulating a Heat Transfer Fluid through underground loops, absorbing heat from the ground in winter and releasing heat into the ground in summer.
- Geothermal systems can reduce energy consumption by approximately 25% to 50% compared to air source heat pump systems.
- Ground Source Heat Pumps more than 20 year life expectancy.
- Geothermal underground infrastructure 25 - 50 year life expectancy minimum typical.

Conventional vs Alternative

Cooling



Heating



Standard vs. Geothermal Efficiency Comparison

Basic Geothermal Principles

Geoexchange Benefits

- Elimination of:
 - Conventional Mechanical Systems
 - Fossil Fuel Dependence and Price Fluctuations
 - Legionella Risk
- Reduction of:
 - Carbon Footprint
 - Maintenance
 - Noise & Vibrations
 - Mechanical Room Space
 - Roof Space
 - Eyesores

Cooling Towers



Boiler Plant



Chiller plant




Geexchange Technologies

Typical Designs:


- Vertical Closed-Loop System
- Open-Loop System
- Hybrid Systems
- District-scale/Thermal Energy Networks

Less Common Design Alternatives:


- Horizontal Closed-Loop
- Closed-Loop Surface Water
- Standing Column Well




Typical Closed Loop System



Typical Open Loop System





Open-Loop Groundwater Heat Pump with Isolation Heat Exchanger



Source: Appalachian Heating

Typical Standing Column Well System



Source: PWGC

St. John Villa Campus Redevelopment Project

- Redevelopment of the former St. John Villa campus at 57 Cleveland Place in the Arrochar section of Staten Island to include a new primary/intermediate school, two separate intermediate/high schools, an athletic field with bleachers, renovated Chapel Building, a maintenance building, three parking lots, and landscaped areas.
- Design team led by architect Pei Cobb Freed & Partners
- Geothermal system design led by P.W. Grosser Consulting
- Key design consultants include:
 - Loring Consulting Engineers - mechanical design; heat pump sizing
 - SOCOTEC - energy modeling
 - Shenoy Engineering, PC - domestic hot water, plumbing, and electrical design




St. John Villa Campus Redevelopment Project



St. John Villa Campus Geothermal System Layout

Geothermal System Summary

- 276 Vertical Closed Loop Boreholes
- Average of 10 boreholes on each circuit run to manifold
- Combined manifold, plus separate circulation pumps, air/dirt separators, expansion tanks located under Bleachers
- Supply and return mains run to each of the PS/IS, IS/HS and Chapel Buildings
- GSHPs located in each building's mechanical room




Feasibility Study

- Provide client with conceptual design and scoping out a project. Evaluate if the site is suitable for a geothermal system.
- The goal is to determine the project's viability and outline the basic system parameters for field testing and a full-scale geothermal system.

Components


- Site Assessment
- Subsurface Conditions
- Design Heating & Cooling Loads
- Field Testing/ Thermal Conductivity
- Geothermal System Layout
- Construction Logistics
- Permitting Requirements
- Environmental Considerations
- Incentives (tax credits, utility rebates)
- Cost Analysis



Test Bore Installation

Field Testing Program – Closed Loop System


- American Well and Pump Co. - Driller
- Five test bores – 2 to 700' BGS, 3 to 500' BGS
- Install test loops and provide FTC test on each bore
- Different test loop depths and drilling techniques (air rotary vs mud rotary) employed to optimize full-scale system design
- Test loops to be incorporated into full-scale system



GEOTHERMAL TEST WELL DETAIL
(TYP. OF 5)
SCALE: NOT TO SCALE

FORMATION DESCRIPTION	DEPTH (FT)
Brown clay/grey clay	0'-40'
Small gravel, silty sand	40'-140'
Small gravel, sand, little red clay	140'-160'
Small gravel, silty sand, streak of clay	160'-260'
Small gravel, grey clay	260'-280'
Red clay	280'-320'
Multicolored clay	320'-340'
Weathered rock	340'-357'
Rock: schist, gneiss and serpentinite rock mix	357'-705'

Bore produced 30 gpm water at 660 ft; 60 gpm at 680 ft.



**PROPOSED TEST BORE
EXISTING SURVEY REFERENCE**

Ground Loop Design Modeling

Formation Thermal Conductivity Test Report

Date February 11-13, 2009
Location Staten Island, NY
Undisturbed Formation Temperature Approx. 54-55°F

Borehole Data – As Provided by Aquifer Drilling & Testing, Inc.

Borehole Diameter 8 3/4 inches, 0-191 ft
6 inches, 191-499 ft

Note: Six inch steel casing installed to 191 ft.

Drill Log	Reddish brown fine sand	0'-149'
	Granite gneiss	149'-159'
	Clay	159'-165'
	Granite gneiss	165'-181'
	Clay	181'-183'
	Grey serpentinite	183'-360'
	Schist	360'-499'

Note: Water flow observed of approximately 15 gpm at 207 ft, 100 gpm at 270 ft.

U-bend Size 1 1/4 inch HDPE
U-Bend Length 498 ft
Grout Type GeoPro TG Select
Grout Solids 400 lb sand per 50 lb bentonite
Grouted Portion Entire bore

Test Data

Test Duration 48.4 hrs.
Average Voltage 241.2 V
Average Power 8,177 W
Total Heat Input Rate 27,908 Btu/hr
Calculated Circulator Flow Rate 9.0 gpm
Standard Deviation of Power 0.25%
Maximum Variation in Power 1.50%

Est. Average Heat Capacity (Btu/ft ³ °F)	Thermal Conductivity (Btu/hr-ft-°F)	Est. Thermal Diffusivity (ft ² /day)
37.4	1.75	1.12

Formation Thermal Conductivity Test Report

Date February 9-11, 2009
Location Staten Island, NY
Undisturbed Formation Temperature Approx. 54-55.5°F

Borehole Data – As Provided by Aquifer Drilling & Testing, Inc.

Borehole Diameter 8 3/4 inches, 0-191 ft
6 inches, 191-498 ft

Note: Six inch steel casing installed to 191 ft.

Drill Log	Reddish brown fine sand	0'-157'
	Pink granite gneiss	157'-225'
	Green serpentinite	225'-305'
	Pink granite gneiss	305'-385'
	Grey schist	385'-498'

Note: Water flow observed of approximately 15 gpm at 365 ft.

U-bend Size 1 1/4 inch HDPE
U-Bend Length 498 ft
Grout Type GeoPro TG Select
Grout Solids 400 lb sand per 50 lb bentonite
Grouted Portion Entire bore

Test Data

Test Duration 47.0 hrs.
Average Voltage 240.9 V
Average Power 8,175 W
Total Heat Input Rate 27,902 Btu/hr
Calculated Circulator Flow Rate 8.88 gpm
Standard Deviation of Power 0.19%
Maximum Variation in Power 1.60%

Est. Average Heat Capacity (Btu/ft ³ °F)	Thermal Conductivity (Btu/hr-ft-°F)	Est. Thermal Diffusivity (ft ² /day)
36.8	1.82	1.19

Ground Loop Design Modeling

Input Parameters (Cont.)

Pattern		Modeling Time Period	
Vertical Grid Arrangement:	1 x 3	Prediction Time:	20.0 years
Borehole Number:	3	Long Term Soil Temperatures:	
Borehole Separation:	20.0 ft	Cooling:	52.5 °F
Bores Per Circuit	1	Heating:	52.5 °F
Fixed Length Mode	On		
Grid File	None		
File:			
Default Heat Pumps		Optional Hybrid Loads	
Manufacturer:	- Default Generic	Cooling	Heating
Series:	Generic High Efficiency	Geo Peak (%)	100%
Design Heat Pump Inlet Load Temperatures:		Geo Total (%)	100%
	Cooling (WB) Heating (DB)	Hybrid Peak (%)	0%
Water to Air:	67 °F 70 °F	Hybrid Total (%)	0%
Water to Water:	55 °F 100 °F		
Extra kW		Loads File	
Pump Power	0.0 kW	2023-05-30 - Club Cabin Loading.zon	
Cooling Tower Pump:	0.0 kW		
Cooling Tower Fan:	0.0 kW		
Additional Power	0.0 kW		

Final Design Modeling post TCT

Ground Loop Design Borehole Design Project Report - 5/30/2023



Project Name: Discovery Land - Club Cabin
 Designer Name: Michael Scanlon, PE
 Date: 5/30/2023 Project Start Date: 5/30/2023
 Client Name: Discovery Land Co.
 Address Line 1:
 Address Line 2:
 City: Phone:
 State: Fax:
 Zip: Email:


Calculation Results

Design Method:	Monthly	COOLING	HEATING
Total Bore Length (ft):		900.0	900.0
Borehole Number:		3	3
Borehole Length (ft):		300.0	300.0
Ground Temperature Change (°F):		N/A	N/A
Peak Unit Inlet (°F):		79.1	36.4
Peak Unit Outlet (°F):		88.3	32.7
Total Unit Capacity (kBtu/Hr):		76.0	50.4
Peak Load (kBtu/Hr):		76.0	50.4
Peak Demand (kW):		3.3	3.3
Heat Pump EER/COP:		22.6	4.4
Seasonal Heat Pump EER/COP:		31.4	4.5
Avg. Annual Power (kWh):		1.95E+3	4.79E+3
System Flow Rate (gpm):		19.0	12.6

Input Parameters

Fluid		Soil	
Flow Rate	3.0 gpm/ton	Ground Temperature:	52.5 °F
Fluid:	17.7% Propylene Glycol	Thermal Conductivity:	1.43 Btu/(h*ft**F)
Specific Heat (Cp):	0.94 Btu/(°F*lbm)	Thermal Diffusivity:	1.01 ft^2/day
Density (rho):	64.0 lb/ft^3		
Piping			
Pipe Type:	1 1/4 in. (32 mm) - SDR11		
Flow Type:	Turbulent		
Pipe Resistance:	0.104 h*ft**F/Btu		
U-Tube Configuration:	Single		
Radial Pipe Placement:	Average		
Borehole Diameter:	6.00 in		
Grout Thermal Conductivity:	1.20 Btu/(h*ft**F)		
Borehole Thermal Resistance:	0.208 h*ft**F/Btu		

Ground Loop Design Modeling



GLD

Software

Gaia

Geothermal

Ground Loop Design

Piping Report - 5/30/2023

System Summary

Total Pipe Length (ft):	1808.0
Total Circuit Pipe Length (ft):	1800.0
Modules Manifolds Pre-Manifold:	1 1 0
Number of Circuits:	3
Includes Balancing Valves	No
SystemFluid Type:	Propylene Glycol
System Fluid Volume (Gallons):	138.3
Antifreeze Percentage (%)	17.7% by Weight
Freeze Point Protection (°F):	20
Minimum Design Temperature (°F):	32

Operational Performance - PEAK LOAD Mode

System Flow Rate (gpm):	19.0
System Pressure Drop (ft.hd.):	6.8
Max GHX Module Pressure Drop (ft.hd.):	6.8
Reynolds Number Range for Circuits:	3933 <--> 3936

Power Performance

Total Circulation Pump Power (hP):	0.04
Pumping Power Score:	0.6

Purging Performance (Fluid:Water)

Purging Flow Rate (gpm):	29.8
Purging Pressure Drop (ft.hd.):	12.0
Required Purge Pump Power (hP):	0.15


Design/Construction Scope

PWGC


- Geothermal borefield layout
- Test bore subcontracting/oversight
- Manifold layout
- Construction oversight
- Ground loop design modeling

MEP Consultant


- Heating & cooling loads
- Supply/return piping from manifold
- Geothermal subcontracting
- GSHPs selection
- HVAC design
- Construction oversight




PWGC Design Scope



PWGC or MEP Consultant Design Scope




MEP Consultant Design Scope




Design Considerations

- Accurate load profile & system sizing
- Subsurface utility mapping (GPR) & conflict avoidance
- Optimized borefield placement
 - Minimize land usage
 - Preserve open space
 - Avoid future construction/landscaping conflicts
- Vertical or angled boreholes for compact footprint/expanded ground access
- Mechanical room integration
- Domestic Hot Water inclusion
- Zoning & site topography constraints
- Phasing & construction logistics



Borefield Layout Overlay With GPR Results


Geothermal to GSHPs



Geothermal Manifold Room


Geothermal to GSHPs

1. Geothermal supply/return piping connect into main piping via centralized manifold
2. The manifold is equipped with isolation valves, bypass valves, and energy metering for flow rate and temperature monitoring
3. Supply main routes through air/dirt separator, expansion tank, glycol fill station, and circulation pumps
4. Circulation pumps distribute supply water effectively to GSHPs in each building
5. Supply water exchanges heat as needed for heating or cooling for GSHPs
6. Return (used) water is sent back to manifold
7. Return water is then distributed evenly to boreholes



Geothermal Controls

- Maintain entering-water temperature (EWT) to heat pumps within safe range.
- Deliver required flow with minimal pumping energy.
- Enable monitoring, trending, and BMS integration
- Actuated bypass valve to stabilize ΔP and maintain min flow during low load
- Isolation valves per header/branch; normally open
- Pressure maintenance: diaphragm expansion tanks
- Lead/lag primary pumps
- VFD control to maintain setpoints



GEOTHERMAL PROC

Installation



Rock Drill Bit



HDPE Loop Piping



Grout Materials and Piping



Drill Rig and Support Vehicles



Overburden Drill Bit

Installation



Drilling In Progress



Grouting Equipment




Completed Loops



Grouting Process – Tremie Pipe Hose Reel



Grouted Loop/Pressure Test



Installation



Typical Site Conditions



Drilling Process



Grouting



Manifold Vault



Installation



Borehole Casing Cut Down to
Trench Bottom




Protective Lip Installed on Casing



Horizontal Piping Assembly



Horizontal Pipe Fittings Pre-assembled



Trench Backfilling in Lifts


Installation



Supply and Return Lines



Interior Penetrations for Supply and Return Lines from
Manifold Vault



Utility Crossings



Supply and Return Line Penetrations Sealed and
Fitted with Butterfly Valves



Final System Flush, Purge, and Pressure Testing


Installation



Interior Manifold



Interior Manifold



Interior Manifold

Example Projects



Obama Presidential Center – Presidential Library and Athletic Building (~500 Tons)



St. John's Villa Academy – IS/HS, PS/IS, and Chapel Buildings (Campus System ~900 Tons)



Wyandanch Rising (Campus Study)



Mastercard Headquarters (~600 Tons)




Columbia University – Geochemistry Building (~175 Tons)



SUNY Farmingdale College – Computer Science Building (~150 Tons)

Example Projects



St. Patrick's Cathedral (~200 Tons)



Amneal Pharmaceuticals (Open Loop ~1,200 Tons)



Cornell/Roosevelt Island




Glen Cove Hospital (Campus System 10+ Buildings)




Brooklyn Navy Yard – Open Loop



Specialty Geothermal Services



General Theological Seminary



Google(X) 10-State Geologic/GIS Mapping



NYC Geothermal Feasibility Screening Tool



ATES Geothermal Screening Tool

Geothermal Snapshot

High Efficiency

- Up to 600% efficiency, even during cold winters (U.S. DOE)

Long Lifespan

- Heat Pumps: 20+ years
- Underground Infrastructure: 25–50 years

Energy Cost Savings

- Reduce energy consumption by 25–50% compared to air source systems

Sustainable & Low Maintenance

- Eliminates need for boilers/chillers; reduces carbon emissions.

Supports State & Local Climate Goals

- Aids compliance with NY natural gas ban and electrification mandates

Financial Incentives

- Direct Pay for non-taxed entities
- Federal Tax Credit (ITC – Section 48)
- 30% through 2032 (drops in later years)
- Bonus credits for domestic content

New York State Tax Credit

- 35% of qualified expenditures (max \$5,000 per system)

Utility Rebates

- Con Edison: Up to 50% of project cost, capped at \$100K
- PSEG Long Island: 50% rebate on thermal conductivity testing (up to \$40K)

Why PWGC?

- Proven track record, regulatory insight, and integrated design with MEP/civil/architect teams

An aerial photograph of a city landscape. In the foreground, there's a large stadium with a green field and a red brick building. A parking lot with several cars is visible. The middle ground is filled with trees showing autumn foliage. In the background, a wide river flows, and a city skyline is visible across the water under a clear sky.

Pioneers in Sustainable Geothermal Solutions

Paul Boyce, PE

paulb@pwgrosser.com

Michael Scanlon, PE

mscanlon@pwgrosser.com

Erik Dee-Olsen, PE

edee-olsen@pwgrosser.com

631.589.6353

pwgc.info@pwgrosser.com



PWGC
ENVIRONMENTAL ENGINEERING & CONSULTING