



Public Works Department
City of Bellingham

Private Facility Inspection Report

July 16, 2021

Facility Name: June Road Pond
Address: 849 June Road

Description: The Private Stormwater Mitigation Facility consists of:

- Detention Pond
- Catch Basin
- Control Structure

Inspection Conducted: June 25, 2021
Last Inspected: June 30, 2020

General Condition: The overall condition of the stormwater mitigation facility is excellent. Addressing several issues involving repair and maintenance will bring this facility in line with the City of Bellingham's stormwater ordinance and minimize future, more expensive maintenance problems.

System Component: Detention Pond

Existing conditions: Cat tail growth observed. Some vegetation growth encroaching at the pond emergency overflow spillway. Some volunteer trees and beginnings of blackberry observed around the inside perimeter of pond.

Maintenance needed: As a part of routine maintenance perform vegetation maintenance to keep emergency overflow spillway free and clear. Remove all cat tails from the pond at the end of the growing season (per your Operation & Maintenance Manual). Recommend removal of volunteer trees and blackberry as a part of routine maintenance to prevent from becoming established.

System Component: Catch Basin

Existing conditions: Little to no sediment in catch basin.

Maintenance needed: None at this time, continue with routine maintenance as needed.

System Component: Control Structure

Existing conditions: Little to no sediment in control structure; appears to be in good working condition.

Maintenance needed: None at this time, continue with routine maintenance as needed.

Katie Miller, Stormwater Inspector
City of Bellingham, Public Works Department
Natural Resources Division, Stormwater Section

Engineering
104 W. Magnolia Street, Suite 109
Bellingham, WA 98225
Phone: (360) 778-7900
Fax: (360) 778-7901
TTY: (360) 778-8382
Email: pw@cob.org

Natural Resources
Physical: 2200 Nevada Street
Mailing: 2221 Pacific Street
Bellingham, WA 98229
Phone: (360) 778-7800
Fax: (360) 778-7801
Email: pw@cob.org

Operations
2221 Pacific Street
Bellingham, WA 98229
Phone: (360) 778-7700
Fax: (360) 778-7701
Email: pw@cob.org



Public Works Department
City of Bellingham

July 16, 2021

Ref: Stormwater Facility at 849 June Road (June Road Pond)

To All Concerned Parties,

Inspection of the private stormwater facility at 849 June Rd. Bellingham, WA, revealed that it is working as required by Bellingham Municipal Code 15.42.

While the stormwater system is in compliance, there were some routine maintenance items noted during the inspection that should be addressed to avoid more costly repairs in the future. Please refer to the enclosed Private Facility Inspection Report. Maintenance and repairs to the system(s) should be done by persons knowledgeable in maintenance and aware of construction practices. If there are any questions about the inspection report, you can contact us at (360) 778-7947 or email klmiller@cob.org.

We appreciate your cooperation in maintaining your site stormwater system in proper working condition. It is necessary for private storm systems to function properly in order to assure water quality and/or flood protection.

The estimated date of the next inspection of this facility is June 2022.

Please contact me at (360) 778-7947 or klmiller@cob.org if you have any questions concerning this letter.

Thank you for your cooperation.

Sincerely,

Katie Miller

Katie Miller, Stormwater Inspector
Storm and Surface Water Utility Section
Public Works Natural Resources; City of Bellingham

Enclosure: Private Facility Inspection Report

Cc: The Commons at Cordata Condominium Owner's Association

Engineering

104 W. Magnolia Street, Suite 109
Bellingham, WA 98225
Phone: (360) 778-7900
Fax: (360) 778-7901
TTY: (360) 778-8382
Email: pw@cob.org

Natural Resources

104 W. Magnolia Street, Suite 109
Bellingham, WA 98225
Phone: (360) 778-7800
Fax: (360) 778-7801
Email: pw@cob.org

Operations

2221 Pacific Street
Bellingham, WA 98229
Phone: (360) 778-7700
Fax: (360) 778-7701
Email: pw@cob.org

President-Mike Nolan; president.commonscOA@gmail.com
Vice President-Leslie Myers; vicepres.commonscOA@gmail.com
The June Road Cottages Condominium Owner's Association
President-Ethan Voon; president2020.jrccOA@gmail.com