

GUARDIAN FIRE TESTING LABORATORIES, INC.

480 Hinman Ave.
Buffalo, NY 14216

Product Certification

Accredited By American National Standards Institute (ANSI) To: ISO 17065

Roseburg MDF Medford

2685 North Pacific Hwy.
Medford, OR 97504

“Medite FR MDF” (542) Nominal ½ Inch through 1-1/2 Inch thick: ASTM E84, Rating Class “A”, Test Report GL 60114, 8/30/14

“Medite FR MDF” (635) Nominal 1/4 Inch up to 1/2 Inch Thick; Standard: ASTM E84, Rating Class “A”, Test Report GL 67515, 8/22/15

“Medite FR MDF” (542) Nominal 1/2 Inch through 1-1/2 Inch Thick; Standard: CAN/ULC S102, Flame Spread Rating (FSR) of 10; Smoke Developed Classification (SDC) of 5; Test Report GL 49215, 7/3/2015

“Medite FR MDF” (542) Nominal 3/8 Inch through 1-1/2 Inch Thick; Standard: ASTM E2768 (extended time), Rating Class “A” Test Report GL GL-6-2-17Y, 7/11/17

“Arreis” (437) Nominal ¼” and Thicker, ASTM E84, Rating Class C, GL 6217Z, ASTM E84, 7/6/17



Suzanne Purson

Administrator

Certifying Product Reliability Against Fire

RE-ISSUE DATE: April 28, 2019