

## **New York State Unified Solar Permit** Expedited Solar Permit Process for Small-Scale Photovoltaic Systems

### **Requirements for Application Submittal – STEP 1**

For use in all New York State counties with the exception of Nassau County and Suffolk County.

The expedited solar permitting process uses a unified permit across municipalities in New York State.

A combined building and electrical permit for a grid-tied photovoltaic (PV) system will be issued pending proper completion of forms, submission of approved plans and approval by municipality. **All applicants must submit:**

#### **1. Unified Solar Permit for Small-Scale Photovoltaic Systems Eligibility Checklist – STEP 2**

#### **2. One (1) set of plans (number may vary by municipality) that include:**

- Site Plan showing location of major components of solar system and other equipment on roof or legal accessory structure. This plan should represent relative location of components at site, including, but not limited to, location of array, existing electrical service location, utility meter, inverter location, system orientation and tilt angle. This plan should show access and pathways that are compliant with New York State Fire Code, if applicable.
- One-Line or 3-Line Electrical Diagram. The electrical diagram required by NYSERDA for an incentive application and/or utility for an interconnection agreement can be used here.
- Specification Sheets for all manufactured components. If these sheets are available electronically, a web address will be accepted in place of an attachment, at the discretion of the municipality.
- All diagrams and plans must include the following: (a) Project address, section, block and lot number of the property; (b) Owner's name, address and phone number; (c) Name, address and phone number of the person preparing the plans; and (d) System capacity in KW-DC.

#### **3. Unified Solar Permit for Small-Scale Photovoltaic Systems Application – STEP 3**

#### **4. Permit Fee Amount**

\$50.

#### **Permit Review and Inspection Timeline**

Permit determinations will be issued within 14 days upon receipt of complete and accurate applications. The municipality will provide feedback within 7 days of receiving incomplete or inaccurate applications. If an inspection is required, a single inspection should be sufficient and will be provided within 7 days of inspection request.

The NY-Sun Initiative, a dynamic public-private partnership, will drive growth of the solar industry and make solar technology more affordable for all New Yorkers.

**Visit [ny-sun.ny.gov](http://ny-sun.ny.gov) for more information on the NY-Sun Initiative.**

**Town of Bethel**  
**3454 State Route 55**  
**P.O. Box 300**  
**White Lake, NY 12786**

**P: (845) 583-4350 ext. 105**

**E-Mail:**

**[bldgdept@libertybiz.rr.com](mailto:bldgdept@libertybiz.rr.com)**

**Website: [townofbethelny.us](http://townofbethelny.us)**



## PERMIT APPLICATION

# NY State Unified Solar Permit

Unified solar permitting is available statewide for eligible solar photovoltaic (PV) installations. Municipal authorities that adopt the unified permit streamline their process while providing consistent and thorough review of solar PV permitting applications and installations. Upon approval of this application and supporting documentation, the authority having jurisdiction (AHJ) will issue a building and/or electrical permit for the solar PV installation described herein.

### PROJECT ELIGIBILITY FOR UNIFIED PERMITTING PROCESS

By submitting this application, the applicant attests that the proposed project meets the established eligibility criteria for the unified permitting process (subject to verification by the AHJ). The proposed solar PV system installation:

- Yes  No 1. Has a rated DC capacity of 25 kW or less.
- Yes  No 2. Is not subject to review by an Architectural or Historical Review Board. (If review has already been issued answer YES and attach a copy)
- Yes  No 3. Does not need a zoning variance or special use permit. (If variance or permit has already been issued answer YES and attach a copy)
- Yes  No 4. Is mounted on a permitted roof structure, on a legal accessory structure, or ground mounted on the applicant's property. If on a legal accessory structure, a diagram showing existing electrical connection to structure is attached.
- Yes  No 5. The Solar Installation Contractor complies with all licensing and other requirements of the jurisdiction and the State.
- Yes  No 6. If the structure is a sloped roof, solar panels are mounted parallel to the roof surface.

For solar PV systems not meeting these eligibility criteria, the applicant is not eligible for the Unified Solar Permit and must submit conventional permit applications. Permit applications may be downloaded here: [townofbethelny.us/forms](http://townofbethelny.us/forms) or obtained in person at Town of Bethel Building Department, 3454 State Route 55, White Lake, NY 12786 (8 a.m. - 4 p.m.)

### SUBMITTAL INSTRUCTIONS

For projects meeting the eligibility criteria, this application and the following attachments will constitute the Unified Solar Permitting package.

- This application form, with all fields completed and bearing relevant signatures.
- Permitting fee of \$50.00, payable by credit/debit card, cash or check payable to Town of Bethel.
- Required Construction Documents for the solar PV system type being installed, including required attachments.

Completed applications can be submitted to [bldgdept@libertybiz.rr.com](mailto:bldgdept@libertybiz.rr.com) or in person at Bethel Building Department, 3454 State Route 55, White Lake, NY 12786 or by US Mail: P.O. Box 300, White Lake, NY 12786 or fax to: (845) 583-4710

### APPLICATION REVIEW TIMELINE

Permit determinations will be issued within 14 calendar days upon receipt of complete and accurate applications. The municipality will provide feedback within 14 calendar days of receiving incomplete or inaccurate applications.

### FOR FURTHER INFORMATION

Questions about this permitting process may be directed to Town of Bethel Building Department (845) 583-4350 ext. 105.

## PROPERTY OWNER

Property Owner's First Name

Last Name

Title

Property Address

City

State

Zip

Section

Block

Lot Number

## EXISTING USE

Single Family     2-4 Family     Commercial     Other

## PROVIDE THE TOTAL SYSTEM CAPACITY RATING (SUM OF ALL PANELS)

Solar PV System: \_\_\_\_\_ kW DC

## SELECT SYSTEM CONFIGURATION

Make sure your selection matches the Construction Documents included with this application.

Supply side connection with microinverters     Load side connection with DC optimizers  
 Supply side connection with DC optimizers     Load side connection with microinverters  
 Supply side connection with string inverter     Load side connection with string inverter

## SOLAR INSTALLATION CONTRACTOR

Contractor Business Name

Contractor Business Address

City

State

Zip

Contractor Contact Name

Phone Number

Contractor License Number(s)

Contractor Email

Electrician Business Name

Electrician Business Address

City

State

Zip

Electrician Contact Name

Phone Number

Electrician License Number(s)

Electrician Email

Please sign below to affirm that all answers are correct and that you have met all the conditions and requirements to submit a unified solar permit.

Property Owner's Signature

Date

Solar Installation Company Representative Signature

Date

## SUBMITTAL REQUIREMENTS SOLAR PV 25KW OR LESS (ATTACHMENTS)

# NY State Unified Solar Permit

This information bulletin is published to guide applicants through the unified solar PV permitting process for solar photovoltaic (PV) projects 25 kW in size or smaller. This bulletin provides information about submittal requirements for plan review, required fees, and inspections.

### PERMITS AND APPROVALS REQUIRED

The following permits are required to install a solar PV system with a nameplate DC power output of 25 kW or less:

- a) Unified Solar Permit

Planning review is not required for solar PV installations of this size.

Fire Department approval is not required for solar PV installations of this size.

### SUBMITTAL REQUIREMENTS

In order to submit a complete permit application for a new solar PV system, the applicant must include:

- a) Completed Standard Permit Application form which includes confirmed eligibility for the Unified Solar Permitting process. This permit application form can be downloaded at [townofbethelny.us/forms](http://townofbethelny.us/forms)
- b) Construction Documents, with listed attachments must be stamped and signed by a New York State Registered Architect or New York State Licensed Professional Engineer.

Town of Bethel, through adopting the Unified Solar Permitting process, requires contractors to provide construction documents, such as the examples included in the Understanding Solar PV Permitting and Inspecting in New York State document. Should the applicant wish to submit Construction Documents in another format, ensure that the submittal includes the following information:

- Manufacturer/model number/quantity of solar PV modules and inverter(s).
- String configuration for solar PV array, clearly indicating the number of modules in series and strings in parallel (if applicable).
- Combiner boxes: Manufacturer, model number, NEMA rating.
- From array to the point of interconnection with existing (or new) electrical distribution equipment: identification of all raceways (conduit, boxes, fittings, etc.), conductors and cable assemblies, including size and type of raceways, conductors, and cable assemblies.
- Sizing and location of the EGC (equipment grounding conductor).
- Sizing and location of GEC (grounding electrode conductor, if applicable).
- Disconnecting means of both AC and DC including indication of voltage, ampere, and NEMA rating.
- Interconnection type/location (supply side or load side connection)
- For supply side connections only, indication that breaker or disconnect meets or exceeds available utility fault current rating kAIC (amps interrupting capacity in thousands).
- Ratings of service entrance conductors (size insulation type AL or CU), proposed service disconnect, and overcurrent protection device for new supply side connected solar PV system (reference NEC 230.82, 230.70).
- Rapid shutdown device location/method and relevant labeling.

c) (For Roof Mounted Systems) A roof plan showing roof layout, solar PV panels and the following fire safety items: approximate location of roof access point, location of code-compliant access pathways, code exemptions, solar PV system fire classification, and the locations of all required labels and markings.

d) Provide construction drawings with the following information:

- The type of roof covering and the number of roof coverings installed.
- Type of roof framing, size of members, and spacing.
- Weight of panels, support locations, and method of attachment.
- Framing plan and details for any work necessary to strengthen the existing roof structure.
- Site-specific structural calculations.

e) Where an approved racking system is used, provide documentation showing manufacturer of the racking system, maximum allowable weight the system can support, attachment method to roof or ground, and product evaluation information or structural design for the rack.

## PLAN REVIEW

Applications can be submitted to Bethel Building Dept., P.O. Box 300, White Lake, NY 12786 or in person 3454 State Route 55, White Lake, NY 12786 or email: [bldgdept@libertybiz.rr.com](mailto:bldgdept@libertybiz.rr.com) or by fax (845) 583-4710.

## FEES

The Unified Solar Permit Fee is \$50.

## INSPECTIONS

Once all permits to construct the solar PV installation have been issued and the system has been installed, it must be inspected before final approval is granted for the solar PV system. On-site inspections can be scheduled by contacting Town of Bethel Building Department by telephone at (845) 583-4350 ext. 105. or electronically at [bldgdept@libertybiz.rr.com](mailto:bldgdept@libertybiz.rr.com)

Inspection requests received within business hours are typically scheduled for the next business day. If next business day is not available, inspection should happen within a five-day window.

In order to receive final approval, the following inspections are required:

During a rough inspection, the applicant must demonstrate that the work in progress complies with relevant codes and standards. The purpose of the rough inspection is to allow the inspector to view aspects of the system that may be concealed once the system is complete.

- Wiring concealed by new construction.
- Portions of the system that are contained in trenches or foundations that will be buried upon completion of the system.

It is the responsibility of the applicant to notify the Town of Bethel Building Department before the components are buried or concealed and to provide safe access (including necessary climbing and fall arrest equipment) to the inspector. The inspector will attempt, if possible, to accommodate requests for rough inspections in a timely manner.

**FINAL INSPECTION.** The applicant must contact the Town of Bethel Building Department when ready for a final inspection. During this inspection, the inspector will review the complete installation to ensure compliance with codes and standards, as well as confirming that the installation matches the records included with the permit application. The applicant must have ready, at the time of inspection, the following materials and make them available to the inspector:

- Copies of as-built drawings and equipment specifications, if different than the materials provided with the application.
- Photographs of key hard to access equipment, including;
  - Example of array attachment point and flashing/sealing methods used.
  - Opened rooftop enclosures, combiners, and junction boxes.
  - Bonding point with premises grounding electrode system.
  - Supply side connection tap method/device.
  - Module and microinverter/DC optimizer nameplates.
  - Microinverter/DC optimizer attachment.

The Town of Bethel has adopted a standardized inspection checklist.

The inspection checklist provides an overview of common points of inspection that the applicant should be prepared to show compliance. If not available, common checks include the following:

- Number of solar PV modules and model number match plans and specification sheets number match plans and specification sheets.
- Array conductors and components are installed in a neat and workman-like manner.
- Solar PV array is properly grounded.
- Electrical boxes and connections are suitable for environment.
- Array is fastened and sealed according to attachment detail.
- Conductor's ratings and sizes match plans.
- Appropriate signs are properly constructed, installed and displayed, including the following:
  - Sign identifying PV power source system attributes at DC disconnect.
  - Sign identifying AC point of connection.
  - Rapid shutdown device meets applicable requirements of NEC 690.12.
- Equipment ratings are consistent with application and installed signs on the installation, including the following:
  - Inverter has a rating as high as max voltage on PV power source sign.
  - DC-side overcurrent circuit protection devices (OCPDs) are DC rated at least as high as max voltage on sign.
  - Inverter is rated for the site AC voltage supplied and shown on the AC point of connection sign.
  - OCPD connected to the AC output of the inverter is rated at least 125% of maximum current on sign and is no larger than the maximum OCPD on the inverter listing label.
  - Sum of the main OCPD and the inverter OCPD is rated for not more than 120% of the buss bar rating.

## UNIFIED SOLAR PERMITTING RESOURCES

The jurisdiction has adopted the following documents from the New York Unified Solar Permit process: Delete any documents not adopted by the jurisdiction.

- Standard Application [townofbethelny.us/forms](http://townofbethelny.us/forms)
- The Understanding Solar PV Permitting and Inspecting in New York State document, which includes sample construction documents, inspection checklist, design review checklist, and labeling guide can be found on the website with the permit. (See Step 2 for Photovoltaic Eligibility Checklist on page 1).

## DEPARTMENTAL CONTACT INFORMATION

For additional information regarding this permit process, please contact the Town of Bethel Building Department at (845) 583-4350 ext. 105.