



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
NEDUMANGADU, ARUVIKKARA, THIRUVANANTHAPURAM
Telephone No - 0472-2998117 E-mail - qcsdlnedumangadu@gmail.com
Test Report

Test Report. No. KWA/QCSDL/ND/2024/1354

Date of Report : 17/08/2024

Customer Name & Address PRINCIPAL, VISWADARSHINI PUBLIC SCHOOL , URIACODE			1. Date of Receipt : 12/08/2024		
			2. Sampling done by : The Customer (QUA_157575)		
			3. Sample Code : KWA/QCSDL/ND/2024/1354		
			4. Source of Sample : Drinking Water		
			5. Sample Quantity :1 litre		
			6. Test Performing Dates : From : 14/08/2024 To : 17/08/2024		
Sl. No.	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Odour	Qualitative	IS 3025 (Part 5-2021)	-	Agreeable
2	Turbidity	(NTU)	IS 3025 (Part 10) - 2023) Nephelometric Method	1	0.4
3	pH at 25°C	-	IS 3025 (Part 11)- 2022 Electrometric Method	6.5 to 8.5	5.1
4	Total Hardness (as Ca CO ₃)	(mg/litre)	IS 3025 (Part 21) - 2019 EDTA method	200	24
5	Chloride (as Cl)	(mg/litre)	IS 3025 (Part 32) : 2019 Argentometric method	250	19.4

Remarks:

- NB:-
1. The results stated above related only to the sample(s) received for testing.
 2. This test report shall not be reproduced except in full without the written approval of the Laboratory.
 3. Retention Period: 7 days from the date of Analysis
- *BDL= Below Detection Limit
*DL = Detection Limit

Analyzed By

KALA K K

SANITARY CHEMIST
QUALITY CONTROL SUB DISTRICT LAB
NEDUMANGADU, ARUVIKKARA
KWA, TVPM

Authorized By

KALA K K

KWA/QCSDL/ND/R/41	Issue No:2	Issue Date: 14/06/2022
Rev.No: 04	Date: 24.07.23	Page 1 of 1



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
NEDUMANGADU, ARUVIKKARA, THIRUVANANTHAPURAM
Telephone No: 0472-2998117 E-mail - qcsdlnedumangadu@gmail.com

Test Report

Test Report. No. KWA/QCSDL/ND/2024/1354

Date of Report : 17/08/2024

Customer Name & Address			1. Date of Receipt : 12/08/2024		
PRINCIPAL , VISWADARSHINI PUBLIC SCHOOL, URIACODE			2. Sampling done by : The Customer (QUA_157575)		
			3. Sample Code : KWA/QCSDL/ND/2024/1354		
			4. Source of Sample : Drinking Water		
			5. Sample Quantity :1 litre		
			6. Test performing Dates From : 14/08/2024 to : 17/08/2024		
1	Electrical Conductivity at 25 ° C	(micro mhos/cm)	IS 3025 (part 14) - 2013		108..1
2	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) - 2003) 1' 10 Phenanthrolin Method	1.0	0.06
3	Nitrate (as NO ₃)	(mg/litre)	APHA 23rd Edition 4500-NO3-B: 2017 UV Spectrophotometric Screening Method	45	26.15

Remarks:-

NB:-

1. The results stated above related only to the sample(s) received for testing.
2. This test report shall not be reproduced except in full without the written approval of the Laboratory.
3. Retention Period: 7 days from the date of Analysis

*BDL= Below Detection Limit

*DL = Detection Limit

Analyzed by:

KALA K K

SANITARY CHEMIST
QUALITY CONTROL SUB DISTRICT LAB
NEDUMANGADU, ARUVIKKARA
KWA, TVPM

Authorized By

KALA K K

* End of Report *

KWA/QCSDL/ND/R/41	Issue No:2	Issue Date: 14/06/2022
Rev.No: 04	ev Date: 24.07.2	Page 1 of 1



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY

VELLAYAMBALAM, THIRUVANANTHAPURAM
Telephone No - 0471-2735303, E-mail - aeequalityvm@gmail.com

Test Report

Test Report. No -KWA/QCSDL/ND/2024/1354

Date of Report : 13.08.2024

Customer Name & Address			1. Date of Receipt : 12.08.2024	
PRINCIPAL, VISWADARSHINI PUBLIC SCHOOL , URIACODE			2. Sampling done by : The Customer (QUA 157575)	
			3. Sample Code : KWA/QCSDL/ND/2024/1354	
			4. Sample Particulars : Drinking Water	
			5. Sample Quantity : 2 litre	
			6. Test Performing Dates From : 12.08.2024 To : 13.08.2024	
Sl. No.	Parameters	Acceptable limits as per-IS 10500-2012	Test Method	Result
1	Total Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	ABSENT
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	ABSENT

Remarks:-

NB:- 1.The results stated above related only to the sample(s) received for testing.

2.This test report shall not be reproduced except in full without the written approval of the Laboratory.

3. Retention Period: 7 days from the date of Analysis

Analysed by

BACTERIOLOGIST
QUALITY CONTROL DISTRICT LAB
KWA
THIRUVANANTHAPURAM
Authorized Signatory

* End of Report *

KWA/QCDL/TVM/R/41	Issue No:2	Issue Date 31.05.2022
Rev.No: 02	Date: 18.05.2023	Page 1 of 1