


SBA MUST BE NOTIFIED AT LEAST 24 HOURS PRIOR TO CONSTRUCTION

610-267-7772



NOTES:

1. LOCATE CURB BOX AT RIGHT-OF-WAY OR EASEMENT LINE.
2. CURB BOX SHALL NOT BE LOCATED IN PAVED AREAS.
3. COMPRESSION STYLE CURB STOP MANUFACTURED BY MUELLER, FORD OR APPROVED EQUAL.
4. CURB BOX MANUFACTURED BY BINGHAM & TAYLOR- 21/2" CI BOX Ref.#93-E
5. CURB BOX COVER SHALL NOT BE COVERED BY SOD, GRASS, OR PLANTINGS, AND MUST BE FULLY ACCESSIBLE WITHOUT DIGGING. CURB BOX COVER SHALL BE PAINTED LIGHT BLUE, AND INCLUDE THE INSCRIPTION "WATER".
6. CURB BOX MUST BE VERTICAL AND PLUMB; AND EASILY ACCESSIBLE WITH KEY.
7. SERVICE MUST BE ONE CONTINUOUS LENGTH OF K-COPPER INTO BUILDING WITH 6" OF SCREENING BED AND 6" SCREENINGS COVER OVER TOP OF SERVICE. *Meter Pit required if service length from curb stop exceeds 100' to building*