Villas West Architectural Specification

Specifications for Installing a Dryer Vent Through the Villa Rear Wall or Shed Wall

Specification No: VWAS 15

Issue Date: 12-21-2004 Revision Date: 05-14-2013

Revision Level: A

Board Approval Date: 05-14-2013

Page 1

General: An Architectural Alteration Application, Form No. AAA, requesting the installation of a dryer vent through the villa rear wall or shed wall must be submitted to the Architectural Committee for review. The Architectural Committee will submit its recommendation to the Board of Directors for final approval.

Specifics:

- 1. All necessary permits must be obtained from Pima County Developmental Services.
- 2. Any electrical conductors which must be buried underground to supply laundry equipment shall follow the requirements state below:
 - Direct buried UF cable shall be buried not less than 24 inches

5. Homeowner is responsible for compliance to all specifications.

- Conductors in rigid metal or intermediate metal conduit shall be buried not less than 6 inches
- Conductors in non-metallic raceway listed for direct burial shall be buried not less than 18 inches.
- Circuits of 120 volts or less with GFCI protection and maximum over current protection of 20 amperes shall be buried not less than 12 inches.
- 3. All conductors, where they exit the ground, shall be protected by a suitable raceway, which will be fastened to the building wall.
- 4. All installations shall comply with current Pima County Electrical and Plumbing codes and be inspected by a Pima County inspector.
- Owner's Signature Date Contractor's Signature Date

Architectural Chairperson Date Association President Date