


Tank Information			
ZONE	REV	DESCRIPTION	DATE
		12 Gauge Carbon Steel Construction, UL142 Listed, Red Primer coating	Mar 2015

FINAL APPROVED DRAWING
 BY: _____
 DATE: _____

Top View



 Pee Dee Tank	165WB		
	165 Gallon Work Bench Tank, Single wall construction, standard openings, channel under tank, red primer coating		
1333 North Douglas St Florence, SC 29501 Telephone (843) 669-3381 Fax (843) 664-9118	UL142 Listed	For Stationery Use Only	REV
	SCALE	M Moran	SHEET