



Tank Information			
ZONE	REV	DESCRIPTION	DATE
		12 Gauge Carbon Steel Construction, UL142 Listed, Red Primer coating	Mar 2015


FINAL APPROVED DRAWING
BY: _____
DATE: _____

Top View



2" NPT
Openings



 Pee Dee Tank	280WB		
	280 Gallon Work Bench Tank, Single wall construction, standard openings, channel under tank, red primer coating		
1333 North Douglas St Florence, SC 29501 Telephone (843) 669-3381 Fax (843) 664-9118		UL142 Listed	For Stationery Use Only
	SCALE	M Moran	REV
			SHEET