


Tank Information			
ZONE	REV	DESCRIPTION	DATE

12 Gauge Carbon Steel
Construction, UL142
Listed, Red Primer
coating


Mar 2015


FINAL APPROVED DRAWING
BY: _____
DATE: _____

Top View



Outside
Warp comes
to within 1"
of top



 Pee Dee Tank	500DWWB		
	500 Gallon Work Bench Tank, Double wall construction, standard openings, channel under tank, red primer coating		
1333 North Douglas St Florence, SC 29501 Telephone (843) 669-3381 Fax (843) 664-9118	UL142 Listed	For Stationery Use Only	REV
SCALE	M Moran	SHEET	