



119 Van Order Drive, Kingston, ON K7M 1B9 ☎ Fax (613) 546-9375 ☎ Phone (613) 546-5591 [www.kfhc.ca](http://www.kfhc.ca)

Job No: THK PT 20-01

Housing Provider: Kingston & Frontenac Housing Corporation on behalf of  
Town Homes Kingston

Job Description: Heating & Cooling Unit Replacement  
2075 Battersea Road  
Glenburnie, Ontario

Addendum No. 1

Date: April 3, 2020

---

The following additions, deletions and changes are to be read with and form part of the original Bid Documents.

Receipt of this addendum must be acknowledged by inserting its number in the space provided on the Bid Form.

This Addendum consists of 2 pages, including the attachment.

**DELETE:**

The AHU Schedule on Drawing Sheet M2

**INSERT:**

The attached document: AHU SCHEDULE 2020-04-02

**End of Addendum**

Addendum #1

The AHU schedule on drawing sheet M2 is withdrawn and is replaced with the following:

AHU SCHEDULE																	
TAG	MAKE & MODEL	DISCHARGE	FAN	ENTERING WATER TEMP.	WATER FLOW GPM	AIR FLOW CFM	HEATING CAPACITY (MBH)	VOLTAGE	MCA	MOCP	QTY	INSTALL ROOM DISTRIBUTION					
												1T	1B	1H	2T	2B	2H
AHU-1	ENERZONE AHN18	VERTICAL	1/3 HP EC FIXED TORQUE MOTOR	140 F (60 C)	2	600	28	115/1/60	5.1	15	9	102, 113, 115, 119, 215, 217, 304		106, 108			
AHU-2	ENERZONE AHN18					550	28				10	103, 107, 114, 116, 118, 216, 218, 220, 303, 305					
AHU-3	ENERZONE AHN24					700	33				6			110, 211	112, 209, 309, 312		
AHU-4	ENERZONE AHN24					800	33				0						

NOTES:

- FILTER RACK TO BE FIELD INSTALLED 16 X 18
- UNITS TO BE SUPPLIED WITHOUT CIRCULATOR PUMP
- UNITS TO BE FACTORY CONFIGURED FOR R-407C REFRIGERANT.