



119 Van Order Drive, Kingston, ON K7M 1B9 📠 Fax (613) 546-9375 📞 Phone (613) 546-5591 www.kfhc.ca

Job No: RFP 2026-01

Housing Corporation: Kingston & Frontenac

Job Description: Water Testing, Monitoring and Reporting

Addendum No. 1

Date: December 2, 2025

The following additions, deletions and changes are to be read with and form part of the original Bid Documents.

Receipt of this addendum must be acknowledged by inserting its number in the space provided on the Bid Form.

This Addendum consists of 1 page(s).

Correction:

Under Project Requirements, 3.0 Background of the Project – 2075 Battersea Road, Glenburnie, ON, under “Equipment on Site” on page 8 of the document.

Insert manganese greensand filters
between “chlorine injection” and “large cistern tank”

Under Project Requirements, 5.0 Scope of work, on page 9 of the document.

Delete

1. Daily monitoring of the free chlorine residual using the SCADA system, which is property of the current water monitoring company and not owned by KFHC. The successful Proponent will need to supply this equipment with an operator inspecting the data at least every 72 hours.

Insert

1. Daily monitoring of the free chlorine residual **and turbidity** using the SCADA system, which is property of the current water monitoring company and not owned by KFHC. The successful Proponent will need to supply this equipment with an operator inspecting the data at least every 72 hours.

End of Addendum