

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 04/ जि.प्र./ लो.स्वा.सं./ उपखण्ड / शिवपुरी

Dated: 13/06/2025

It is certified that an inspection team headed by Rajeev Bhatia from Shivpuri PHED, Dist Shivpuri (MP) inspected the KHEDEPATI SIGNATUTRE INTERNATION SCHOOL, NEAR ABDUL COLONY, VILLAGE SINGHNIWAS, TEH. AND DIST. SHIVPURI(M.P.) on 18.06.2025 and on the basis of Water Test Report (Attached) bearing no. 80/1 dated 11/06/25 of (PHED Lab) certified that the KHEDEPATI SIGNATUTRE INTERNATION SCHOOL has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 17.06.202617.06.2026

Quality manager
D.W.T.L. shivpuri
(M.P.)

Signature with Seal: 19/06/25Name: Rajeev BhatiaDesignation: Quality managerName & Address of the Office / Department: D.W.T.L. shivpuri (M.P.)

Issued To

KHEDEPATI SIGNATUTRE INTERNATION SCHOOL
NEAR ABDUL COLONY, VILLAGE SINGHNIWAS
TEH. AND DIST. SHIVPURI (M.P.)


Headmaster

Khedapati Signature International School
Shivpuri (M.P.) Code-PS121958

Sagun Chandra Bhatia
PRESIDENT / SECRETARY / TREASURER
SHRI KHEDEPATIJI EDUCATION
AND SOCIAL WELFARE SOCIETY
No. 02/41/01/26293/23


Status of Sample	Chemical /Bacteriological Test	Unique Identification No.	80/1	7
Sender's name	By- Khedapati Signature International School Near Abdul Kalam Colony Shivpuri	Sender's letter no.	Q	
Sender's address	By- Khedapati Signature International School Near Abdul Kalam Colony Shivpuri	Sender's letter date	26/05/2025	0
		Start Date Of Analysis	10/06/2025	0
Quantity of Sample	1 Ltr.	Receipt No.	02	
Sample Collected by	School Staff	End Date Of Analysis	11/06/2025	0


Sample details:


S No	Distt	Block	Village	Location	source
1	Shivpuri	Shivpuri	Shivpuri	By- Khedapati Signature International School Near Abdul Kalam Colony Shivpuri	B W

Physical/ Chemical /Bacteriological Test Report With Details of Parameters Their Test Methods, Units and Specifications as per BIS.

S. No	Characteristics	Test Method (BIS 10500:2012)	Unit	As per BIS-10500:2012 & Reaffirmed in Sep. 2018		Test Result						
				Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Source	Sample Numbers						
						1	2	3	4	5	6	7
1	2	3	4	5	6	7						
1	Turbidity	BIS :3025 Part 10	NTU	1	5	3.7			-	-	-	-
2	pH	BIS :3025 Part 11	pH scale	6.5to8.5	<6.5to9.2>	7.2			-	-	-	-
3	TDS	BIS :3025 Part 16		500	2000	468			-	-	-	-
4	Total Hardness as CaCO ₃	BIS :3025 Part 21	mg/l	200	600	226			-	-	-	-
5	Total Alkalinity as CaCO ₃	BIS :3025 Part 23	mg/l	200	600	399			-	-	-	-
6	Residual chlorine	BIS :3025 Part 26	ppm	0.2	>1.0	Nil			-	-	-	-
7	Chloride as Cl	BIS :3025 Part 32	mg/l	250	1000	23			-	-	-	-
8	Calcium as Ca ⁺⁺	BIS :3025 Part 40	mg/l	75	200	59			-	-	-	-
9	Magnesium as Mg	BIS :3025 Part 46	mg/l	30	100	18			-	-	-	-
10	Iron as Fe ⁺⁺	BIS :3025 Part 53	mg/l	0.3	1.0	Nil			-	-	-	-
11	Nitrate as NO ₃	BIS :3025 Part 34	mg/l	45	45	1.0			-	-	-	-
12	Fluoride as F ⁻	BIS :3025 Part 60	mg/l	1.0	1.5	0			-	-	-	-
13	Total coliform MPN/100ml	standard method 1992	MPN 100ml	zero	10	0			-	-	-	-


Headmaster
 Khedapati Signature International School
 Shivpuri (M.P.) Code-PS121958


Signature
 Quality Manager
 Authorized Signatory
 C.W.T.L. Shivpuri
 (M.P.)


PRESIDENT / SECRETARY / TREASURER:
 SHRI KHEDAPATI JI EDUCATION
 AND SOCIAL WELFARE SOCIETY
 No. 02/41/01/26293/23