



ADDENDUM #2 to
Request For Proposals (RFP)
Photovoltaic (Solar Panel) Array for the Detroit/Wayne
County Port Authority
August 27, 2024

Please note the following changes to the RFP:

1. See attached description of a change in the basis of design for the 460watt Jinko solar panel, which has been discontinued.



5145 Livernois Rd., Suite 100, Troy, MI 48098-3276,

PROJECT: DWCPA PV & Hydrokinetic Energy 2024.0064.00 DATE: 8/27/2024

SUBJECT: DWCPA PV Project - Pending Changes TRANSMITTAL ID: 00004

PURPOSE: For your use VIA: Info Exchange

FROM

NAME	COMPANY	EMAIL	PHONE
Eric Graettinger 5145 Livernois Rd., Suite 100, Troy, MI 48098-3276	Peter Basso Associates, Inc.	egraettinger@pbanet.com	(248)312-4614

TO

NAME	COMPANY	EMAIL	PHONE
BIDS@MCECO.COM United States		BIDS@MCECO.COM	
dhenderson@michigansolutions.com		dhenderson@michigansolutions.com	

REMARKS: Good afternoon,

We've been informed that the 460watt Jinko Solar panel that we used as our basis of design has been discontinued. We plan to issue revised basis of design drawings on 8/28 using the attached panel and inverter as the basis of design, since this panel's physical size has impacts to the spacing of rows of panels on the roof, as well as the string configuration. The new basis of design panel and inverter is attached.

Since this is a basis of design and not a required panel/inverter combination, we would like to maintain the bid due date for this Friday, August 30th at noon. If this impacts your ability to bid, please let me know.

Look for Addendum Drawings on Wednesday.

Thank you,
Eric Graettinger

Transmittal

DATE: 8/27/2024
TRANSMITTAL ID: 00004

DESCRIPTION OF CONTENTS

QTY	DATED	TITLE	NOTES
1	8/27/2024	Cheetah Plus JKM425-445M-78H-D1.2-EN-F35.pdf	
1	8/27/2024	se-three-phase-inverter-with-synergy-technology-480v-datasheet-na.pdf	

COPIES:

Eric Graettinger
Mark Schrupp

(Peter Basso Associates, Inc.)
(Detroit Wayne County Port Authority)