

1. PROVIDE RAPID SHUT DOWN MODULES AS REQUIRED BY NEC 690.12 SIMILAR TO TIGO TS4-A-F.
2. PROVIDE PV GENERATION METER WITHIN 5FT OF EXISTING SERVICE METER.
3. PROVIDE 150A ENCLOSED MOLDED CASE CIRCUIT BREAKER WITH SHUNT TRIP PROTECTION NEAR INCOMING SERVICING METERING. SHUNT TRIP CONTROL WILL BE BY OTHERS.



REVISION

 **Peter Basso**
Associates
CONSULTING ENGINEERS

5145 Livernols, Suite 100
Troy, Michigan 48068-3276
Tel. 248-879-5686
www.PeterBassoAssociates.com
PBA Project No.: 2024.0064

PROJECT TITLE
DETROIT/WAYNE COUNTY
PORT AUTHORITY

130 E. Atwater Street Detroit, MI 48226

SHEET TITLE
ONE LINE DIAGRAM

DATE
08-02-2024

ISSUE
BIDS

SHEET No. _____