

MIDDLETON RURAL FIRE DISTRICT



STAR FIRE PROTECTION DISTRICT

FIRE DEPARTMENT ACCESS AND WATER SUPPLY RESIDENTAL CONSTRUCTION APPLICATION

PLEASE PRINT

Contractor: Contact: Date:
Address: City: Zip:
Phone/Mobile: Email Address:
Owner(s):
Address: City: Zip:
Phone/Mobile: Email Address:

PROJECT INFORMATION

Project Location: County:
Legal Description: Lot: Block: Subdivision:
Total Sq. Ft.: Stories Above Grade: Stories Below Grade:

APPARATUS ACCESS & TURN-AROUND

Fire apparatus access roads shall have an unobstructed width of not less than 20 feet exclusive of shoulders with an unobstructed vertical clearance of not less than 13 feet 6 inches. The Surface shall be capable of supporting the imposed load of fire apparatus weighing at least 75,000 pounds. Access roads over 150ft from the public roadway will require emergency turnaround.

How many dwellings will access the road? Road/Driveway Length:
Will the road have a gate? Yes No Is the road 7% grade or less? Yes No

WATER SUPPLY

Fire Flow and Water Supply – One- and two-family dwellings not exceeding 3,600 square feet require a fire flow of 1,000 gallons per minute for a duration of 1 hour to service the entire project. One- and two-family dwellings in excess of 3,600 square feet require a minimum fire flow as specified in Appendix B of the International Fire Code.

Is the dwelling within 1000ft from an approved fire hydrant? Yes – Location: No

APPLICANT COMMENTS

Blank area for applicant comments.

APPLICATION REQUIRMENTS

OFFICE USE ONLY

APPARATUS ACCESS & TURN-AROUND:
WATER SUPPLY:
KNOX BOX OR SWITCH:
Notes:
Application & Plans Received: (Date/By)
Permit Fee: \$100.00 Paid Cash Check #
Fire Authority Having Jurisdiction:
Fire District Permit #
City/County Jurisdiction:
County/City Permit #
Emergency Access and Water Supply Application Status
Approved Approved with Conditions Denied
Fire Code Official: Date:

Updated:7_27_21 VI