

| 2020 NEC | Topic | 2017 NEC |
|------------------|---|------------------|
| Part I | General | Part I |
| 310.1 | Scope | 310.1 |
| 310.2 | Definitions | 310.2 |
| 310.3 | Conductors | 310.106 |
| 310.3(A) | Minimum Size of Conductors | 310.106(A) |
| 310.3(B) | Conductor Material | 310.106(B) |
| 310.3(C) | Stranded Conductors | 310.106(C) |
| 310.3(D) | Insulated | 310.106(D) |
| Part II | Construction Specifications | Part III |
| 310.4 | Conductor Constructions and Applications | 310.104 |
| Table 310.4(A) | Conductor Applications and Insulations Rated 600 Volts | Table 310.104(A) |
| Table 310.4(B) | Thickness of Insulation for Nonshielded Types RHH and RHW | Table 310.104(B) |
| | Solid Dielectric Insulated Conductors Rated 2000 Volts | |
| 310.6 | Conductor Identification | 310.110 |
| 310.6(A) | Grounded Conductors | 310.110(A) |
| 310.6(B) | Equipment Grounding Conductors | 310.110(B) |
| 310.6(C) | Ungrounded Conductors | 310.110(C) |



| 2020 NEC | Topic | 2017 NEC |
|-------------|--|---------------|
| 310.8 | Marking | 310.120 |
| 310.8(A) | Required Information | 310.120(A) |
| 310.8(B) | Method of Marking | 310.120(B) |
| 310.8(B)(1) | Surface Marking | 310.120(B)(1) |
| 310.8(B)(2) | Marker Tape | 310.120(B)(2) |
| 310.8(B)(3) | Tag Marking | 310.120(B)(3) |
| 310.8(B)(4) | Optional Marking of Wire Size | 310.120(B)(4) |
| 310.8(C) | Suffixes to Designate Number of Conductors | 310.120(C) |
| 310.8(D) | Optional Markings | 310.120(D) |
| Part III | Installation | Part II |
| 310.10 | Uses Permitted | 310.10 |
| 310.10(A) | Dry Locations | 310.10(A) |
| 310.10(B) | Dry and Damp Locations | 310.10(B) |
| 310.10(C) | Wet Locations | 310.10(C) |
| 310.10(D) | Locations Exposed to Direct Sunlight | 310.10(D) |
| 310.10(E) | Shielding | 310.10(E) |
| 310.10(E) | Direct-Burial Conductors | 310.10(F) |



| 2020 NEC | Topic | 2017 NEC |
|--------------|--|--------------------|
| 310.10(F) | Corrosive Conditions | 310.10(G |
| 310.10(G) | Conductors in Parallel | 310.10(H) |
| 310.10(G)(1) | General | 310.10(H)(1) |
| 310.10(G)(2) | Conductor and Installation Characteristics | 310.10(H)(2) |
| 310.10(G)(3) | Separate Cables or Raceways | 310.10(H)(3) |
| 310.10(G)(4) | Ampacity Adjustment | 310.10(H)(4) |
| 310.10(G)(5) | Equipment Grounding Conductors | 310.10(H)(5) |
| 310.10(G)(6) | Bonding Jumpers | 310.10(H)(6) |
| 310.12 | Single-Phase Dwelling Services and Feeders | 310.15(B)(7) |
| 310.12(A) | Services | 310.15(B)(7)(1) |
| 310.12(B) | Feeders | 310.15(B)(7)(2) |
| 310.12(C) | Feeder Ampacities | 310.15(B)(7)(3) |
| 310.12(D) | Grounded Conductors | 310.15(B)(7)(4) |
| Table 310.12 | Single-Phase Dwelling Services and Feeders | Table 310.15(B)(7) |
| | 578.11 30000 | [2011 NEC] |
| 310.14 | Ampacities for Conductors Rated 0-2000 Volts | 310.15 |
| 310.14(A) | General | 310.15(A) |



| 2020 NEC | Topic | 2017 NEC |
|--------------------|---|-----------------------|
| 310.14(A)(1) | Tables or Engineering Supervision | 310.15(A)(1) |
| 310.14(A)(2) | Selection of Ampacity | 310.15(A)(2) |
| 310.14(A)(3) | Temperature Limitation of Conductors | 310.15(A)(3) |
| 310.14(B) | Engineering Supervision | NEW |
| 310.15 | Ampacity Tables | 310.15(B) |
| 310.15(A) | General | 310.15(B)(1) |
| 310.15(B) | Ambient Temperature Correction Factors | 310.15(B)(2) |
| 310.15(B)(1) | General | 310.15(B)(2) |
| 310.15(B)(2) | Rooftop | 310.15(B)(3)(c) |
| Table 310.15(B)(1) | Ambient Temperature Correction Factors Based on | Table 310.15(B)(2)(a) |
| | 30°C (86°F) | |
| Table 310.15(B)(2) | Ambient Temperature Correction Factors Based on | Table 310.15(B)(2)(b) |
| | 40°C (104°F) | |
| 310.15(C) | Adjustment Factors | 310.15(B)(3) |
| 310.15(C)(1) | More than Three Current-Carrying Conductors | 310.15(B)(3)(a) |
| Table 310.15(C)(1) | Adjustment Factors for More Than Three Current-Carrying | Table 310.15(B)(3)(a) |
| | Conductors | |



| 2020 NEC | Topic | 2017 NEC |
|--------------|--|---------------------|
| 310.15(C)(2) | Raceway Spacing | 310.15(B)(3)(b) |
| 310.15(D) | Bare or Covered Conductors | 310.15(B)(4) |
| 310.15(E) | Neutral Conductor | 310.15(B)(5) |
| 310.15(F) | Grounding or Bonding Conductor | 310.15(B)(6) |
| 310.16 | Ampacities of Insulated Conductors in Raceway, Cable, or Earth | NEW |
| | (Directly Buried) (86°F) | |
| 310.17 | Ampacities of Single-Insulated Conductors in Free Air (86°F) | NEW |
| 310.18 | Ampacities of Insulated Conductors in Raceway or Cable (104°F) | NEW |
| 310.19 | Ampacities of Single-Insulated Conductors in Free Air (104°F) | NEW |
| 310.20 | Ampacities of Conductors Supported on a Messenger (104°F) | NEW |
| 310.21 | Ampacities of Bare or Covered Conductors in Free Air (104°F) | NEW |
| Table 310.16 | Ampacities of Insulated Conductors Not More Than Three | Table 310.15(B)(16) |
| | Current-Carrying Conductors in Raceway, Cable, or Earth | |
| | (Directly Buried) (86°F) | |
| Table 310.17 | Ampacities of Single-Insulated Conductors in Free Air (86°F) | Table 310.15(B)(17) |
| Table 310.18 | Ampacities of Insulated Conductors Not More Than Three | Table 310.15(B)(18) |
| | Current-Carrying Conductors in Raceway or Cable (104°F) | |



| 2020 NEC | Topic | 2017 NEC |
|-------------------|---|---------------------|
| Table 310.19 | Ampacities of Single-Insulated Conductors in Free Air (104°F) | Table 310.15(B)(19) |
| Table 310.20 | Ampacities of Conductors Supported on a Messenger (104°F) | Table 310.15(B)(20) |
| Table 310.21 | Ampacities of Bare or Covered Conductors in Free Air (104°F) | Table 310.15(B)(21) |
| 310.60 | Conductors Rated 2001 to 35,000 Volts | Moved to new |
| | | Article 311 |