

- SINGLE CHECK VALVES ARE NOT ACCEPTABLE BACK FLOW PREVENTION DEVICES
 NO CONNECTIONS OR PLUMBING DEVICES SHALL BE INSTALLED UPSTREAM OF THE BACK FLOW PREVENTION DEVICE EXCEPT AS SHOWN ABOVE.

TYPICAL WATER METER INSTALLATION

NOT TO SCALE



474 Windmere Drive State College, PA 16801 [814] 238 - 7117 Pex (814) 238 - 7126 hrg@hrg-inc.com www.hrg-inc.com

SUBURBAN WATER AUTHORITY

CLINTON COUNTY

	CADD-	MDS
	CHECKED-	
	SCALE-	AS NOTED
- 1	DATE	007 5000

DESIGN- DMS

PROJ. MOR. - DMS

PENNSYLVANIA DATE- OCT. 2009

SHEET NO. 1 or 1 PROJECT 0778.031

DRAWING NO.