

Public Water System
NAME: City of Carls Corner
ID: PWS 1090070

Boil Water Notification

BOIL YOUR WATER BEFORE USING

Condition(s) Requiring Notice

Our water system is issuing a boil water notice due to the following condition(s):

Reduced Distribution and line break.

Potential Adverse Health Effects

Due to the conditions, there is a possibility of contamination. Consumption of contaminated water may cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

What Should I Do?

DO NOT DRINK THE WATER WITHOUT BOILING IT FIRST. Bring all water to a boil, let it boil for one minute and let it cool before using, or use bottled water. Boiled or bottled water should be used for drinking, making ice, brushing teeth, washing dishes, and food preparation until further notice. Boiling kills bacteria and other organisms in the water.

What is Being Done?

Replacing rokelines and Charging system. Flushing line.

We will inform you when we have addressed the cause of the boil water notice and tests show no bacteria are present and you no longer need to boil your water.

For More Information, Please Contact:

PWS Contact Name: Susan Ezell

Phone: 254_580-3526 Email: cityofcarlscorner@gmail.com

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date distributed: 8/25/26