

Annexure C

Appendix - XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 284

Dated: 19/06/2026

It is certified that an inspection team headed by ASSISTANT ENGINEER (Name of Officers with designation) from JUHI JYOTI ASSISTANT ENGINEER (Name of Department / Office) inspected the HIMALAYAN ACADEMY PAKARTALLA (Name & Address of the school) on 19/06/2026 (date of inspection) checked the Water test report submitted by the school and found that the school has potable drinking water for the students and staff of the institution and is having provision for running water in the toilets and maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T. Govt.

The above is valid for a period of 01 YEAR

Signature with Seal: _____

Name: JUHI JYOTI

Designation: ASSISTANT ENGINEER

Name & Address of the Office / Department: P.H.SUB DIV
KAHALGAON

To

HIMALAYAN ACADEMY
PAKARTALLA, KAHALGAON
BHAGALPUR,

(Name & Address of the Institution)

**REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION**

Certificate

No. 86

DATE 08/06/2026

*It is certified that an inspection team headed by— Mr. Jai Kishan Kumar
(Assistant Chemist) from P. H. Division Bhagalpur East, Bhagalpur
inspected the Himalayan Academy, Pakartalla, Kahalgaon, Bhagalpur
on 05.06.2026 and found the Himalayan Academy, Pakartalla,
Kahalgaon, Bhagalpur has safe drinking water facilities for the students and
members of staff institution and is maintaining the hygienic sanitation condition in the school
campus as per the norms prescribed by the Central/State/U.T Govt.*

The above valid for a period of- *One Year (08.06.2026 to 07.06.2027).*

Signature With Seal:-

Name

Sanjay K. Paswan

Designation :-

Assistant Research Officer



To,

*Himalayan Academy
Pakartalla, Kahalgaon,
Bhagalpur
Bihar-813203*

Government Of Bihar

Regional Water Testing Laboratory

Public Health Engineering Department,
Bhagalpur

Name of School :- Himalayan Academy

Sample Collected By- Lab Staff
Source of Sample- R.O water

Ref.No. EE-1981 Dt- 03/06/2026

Date of Sampling - 05.06.2026

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No.	Location				Physico - Chemical and Bacteriological Parameters														Remarks		
	Block	Panchayat	Village	Habitation	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SC ₁	F		As	Microbial
1					Himalayan Academy Pakaralla, Kahalgaon, Dist- Bhagalpur (Bihar)-813203	7.84	0.69	185.1	90.7	46.2	18.5	6.16	21.9	44.1	0.19	3.78	6.9	0.02	NA	Negative	
					Desirable Limit* 6.5-8.5	1.0	-	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-	
					Permissible Limit* in absence of alternate source	NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**	

NA=Not Applicable

Memo No... *RL-86*

Date *08/06/2026*

Copy Forwarded To : 1. Executive Engineer, P.H. Division Bhagalpur East, for kind information and necessary action.

Sharma
08/06/26
Lab Incharge (A.R.O)