

EXHIBIT C – ATTIC STOCK REPORT

Project: Butts County Board of Education – Central Office Building

Scope Limited to Division 03, Division 09, Division 12 and Companion Documentation (if applicable)

Document Reviewed: Butts Co BOE – Addendum No. 1 Specifications

Created By: Compass Global | Powered by SQUARES AI Platform

1. Basis of Report

This Attic Stock Report is based solely on the Contract Document listed above. The specifications were explicitly searched for the terms **Attic Stock**, **Extra Material(s)**, and **Maintenance Material(s)**. Any requirement stated under these terms is classified as attic stock when quantities are provided. No assumptions or inferred quantities have been applied.

2. Document-Required Attic Stock

Spec Section	Material	Attic Stock Requirement (Verbatim)
093013	Ceramic Tile & Trim	Furnish full-size units equal to three (3) percent of amount installed for each type, composition, color, pattern, and size.
096519	Resilient Tile Flooring	Furnish full-size units equal to ten (10) percent of amount installed for each type indicated, but not less than twenty (20) square yards.
096813	Carpet Tile	Furnish full-size units equal to fifteen (15) percent of amount installed for each type indicated, but not less than twenty (20) square yards.

3. Excluded Sections

Section 096513 – Resilient Base was reviewed and does not include requirements for attic stock, extra materials, or maintenance materials.

4. Conclusion

The specifications require attic stock for ceramic tile, resilient tile flooring, and carpet tile as documented above. No additional attic stock requirements are stated for other scopes within Divisions 03, 09, or 12.