



Product Service

# Attestation of Conformity

No. N8A 076729 0114 Rev. 12

**Holder of Certificate:** **Seraphim Solar System Co.,Ltd.**  
No.1-2, Hengyao Rd, Henglin Zhen  
Wujin District  
213101 Changzhou  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-crystalline Silicon Photovoltaic Module**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704061801207-17

**Date,** 2021-01-27

( Zhulin Zhang )

Page 1 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



# Attestation of Conformity

No. N8A 076729 0114 Rev. 12

## Model(s):

1500 V DC Maximum System voltage,  
 Fire Safety Class C Modules:  
 SRP-xxx-6MA-HV (xxx=330-400, in step of 5);  
 SRP-xxx-6MB-HV (xxx=275-330, in step of 5);  
 SRP-xxx-E01A-HV (xxx=365-420, in step of 5);  
 SRP-xxx-E01B-HV (xxx=305-350, in step of 5);  
 SRP-xxx-BMA-HV (xxx=330-445, in step of 5);  
 SRP-xxx-BMA-HV (xxx=525-545, in step of 5);  
 SRP-xxx-BMB-HV (xxx=275-370, in step of 5);  
 SRP-xxx-BMB-HV (xxx=440-450, in step of 5);  
 SRP-xxx-BMC-HV (xxx=305-380, in step of 5);  
 SRP-xxx-BMC-HV (xxx=485-495, in step of 5);  
 SRP-xxx-BMD-HV (xxx=390-405, in step of 5);  
 SRP-xxx-E6A-HV (xxx=410-435, in step of 5);  
 SRP-xxx-E6B-HV (xxx=350-370, in step of 5);  
 SRP-xxx-BMZ-HV (xxx=425-450, in step of 5);  
 SRP-xxx-6MA-TB (xxx=330-400, in step of 5);  
 SRP-xxx-6MB-TB (xxx=275-330, in step of 5);  
 SRP-xxx-E01A-TB (xxx=365-420, in step of 5);  
 SRP-xxx-E01B-TB (xxx=305-350, in step of 5);  
 SRP-xxx-BMA-TB (xxx=330-445, in step of 5);  
 SRP-xxx-BMA-TB (xxx=525-545, in step of 5);  
 SRP-xxx-BMB-TB (xxx=275-370, in step of 5);  
 SRP-xxx-BMB-TB (xxx=440-450, in step of 5);  
 SRP-xxx-BMC-TB (xxx=305-380, in step of 5);  
 SRP-xxx-BMC-TB (xxx=485-495, in step of 5);  
 SRP-xxx-BMD-TB (xxx=390-405, in step of 5);  
 SRP-xxx-E6A-TB (xxx=410-435, in step of 5);  
 SRP-xxx-E6B-TB (xxx=350-370, in step of 5);  
 SRP-xxx-BMZ-TB (xxx=425-450, in step of 5);

1000 V DC Maximum System voltage,  
 Fire Safety Class C Modules:  
 SRP-xxx-6MA (xxx=330-400, in step of 5);  
 SRP-xxx-6MB (xxx=275-330, in step of 5);  
 SRP-xxx-E01A (xxx=365-420, in step of 5);  
 SRP-xxx-E01B (xxx=305-350, in step of 5);  
 SRP-xxx-BMA (xxx=330-445, in step of 5);  
 SRP-xxx-BMA (xxx=525-545, in step of 5);  
 SRP-xxx-BMB (xxx=275-370, in step of 5);  
 SRP-xxx-BMB (xxx=440-450, in step of 5);  
 SRP-xxx-BMC (xxx=305-380, in step of 5);  
 SRP-xxx-BMC (xxx=485-495, in step of 5);  
 SRP-xxx-BMD (xxx=390-405, in step of 5);  
 SRP-xxx-E6A (xxx=410-435, in step of 5);  
 SRP-xxx-E6B (xxx=350-370, in step of 5);  
 SRP-xxx-BMZ (xxx=425-450, in step of 5);

1500 V DC Maximum System voltage,  
 Fire Safety Class A Modules:  
 SRP-xxx-6MA-BG (xxx=350-395, in step of 5);  
 SRP-xxx-6MB-BG (xxx=295-325, in step of 5);  
 SRP-xxx-6MA-DG (xxx=350-395, in step of 5);  
 SRP-xxx-6MB-DG (xxx=295-325, in step of 5);  
 SRP-xxx-BMA-BG (xxx=350-445, in step of 5);  
 SRP-xxx-BMA-BG (xxx=525-540, in step of 5);  
 SRP-xxx-BMB-BG (xxx=290-370, in step of 5);



Product Service

# Attestation of Conformity

No. N8A 076729 0114 Rev. 12

SRP-xxx-BMB-BG (xxx=440-450, in step of 5);  
 SRP-xxx-BMC-BG (xxx=320-375, in step of 5);  
 SRP-xxx-BMC-BG (xxx=485-495, in step of 5);  
 SRP-xxx-BMD-BG (xxx=395-405, in step of 5);  
 SRP-xxx-BMA-DG (xxx=350-425, in step of 5);  
 SRP-xxx-BMB-DG (xxx=290-350, in step of 5);  
 SRP-xxx-BMC-DG (xxx=320-350, in step of 5);  
 SRP-xxx-BMZ-BG (xxx=425-450, in step of 5);  
 xxx is standing for rated output power at STC.

## Parameters:

Safety Class:	Class II
Max. System Voltage:	1000V DC or 1500V DC
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd No.8 Lanxiang Road Wujin Economic Development Zone Changzhou, Jiangsu, China.
Construction:	Framed or Frameless, with Junction box, cable and connector.
Fire Safety Class:	Class C or Class A according to UL790

## Tested according to:

EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06

Page 3 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.