

SECTION 23 09 23

DIRECT DIGITAL CONTROL SYSTEM FOR HVAC

1.1 SECTION INCLUDES

- A. Building Management System (BMS), utilizing direct digital controls. (WEBsN4)

1.2 RELATED WORK SPECIFIED ELSEWHERE

- A. Products Supplied but Not Installed Under This Section:
 - 1. Control valves.
 - 2. Flow switches.
 - 3. Wells, sockets and other inline hardware for water sensors (temperature, pressure, flow).
 - 4. Automatic control dampers, where not supplied with equipment.
 - 5. Airflow measuring stations.
 - 6. Terminal unit controllers and actuators, when installed by terminal unit manufacturer.
 - 7. Variable frequency drives. (This does not include VFDs integral to machinery such as chillers or boilers).
- B. Products Installed but Not Supplied Under This Section:
 - 1. None.
- C. Products Not Furnished or Installed but Integrated with the Work of This Section:
 - 1. Chiller control systems.
 - 2. Boiler control systems.
 - 3. Pump control packages.
 - 4. In-line meters (gas, water, power).
 - 5. Refrigerant monitors.
 - 6. Chemical water treatment.
 - 7. Smoke detectors (through alarm relay contacts).
 - 8. HVAC units / equipment.
- D. Work Required Under Other Divisions Related to This Section:
 - 1. Power wiring for motors, motor starters, disconnects, and variable frequency drives.
 - 2. Provision and wiring of smoke detectors and other devices relating to fire alarm system.
 - 3. Campus LAN (Ethernet) connection adjacent to JACE network management controller.

1.3 RELATED SECTIONS

- A. Section 23 05 00 - Common Work Results for HVAC.

1.4 SYSTEM DESCRIPTION

- A. Scope: Furnish all labor, materials and equipment necessary for a complete and operating Building Management System (BMS), utilizing Direct Digital Controls as shown on the drawings and as described herein. Drawings are diagrammatic only. All controllers furnished in this section shall communicate on a peer-to-peer bus over an open protocol bus (Examples: LonTalk, BACnet, MODBUS).
 - 1. The intent of this specification is to provide a system that is consistent with any current BMS systems throughout the owner's facilities running the Niagara 4

Framework.

2. System architecture shall fully support a multi-vendor environment and be able to integrate third party systems via existing vendor protocols including, as a minimum, LonTalk, BACnet and MODBUS.
 3. System architecture shall provide secure Web access using any of the current versions of Microsoft Internet Explorer, Mozilla Firefox, or Google Chrome browsers from any computer on the owner's LAN.
 4. All control devices furnished with this Section shall be programmable directly from the Niagara 4 Workbench embedded toolset upon completion of this project. The use of configurable or programmable controllers that require additional software tools for post-installation maintenance shall not be acceptable.
 5. Any control vendor that shall provide additional BMS server software shall be unacceptable. Only systems that utilize the Niagara 4 Framework shall satisfy the requirements of this section.
 6. The BMS server shall host all graphic files for the control system. Where applicable all graphics and navigation schemes for this project shall match those that are on the existing campus NiagaraAX or Niagara 4 Framework server.
 7. A computer including engineering/programming software to modify Operating System Server BMS programs and graphics shall be included for any site consisting of more than a single JACE (SNC), where called out elsewhere, or any site requiring licensing for more than 75 devices.
 8. Owner shall receive all applicable Administrator level login and passwords for engineering toolset at first training session. The Owner shall have full licensing and full access rights for all network management, operating system server, engineering and programming software required for the ongoing maintenance and operation of the BMS.
 9. OPEN NIC STATEMENTS - All Niagara 4 software licenses shall have the following NiCS: "accept.station.in=*"; "accept.station.out=*"and "accept.wb.in=*"and "accept.wb.out=*". All open NIC statements shall follow Niagara Open NIC specifications.
 10. All JACE hardware licenses and certificates shall be stored on local MicroSD memory card employing encrypted "safe boot" technology.
- B. All products of the BMS shall be provided with the following agency approvals. Verification that the approvals exist for all submitted products shall be provided on request, with the submittal package. Systems or products not currently offering the following approvals are not acceptable.
1. Federal Communications Commission (FCC), Rules and Regulations, Volume II -July 1986 Part 15 Class A Radio Frequency Devices.
 2. FCC, Part 15, Subpart B, Class B
 3. FCC, Part 15, Subpart C
 4. FCC, Part 15, Subpart J, Class A Computing Devices.
 5. UL 504 - Industrial Control Equipment.
 6. UL 506 - Specialty Transformers.
 7. UL 910 - Test Method for Fire and Smoke Characteristics of Electrical and Optical-Fiber Cables Used in Air-Handling Spaces.
 8. UL 916 - Energy Management Systems All.
 9. UL 1449 - Transient Voltage Suppression.
 10. Standard Test for Flame Propagation Height of Electrical and Optical - Fiber Cables Installed Vertically in Shafts.
 11. EIA/ANSI 232-E - Interface Between Data Technical Equipment and Data Circuit Terminal Equipment Employing Serial Binary Data Interchange.
 12. EIA 455 - Standard Test Procedures for Fiber Optic Fibers, Cables, Transducers, Connecting and Terminating Devices.
 13. IEEE C62.41- Surge Voltages in Low-Voltage AC Power Circuits.
 14. IEEE 142 - Recommended Practice for Grounding of Industrial and Commercial

- Power Systems.
- a. NEMA 250 - Enclosures for Electrical Equipment.
- 15. NEMA ICS 1 - Industrial Controls and Systems.
- 16. NEMA ST 1 - Specialty Transformers.
- 17. NCSBC Compliance, Energy: Performance of control system shall meet or surpass the requirements of ASHRAE/IESNA 90.1-1999.
- 18. CE 61326.
- 19. C-Tick.
- 20. cUL.

1.5 SPECIFICATION NOMENCLATURE

- A. Acronyms used in this specification are as follows:
 - 1. Actuator: Control device that opens or closes valve or damper in response to control signal.
 - 2. AI: Analog Input.
 - 3. AO: Analog Output.
 - 4. Analog: Continuously variable state overstated range of values.
 - 5. AUC: Advanced Unitary Controller.
 - 6. BCT: BACnet Touchscreen Communicating Thermostat.
 - 7. BMS: Building Management System.
 - 8. DDC: Direct Digital Control.
 - 9. Discrete: Binary or digital state.
 - 10. DI: Discrete Input.
 - 11. DO: Discrete Output.
 - 12. FC: Fail Closed position of control device or actuator. Device moves to closed position on loss of control signal or energy source.
 - 13. FO: Fail open (position of control device or actuator). Device moves to open position on loss of control signal or energy source.
 - 14. GUI: Graphical User Interface.
 - 15. HMI: Human Machine Interface.
 - 16. HVAC: Heating, Ventilating and Air Conditioning.
 - 17. IDC: Interoperable Digital Controller.
 - 18. ILC: Interoperable Lon Controller.
 - 19. LAN: Local Area Network.
 - 20. Modulating: Movement of a control device through an entire range of values, proportional to an infinitely variable input value.
 - 21. Motorized: Control device with actuator.
 - 22. NAC: Network Area Controller.
 - 23. NC: Normally closed position of switch after control signal is removed or normally closed position of manually operated valves or dampers.
 - 24. NO: Normally open position of switch after control signal is removed; or the open position of a controlled valve or damper after the control signal is removed; or the usual position of a manually operated valve.
 - 25. OSS: Operating System Server, host for system graphics, alarms, trends, etc.
 - 26. Operator: Same as actuator.
 - 27. PC: Personal Computer.
 - 28. Peer-to-Peer: Mode of communication between controllers in which each device connected to network has equal status and each shares its database values with all other devices connected to network.
 - 29. P: Proportional control; control mode with continuous linear relationship between observed input signal and final controlled output element.
 - 30. PI: Proportional-Integral control, control mode with continuous proportional output plus additional change in output based on both amount and duration of change in controller variable (reset control).
 - 31. PICS: BACnet Product Interoperability Compliance Statement.

- 32. PICU: Programmable IP Control Unit.
- 33. PID: Proportional-Integral-Derivative control, control mode with continuous correction of final controller output element versus input signal based on proportional error, its time history (reset) and rate at which it's changing (derivative).
- 34. Point: Analog or discrete instrument with addressable database value.
- 35. PPCU: Programmable Plant Control Unit.
- 36. UICU: Unitary IP Control Unit.
- 37. WAN: Wide Area Network.

1.6 SUBMITTALS

- A. Submit under provisions of Section 01 30 00 - Administrative Requirements.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Submit documentation of contractor qualifications, including those indicated in "Quality Assurance" if requested by the A-E.
- D. One copy of CAD based shop drawings in PDF format of the entire control system shall be submitted and shall include a complete list of equipment and materials, including manufacturers' catalog data sheets and installation instructions.
- E. Shop drawings shall also contain complete wiring and schematic diagrams, sequences of operation, control system bus layout and any other details required to demonstrate that the system has been coordinated and will properly function as a system. Terminal identification for all control wiring shall be shown on the shop drawings.
- F. Upon completion of the work, provide electronic 'as-built' drawings and other project-specific documentation.
- G. Any deviations from these specifications or the work indicated on the drawings shall be clearly identified in the Submittals.

1.7 QUALITY ASSURANCE

- A. The Control System Contractor shall have a full service DDC office within 75 miles of the job site. It is preferable that **multiple** contractor bids **using the same manufacturer** be provided. The office shall be staffed with applications engineers, software engineers and field technicians. Additionally, one professional engineer or both a master HVAC and a master electrician. This office shall maintain parts inventory and shall have all testing and diagnostic equipment necessary to support this work, as well as staff trained in the use of this equipment.
- B. Single Source Responsibility of Supplier: The Control System Contractor shall be responsible for the complete installation and proper operation of the control system. The Control System Contractor shall exclusively be in the regular and customary business of design, installation and service of computerized building management systems similar in size and complexity to the system specified. The Control System Contractor shall be the manufacturer of the primary DDC system components or shall be an authorized representative for the primary DDC components manufacturer with staff experience composing at a minimum of at 20 years' work experience with the manufacturers control system equipment.
- C. Equipment and Materials: Equipment and materials shall be cataloged products of

manufacturers regularly engaged in the production and installation of HVAC control systems. Products shall be manufacturer's latest standard design and have been tested and proven in actual use.

1.8 PRE-INSTALLATION MEETINGS

- A. Convene minimum two weeks prior to starting work of this section.

1.9 DELIVERY, STORAGE AND HANDLING

- A. Maintain integrity of shipping cartons for each piece of equipment and control device through shipping, storage and handling as required to prevent equipment damage. Store equipment and materials inside and protected from weather.

1.10 JOB CONDITIONS

- A. Cooperation with Other Trades: Coordinate the Work of this section with that of other sections to ensure that the Work will be carried out in an orderly fashion. It shall be this Contractor's responsibility to check the Contract Documents for possible conflicts between his Work and that of other crafts in equipment location, pipe, duct and conduit runs, electrical outlets and fixtures, air diffusers and structural and architectural features.

1.11 SEQUENCING

- A. Ensure that products of this section are supplied to affected trades in time to prevent interruption of construction progress.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Basis of Design: Honeywell Building Technologies, which is located at: 715 Peachtree St. NE, Atlanta, GA 30308; Only Honeywell-registered WEBs Contractors are acceptable as defined as:
 1. Authorized Controls Integrator (ACI Direct, ACI Elite or ACI)
 2. Building Control Specialist (BCS)
 3. WEBs Contractor
 4. Applied Building Systems - Timberville VA. 540-773-2355
info@appliedbuildingsystems.com
- B. Substitutions: Not permitted except with permission of the Engineer in writing.

2.2 GENERAL

- A. The Building Management System (BMS) shall be comprised of a network of interoperable, stand-alone digital controllers, a network area controller, graphics and programming and other control devices for a complete system as specified herein.
- B. The installed system shall provide secure password access to all features, functions and data contained in the overall BMS.

2.3 OPEN, INTEROPERABLE, INTEGRATED ARCHITECTURE

- A. The intent of this specification is to provide a peer-to-peer networked, stand-alone, distributed control system utilizing Open protocols in one open, interoperable system.
- B. The software shall employ object-oriented technology (OOT) for representation of all data and control devices within the system.

- C. All components and controllers supplied under this contract shall be true "peer-to-peer" communicating devices. Components or controllers requiring "polling" by a host to pass data shall not be acceptable.
- D. The supplied system shall incorporate the ability to access all data using HTML5 enabled browsers without requiring proprietary operator interface and configuration programs or browser plug-ins. An Open Database Connectivity (ODBC) or Structured Query Language (SQL) compliant server database is required for all system database parameter storage. This data shall reside on the Operating System Server located in the Facilities Office on the LAN. Systems requiring proprietary database and user interface programs shall not be acceptable.
- E. A hierarchical topology is required to assure reasonable system response times and to manage the flow and sharing of data without unduly burdening the customer's internal Intranet network. Systems employing a "flat" single tiered architecture shall not be acceptable.
 - 1. Maximum acceptable response time from any alarm occurrence (at the point of origin) to the point of annunciation shall not exceed 5 seconds for network connected user interfaces.
 - 2. Maximum acceptable response time from any alarm occurrence (at the point of origin) to the point of annunciation shall not exceed 60 seconds for remote or dial-up connected user interfaces.

2.4 BAS SERVER HARDWARE : When Applicable

- A. Minimum Computer Configuration (Hardware Independent).
 - 1. Central Server. Owner shall provide a dedicated BAS server with configuration that includes the following components as a minimum:
 - 2. Processor: Intel Xeon CPU E5-2640 x64 (or better), compatible with dual- and quad-core processors.
 - 3. Memory: 2 GB or more recommended for large systems, 8 GB or more recommended for the Windows 64-bit version.
 - 4. Hard Drive: 256 GB minimum, more recommended depending on archiving requirements.
 - 5. Display: Video card and monitor capable of displaying 1024 x 768 pixel resolution or greater.
 - 6. Network Support: Ethernet adapter (10/100 Mb with RJ-45 connector).
 - 7. Connectivity: Full-time high-speed ISP connection recommended for remote site access (i.e. T1, ADSL, cable modem).
- B. Standard Client: The thin-client Web Browser BAS GUI shall be Microsoft Internet Explorer (10.0 or later) running on Microsoft 7+. No special software shall be required to be installed on the PCs used to access the BAS via a web browser.

2.5 SYSTEM NETWORK CONTROLLER (SNC)

- A. These controllers are designed to manage communications between the Programmable IP Control Units (PICU), Programmable Plant Control Units (PPCU), Unitary IP Control Unit (UICU), Advanced Unitary Controllers (AUC), and BACnet Touchscreen Communication Thermostats (BCT) which are connected to its communications trunks or directly on the IP network, manage communications between itself and other system network controllers (SNC), PICUs, PPCUs, UICUs, and with any operator workstations (OWS) that are part of the BAS, and perform control and operating strategies for the system based on information from any controller connected to the BAS.
- B. The controllers shall be fully programmable to meet the unique requirements of the facility it shall control.

- C. The controllers shall be capable of peer-to-peer communications with other SNC's, PICUs, PPCUs, UICUs, and with any OWS connected to the BAS, whether the OWS is directly connected, connected via cellular modem or connected via the Internet.
- D. The communication protocols utilized for peer-to-peer communications between SNC's will be Niagara 4 FoxS, BACnet TCP/IP and SNMP. Use of a proprietary communication protocol for peer-to-peer communications between SNC's is not allowed.
- E. The SNC shall employ a device count capacity license model that supports expansion capabilities.
- F. The SNC shall be enabled to support and shall be licensed with the following Open protocol drivers (client and server) by default:
 - 1. BACnet
 - 2. Lon
 - 3. MODBUS
 - 4. SNMP
 - 5. KNX
- G. The SNC shall be capable of executing application control programs to provide:
 - 1. Calendar functions.
 - 2. Scheduling.
 - 3. Trending.
 - 4. Alarm monitoring and routing.
 - 5. Time synchronization.
 - 6. Integration of LonWorks, BACnet, and MODBUS controller data.
 - 7. Network management functions for all SNC, PICU, PPCU, UICU, AUC and BCT based devices.
- H. The SNC shall provide the following hardware features as a minimum:
 - 1. Two 10/100 Mbps Ethernet ports.
 - 2. Two Isolated RS-485 ports with biasing switches.
 - 3. 1 GB RAM
 - 4. 4 GB Flash Total Storage / 2 GB User Storage
 - 5. Wi-Fi (Client or WAP)
 - 6. USB Flash Drive
 - 7. High Speed Field Bus Expansion
 - 8. -20-60 degrees C Ambient Operating Temperature
 - 9. Integrated 24 VAC/DC Global Power Supply
 - 10. MicroSD Memory Card Employing Encrypted Safe Boot Technology
- I. The SNC shall support standard Web browser access via the Intranet/Internet. It shall support a minimum of 16 simultaneous users.
- J. The SNC shall provide alarm recognition, storage, routing, management and analysis to supplement distributed capabilities of equipment or application specific controllers.
- K. The SNC shall be able to route any alarm condition to any defined user location whether connected to a local network or remote via cellular modem, or wide-area network.
 - 1. Alarm generation shall be selectable for annunciation type and acknowledgement requirements including but not limited to:
 - a. Alarm.
 - b. Return to normal.
 - c. To default.
 - 2. Alarms shall be annunciated in any of the following manners as defined by the user:
 - a. Screen message text.
 - b. Email of complete alarm message to multiple recipients.

- c. Pagers via paging services that initiate a page on receipt of email message.
 - d. Graphics with flashing alarm object(s).
- 3. The following shall be recorded by the SNC for each alarm (at a minimum):
 - a. Time and date.
 - b. Equipment (air handler #, access way, etc.).
 - c. Acknowledge time, date, and user who issued acknowledgement.
- L. Programming software and all controller "Setup Wizards" shall be embedded into the SNC.
- M. The SNC shall support the following security functions.
 - 1. Module code signing to verify the author of programming tool and confirm that the code has not been altered or corrupted.
 - 2. Role-Based Access Control (RBAC) for managing user roles and permissions.
 - 3. Require users to use strong credentials.
 - 4. Data in Motion and Sensitive Data at Rest be encrypted.
 - 5. LDAP and Kerberos integration of access management.
- N. The SNC shall support the following data modeling structures to utilize Search; Hierarchy; Template; and Permission functionality:
 - 1. Metadata: Descriptive tags to define the structure of properties.
 - 2. Tagging: Process to apply metadata to components
 - 3. Tag Dictionary
- O. The SNC shall employ template functionality. Templates are a containerized set of configured data tags, graphics, histories, alarms... that are set to be deployed as a unit based upon manufacturer's controller and relationships. All lower level communicating controllers (PICU, PPCU, UICU, AUC) shall have an associated template file for reuse on future project additions.
- P. The SNC shall be provided with a 5 Year Software Maintenance license. Labor to implement not included.

2.6 PROGRAMMABLE IP CONTROL UNIT (PICU)

- A. HVAC PICU controllers shall be fully programmable to meet the unique requirements of the facility it shall control. The controller platform shall provide options and advanced system functions, programmable and configurable using Niagara 4 Framework, that allow standard and customizable control solutions required in executing the "Sequence of Operation". PICU shall be BACnet BTL; AWS/C, WSP listed. PICU shall meet the BACnet Building Controller (B-BC) Profile.
- B. All PICUs shall be application programmable and shall always maintain their certification. All control sequences within or programmed into the PICU shall be stored in non-volatile memory, which is not dependent upon the presence of a battery to be retained.
- C. The controllers shall be capable of daisy-chain IP communications with other PICU's and peer-to-peer communications with SNC's and with any OWS connected to the BAS, whether the OWS is directly connected, connected via cellular modem or connected via the Internet.
 - 1. Daisy Chain IP connectivity Integrated Fail-safe utilizing Rapid Spanning Tree Protocol 802.1w.
- D. The communication protocols utilized for peer-to-peer communications between PICU's will be Niagara 4 FoxS or BACnet TCP/IP. Use of a proprietary communication protocol for peer-to-peer communications between PICU's is not allowed.
- E. The PICU shall be licensed and enabled to support four (4) devices and shall be licensed with the following Open protocol drivers by default:

1. BACnet IP
- F. The PICU shall be provided with Lifetime Software Maintenance license. Labor to implement not included.
- G. The PICU shall be capable of executing application control programs to provide:
1. Calendar functions.
 2. Scheduling.
 3. Trending.
 4. Alarm monitoring and routing.
 5. Time synchronization.
 6. Integration of all daisy-chain PICU's.
 7. Network management functions for all daisy-chain PICU's.
- H. Programming software shall be embedded into the PICU. The PICU shall not require any external configuration tool or programming tool. All configuration and programming tasks shall be accomplished and accessible from within the embedded Niagara 4 environment.
- I. The PICU shall support the following security functions.
1. Module code signing to verify the author of programming tool and confirm that the code has not been altered or corrupted.
 2. Role-Based Access Control (RBAC) for managing user roles and permissions.
 3. Require users to use strong credentials.
 4. Data in Motion and Sensitive Data at Rest be encrypted.
 5. Encrypted (PKI) Secure IP Stack Communication Security.
 6. FIPS 140-2 Level 1 Cryptographic Module Compliant.
- J. The minimum controller Environmental ratings.
1. Operating Temperature Ambient Rating: -4 degrees to 131 degrees F (-20 degrees to 55 degrees C).
 2. Storage Temperature Ambient Rating: -4 degrees to 150 degrees F (-20 degrees to 65 degrees C).
 3. Relative Humidity: 5% to 95% non-condensing
- K. The controller shall have the additional approval requirements, listings, and approvals:
1. UL 60730-1.
 2. Meets FCC Part 15, Subpart B, Class B (radiated emissions) requirements.
 3. Conforms requirements European Consortium standard EN 61000-6-1; 2001 (EU Immunity).
 4. Conforms requirements European Consortium standard EN 61000-6-3; 2001 (EU Emission).
 5. The controller housing shall be UL plenum rated mounting to either a panel or DIN rail (2.3" x 5.3" x 4.3"; 57.4mm x 135mm x 110mm).
- L. The PICU shall provide the following hardware features as a minimum:
1. The PICU shall provide LED indication of Power, Fault, Ethernet TX/RX/Traffic/Speed without cover removal.
 2. Four 10/100/1000 Mbps Ethernet unmanaged switch, RJ-45 ports.
 3. ARM 9 32-bit processor, 800 MHz
 4. 1 GB RAM
 5. 512 KB MRAM
 6. 2 GB Flash Memory
 7. One USB 2.0 port.
 8. 2.0 A fast-acting Overcurrent Protection.
 9. Integrated 20-30 VAC Global Power Supply
 10. Real Time Clock, 24-hour, 365 day, multi-year calendar +/- 1 minute per month at 77F (25C).

11. RTC Power Failure Backup, 24 hours at 32 degrees to 100 degrees F (0 degrees to 38 degrees C)
 12. Power Output: 20 VDC +/- 10% at 7 mA maximum.
 13. AC power consumption at 9VA, max 100VA.
 14. Removable Terminal Blocks.
 15. Sensor, Actuator, and I/O Module Expandability via a 2-wire, polarity insensitive local PICU communication bus.
 16. 150 Point Base License (Expandable).
 17. LED for each hardware I/O point.
 18. Output H-O-A Switches.
 19. VAV PICU shall include an internal differential pressure sensor.
 - a. Operating Range: 0 to 2-inch WC (0 to 374 Pa).
 - b. Accuracy: +/- 2% of full scale at 32 degrees to 122 degrees F (0 degrees to 50 degrees C).
- M. The PICU shall support standard Web browser access via the Intranet/Internet.
- N. The PICU shall be able to route any alarm condition to any defined user location whether connected to a local network or wide-area network.
1. Alarm generation shall be selectable for annunciation type and acknowledgement requirements including but not limited to:
 - a. Alarm.
 - b. Return to normal.
 - c. To default.
 2. Alarms shall be annunciated in any of the following manners as defined by the user:
 - a. Screen message text.
 - b. Email of complete alarm message to multiple recipients.
 - c. Pagers via paging services that initiate a page on receipt of email message.
 - d. Graphics with flashing alarm object(s).
 3. The following shall be recorded by the PICU for each alarm (at a minimum):
 - a. Time and date.
 - b. Equipment (air handler #, access way, etc.).
 - c. Acknowledge time, date, and user who issued acknowledgement.
- O. PICU Controllers shall support at minimum the following control techniques:
1. General-purpose control loops that can incorporate Demand Limit Control strategies, Set point reset, adaptive intelligent recovery, and time of day bypass.
 2. General-purpose, non-linear control loops.
 3. Start/stop Loops.
 4. If/Then/Else logic loops.
 5. Math Function loops (MIN, MAX, AVG, SUM, SUB, SQRT, MUL, DIV, ENTHALPY).
 6. Analytic calculations.
- P. The following six [6] integral Universal Inputs/Outputs shall be supported per each PICU:
1. UI/O as Analog Inputs; 16 Bit resolution (Thermistor or RTD configurable from 100 to 100K Ohm, 0-10 VDC, 4-20 mA).
 2. UI/O as Digital Inputs; Dry Contact / Totalizer.
 - a. Dry Contact to detect Open / Closed Circuit (Voltage Rating; 0-30 VDC Open Circuit: Resistance Rating; Open Circuit >3,000 Ohms, Closed Circuit <500 Ohms).
 - b. Totalizer – Dry Contact (100 Hz, 360,000 pulses per hour maximum frequency: Minimum Duty Cycle 5 ms ON / 5 ms OFF).
 3. UI/O as Analog Outputs ([3] UI/O can be configured as AO)
 - a. 0-10.0 Vdc, 10.0mA maximum.
 - b. 0-20.0 mA, 550 Ohms maximum.
 4. LED for each hardware I/O point.

- Q. The following six [6] integral Digital Outputs (Triac) shall be supported per each PICU:
1. Solid State Relay normally open contacts, 20-30 VAC @ 50/60 Hz, at 1.0 A Continuous, 3.5 A Inrush.
 2. LED for each hardware I/O point.
 3. Output H-O-A Switches.
- R. The PICU shall employ a 150 Point Base License (expandable) device count capacity license model that supports I/O expansion capabilities.
- S. Each PICU shall have expansion ability to support additional I/O requirements through the use of remote input/output modules and a local communication bus. Each PICU shall be able to support a maximum of 15 Expansion I/O Modules for a maximum of 312 physical I/O points.
1. Mixed Expansion I/O Modules (UI/O & DO) shall communicate with PICU via a 2-wire bus and include removable terminals for field device wires.
 2. Mixed Expansion I/O Modules shall be available in the following configurations:
 - a. 3 UI/O, 2 AO, and 2 DO (7 Points).
 - b. 14 UI/O (5 can be configured as AO), and 6 DO (20 Points).
 3. Universal Inputs/Outputs shall be supported per each Expansion I/O Module:
 - a. UI/O as Analog Inputs; 16 Bit resolution (Thermistor or RTD configurable from 100 to 100K Ohm, 0-10 VDC, 4-20 mA).
 - b. UI/O as Digital Inputs; Dry Contact / Totalizer.
 - 1) Dry Contact to detect Open / Closed Circuit (Voltage Rating; 0-30 VDC Open Circuit: Resistance Rating; Open Circuit >3,000 Ohms, Closed Circuit <500 Ohms).
 - 2) Totalizer – Dry Contact (100 Hz, 360,000 pulses per hour maximum frequency: Minimum Duty Cycle 5 ms ON / 5 ms OFF).
 - c. UI/O as Analog Outputs (UI/O can be configured as AO)
 - 1) 0-10.0 Vdc, 10.0mA maximum.
 - 2) 0-20.0 mA, 550 Ohms maximum.
 - d. LED for each hardware I/O point.
 4. Digital Outputs (Triac) shall be supported per each Expansion I/O Module:
 - a. Solid State Relay normally open contacts, 20-30 VAC @ 50/60 Hz, at 1.0 A Continuous, 3.5 A Inrush.
 - b. LED for each hardware I/O point.
 - c. Output H-O-A Switches.
- T. The PICU shall not include an integrated Local Operator Interface but shall be capable of utilizing a standard browser-based device such as a Tablet, Touch Screen Device, etc.

2.7 PROGRAMMABLE PLANT CONTROL UNIT (PPCU)

- A. HVAC PPCU controllers shall be fully programmable to meet the unique requirements of the facility it shall control. The controller platform shall provide options and advanced system functions, programmable and configurable using Niagara 4 Framework, that allow standard and customizable control solutions required in executing the "Sequence of Operation".
- B. All PPCUs shall be application programmable and shall always maintain their certification. All control sequences within or programmed into the PPCU shall be stored in non-volatile memory, which is not dependent upon the presence of a battery to be retained.
- C. The PPCUs shall be capable of daisy-chain IP communications with other PPCU's and peer-to-peer communications with SNC's and with any OWS connected to the BAS, whether the OWS is directly connected, connected via cellular modem or connected via the Internet.
- D. The communication protocols utilized for peer-to-peer communications between PPCU's will be Niagara 4 FoxS or BACnet TCP/IP. Use of a proprietary communication protocol for peer-

to-peer communications between PPCU's is not allowed.

- E. The PPCU shall be licensed and enabled to support five (5) devices and shall be licensed with the following Open protocol drivers by default:
 - 1. BACnet (MS/TP and IP [ISO 16484-5])
 - 2. LonTalk (ISO 14908)
 - 3. MODBUS (RTU and TCP)
- F. The PPCU shall be provided with a 1 Year Software Maintenance license. Labor to implement not included if greater than 1 year is required.
- G. The PPCU shall provide LED indication of communication and controller performance to the technician, without cover removal.
- H. The PPCU shall be capable of executing application control programs to provide:
 - 1. Calendar functions.
 - 2. Scheduling.
 - 3. Trending.
 - 4. Alarm monitoring and routing.
 - 5. Time synchronization.
 - 6. Integration of all daisy-chain PPCU's.
 - 7. Network management functions for all daisy-chain PPCU's.
- I. Programming software shall be embedded into the PPCU. The PPCU shall not require any external configuration tool or programming tool. All configuration and programming tasks shall be accomplished and accessible from within the embedded Niagara 4 environment.
- J. The PPCU shall support the following security functions.
 - 1. Module code signing to verify the author of programming tool and confirm that the code has not been altered or corrupted.
 - 2. Role-Based Access Control (RBAC) for managing user roles and permissions.
 - 3. Require users to use strong credentials.
 - 4. Data in Motion and Sensitive Data at Rest be encrypted.
- K. The PPCU shall provide the following hardware features as a minimum:
 - 1. Two 10/100 Mbps Ethernet ports.
 - 2. Two RS-485 ports, one isolated and one non-isolated, with biasing switches.
 - 3. ARM 9 32-bit processor, 1 GHz
 - 4. 1 GB RAM
 - 5. 512 KB MRAM
 - 6. 4 GB Flash Memory
 - 7. Two USB 2.0 ports
 - 8. One HMI port to connect onboard or remote HMI.
 - 9. 0-50 degrees C Ambient Operating Temperature
 - 10. Integrated 24 VAC/DC Global Power Supply
 - 11. Real Time Clock
- L. The PPCU shall support standard Web browser access via the Intranet/Internet.
- M. The PPCU shall be able to route any alarm condition to any defined user location whether connected to a local network or remote via cellular modem, or wide-area network.
 - 1. Alarm generation shall be selectable for annunciation type and acknowledgement requirements including but not limited to:
 - a. Alarm.
 - b. Return to normal.
 - c. To default.
 - 2. Alarms shall be annunciated in any of the following manners as defined by the user:

- a. Screen message text.
 - b. Email of complete alarm message to multiple recipients.
 - c. Pagers via paging services that initiate a page on receipt of email message.
 - d. Graphics with flashing alarm object(s).
3. The following shall be recorded by the PPCU for each alarm (at a minimum):
- a. Time and date.
 - b. Equipment (air handler #, access way, etc.).
 - c. Acknowledge time, date, and user who issued acknowledgement.
- N. PPCU Controllers shall support at minimum the following control techniques:
- 1. General-purpose control loops that can incorporate Demand Limit Control strategies, Set point reset, adaptive intelligent recovery, and time of day bypass.
 - 2. General-purpose, non-linear control loops.
 - 3. Start/stop Loops.
 - 4. If/Then/Else logic loops.
 - 5. Math Function loops (MIN, MAX, AVG, SUM, SUB, SQRT, MUL, DIV, ENTHALPY).
- O. The following twenty-six [26] integral Inputs/Outputs shall be supported per each PPCU:
- 1. Six integral 12 Bit resolution Universal Inputs (configurable as 20K NTC, 10K NTC, 0/2-10V, 0/4-20mA, 0.4Hz Dry Contact).
 - 2. Four integral dry contact / totalizer Digital Inputs. Totalizer: 15Hz (25ms on, 25ms off, 5ms bounce).
 - 3. Four integral 8 Bit 0-10 Vdc Analog Outputs with configurable safety position selections.
 - 4. Eight integral Digital Outputs.
 - a. Four Relay normally open contact at 3A, 250Vac, 30Vdc.
 - b. One Relay normally open contact at 10A, 250Vac, 30Vdc with configurable safety position selections.
 - c. Three Relay normally open contact with common feed at 3A, 250Vac, 30Vdc with configurable safety position selections.
- P. The PPCU shall employ a device count capacity license model that supports I/O expansion capabilities.
- Q. Each PPCU shall have expansion ability to support additional I/O requirements through the use of remote input/output modules and a local communication bus. Each PPCU shall be able to support a maximum of 1,200+ physical I/O points.
- 1. I/O-specific modules (UI, BI, AO, BO) shall require a Terminal Socket Module that includes screw or push-in terminals for field device wires, communication, and port to accept pluggable I/O-specific Module. I/O-specific Modules shall be hot pluggable and shall be replaceable without rewiring.
 - 2. Remote Universal Input Module (8 UI).
 - a. Eight Universal Inputs; 0/2-10V, 0/4-20mA, 20K NTC, 10K NTC, PT1000-1, PT1000-2, NI1000TK5000, PT3000, BALCO500, Binary Input (0 / 10V with pull-up).
 - 3. Remote Binary Input Module (12 BI).
 - a. Twelve Binary Inputs; Dry contact or Totalizer (20Hz)
 - b. Each Binary Input shall include a configurable status LED (Alarm: red/green; Status: yellow/off).
 - 4. Remote Analog Output Module (8 AO).
 - a. Eight Analog Outputs with configurable safety position selections. 8 Bit Analog Outputs; 0-10V, Floating Actuator, Binary Output (0V / 10V).
 - b. Each Analog Output shall include a RED status LED that varies brightness based on signal level & flashes in override mode (with manual override Module).
 - c. Optional version with manual override potentiometer per output.

5. Remote Relay Output Module (6 BO).
 - a. Six Relay Outputs with configurable safety position selections.
 - b. Each Relay Output shall include a yellow status LED.
 - c. Optional version with manual override switch per output (Auto, 0, 1).
 6. Remote Floating Output Module (3 FO).
 - a. Three Floating Outputs with configurable safety position selections. 2 Relays per Floating Output.
 - b. Each Floating Output shall include a RED status LED (opening) and a GREEN status LED (closing).
 - c. Manual override potentiometer per output.
 7. Remote Mixed I/O Module (8 UI, 12 BI, 8 AO, 6 BO)
 - a. Eight Universal Inputs; 0/2-10V, 20K NTC, Binary Input (dry contact).
 - b. Twelve Binary Inputs; Dry contact or Totalizer (15Hz)
 - 1) Each Binary Input shall include a yellow status LED.
 - c. Eight Analog Outputs with configurable safety position selections. 10 Bit Analog Outputs; 0-10V, Binary Output (0V / 10V).
 - d. Six Relay Outputs.
 - 1) Each Relay Output shall include a yellow status LED.
- R. The PPCU shall be provided with an integrated Local Operator Interface where applicable.
1. Local Operator Interface shall allow for User-ID and password protected access.
 2. Local Operator Interface shall provide a backlit display, with automatic backlight time-out.
 - a. The display backlight shall automatically light upon press of a key or operation of the push & turn wheel. The display backlight will extinguish if operating keys or push & turn wheel is not used for two minutes.
 3. Local Operator Interface shall provide full display of long text information.
 - a. Automatic left and right scrolling shall ensure that text information longer than the display width can be viewed.
 4. Local Operator Interface shall provide configurable screens for viewing and adjusting data points and parameters, including the following operations.
 - a. Automatics and visual notification of all critical alarms.
 - b. Read and write access to all data points.
 - c. Full length names of data points, schedules, calendars, parameters, alarm texts, state texts and alarms.
 - d. Read and write access to all application parameters.
 - e. Read and write access to all schedules and calendars.
 - f. Read access to the onboard alarm buffer.
 - g. Overview of all data points in manual override.
 - h. Overview of all data points in alarm.
 5. Local Operator Interface shall allow user access to text information via a push & turn operation wheel.
 - a. Scrolling through a list of information shall be accomplished by turning the operation wheel.
 - b. Selecting and acknowledging information shall be accomplished by pushing the operation wheel.
 6. Changing information shall be accomplished by turning the operation wheel.

2.8 UNITARY IP CONTROL UNIT (UICU)

- A. HVAC UICU controllers shall be fully programmable to meet the unique requirements of the HVAC equipment it shall control. The controller platform shall provide options and advanced system functions, programmable and configurable using Niagara 4 Framework, that allow standard and customizable control solutions required in executing the "Sequence of Operation".

- B. All UICUs shall be application programmable and shall always maintain their certification. All control sequences within or programmed into the UICU shall be stored in non-volatile memory, which is not dependent upon the presence of a battery to be retained.
- C. The controllers shall be capable of daisy-chain IP communications with other UICU's and peer-to-peer communications with SNC's and with any OWS connected to the BAS, whether the OWS is directly connected, connected via cellular modem or connected via the Internet.
- D. The communication protocols utilized for peer-to-peer communications between UICU's will be Niagara 4 FoxS or BACnet TCP/IP. Use of a proprietary communication protocol for peer-to-peer communications between UICU's is not allowed.
- E. The UICU shall be licensed and enabled to support three (3) devices and shall be licensed with the following Open protocol drivers by default:
 - 1. BACnet IP and BACnet MSTP
 - 2. Modbus TCP and Modbus RTU
 - 3. SNMP
- F. The UICU shall be provided with Lifetime Software Maintenance license. Labor to implement not included.
- G. The UICU shall be capable of executing application control programs to provide:
 - 1. Calendar functions.
 - 2. Scheduling.
 - 3. Trending.
 - 4. Alarm monitoring and routing.
 - 5. Time synchronization.
 - 6. Integration of all daisy-chain UICU's.
 - 7. Network management functions for all daisy-chain UICU's.
- H. Programming software shall be embedded into the UICU. The UICU shall not require any external configuration tool or programming tool. All configuration and programming tasks shall be accomplished and accessible from within the embedded Niagara 4 environment.
- I. The UICU shall support the following security functions.
 - 1. Module code signing to verify the author of programming tool and confirm that the code has not been altered or corrupted.
 - 2. Role-Based Access Control (RBAC) for managing user roles and permissions.
 - 3. Require users to use strong credentials.
 - 4. Data in Motion and Sensitive Data at Rest be encrypted.
 - 5. Encrypted (PKI) Secure IP Stack Communication Security.
 - 6. FIPS 140-2 Level 1 Cryptographic Module Compliant.
- J. The minimum controller Environmental ratings.
 - 1. Operating Temperature Ambient Rating: -4 degrees to 140 degrees F (-20 degrees to 60 degrees C).
 - 2. Storage Temperature Ambient Rating: -40 degrees to 185 degrees F (-40 degrees to 85 degrees C).
 - 3. Relative Humidity: 5% to 95% non-condensing
- K. The controller shall have the additional approval requirements, listings, and approvals:
 - 1. Meets FCC Part 15, Class B (radiated emissions) requirements.
 - 2. C-UL
 - 3. CE
 - 4. UL916, Open Energy Management Class 2
 - 5. RoHS2
 - 6. REACH

7. WEEE
 8. CAN/CSA-C22.2 No. 205-12
 9. The controller housing shall be UL plenum rated mounting to either a panel or DIN rail (2.40" x 7.04" x 4.53"; 61mm x 179mm x 115mm).
- L. The UICU shall provide the following hardware features as a minimum:
1. The UICU shall provide LED indication of Power, Fault, Ethernet TX/RX/Traffic/Speed without cover removal.
 2. ARM Cortex-A9/M4 9, 800 MHz
 3. 512 MB DDR SDRAM
 4. 2 GB Flash Memory
 5. Powered from 24VAC/DC source
 6. Two 10/100 MB Ethernet ports capable of daisy chaining
 7. 1 RS-485 Serial Port
 8. Real Time Clock
 9. Secure Boot
 10. Ten [10] onboard IO points
 11. Supports up to 3 devices or 50 Points
- M. The UICU shall support standard Web browser access via the Intranet/Internet.
- N. The UICU shall be able to route any alarm condition to any defined user location whether connected to a local network or wide-area network.
1. Alarm generation shall be selectable for annunciation type and acknowledgement requirements including but not limited to:
 - a. Alarm.
 - b. Return to normal.
 - c. To default.
 2. Alarms shall be annunciated in any of the following manners as defined by the user:
 - a. Screen message text.
 - b. Email of complete alarm message to multiple recipients.
 - c. Pagers via paging services that initiate a page on receipt of email message.
 - d. Graphics with flashing alarm object(s).
 3. The following shall be recorded by the UICU for each alarm (at a minimum):
 - a. Time and date.
 - b. Equipment (air handler #, access way, etc.).
 - c. Acknowledge time, date, and user who issued acknowledgement.
- O. UICU Controllers shall support at minimum the following control techniques:
1. General-purpose control loops that can incorporate Demand Limit Control strategies, Set point reset, adaptive intelligent recovery, and time of day bypass.
 2. General-purpose, non-linear control loops.
 3. Start/stop Loops.
 4. If/Then/Else logic loops.
 5. Math Function loops (MIN, MAX, AVG, SUM, SUB, SQRT, MUL, DIV, ENTHALPY).
- P. The following five [5] Universal Inputs shall be supported per each UICU:
1. Type 3 10K Thermistor
 2. 0-100K ohm
 3. 0-10 VDC
 4. 0-20mA with external resistor
 5. Dry Contact
- Q. The following two [2] Analog Outputs shall be supported per each UICU:
1. 0-10VDC, 4mA max output current
- R. The following three [3] Digital Outputs shall be supported per each UICU:

1. Triac, 24VAC @ 0.5 amp
- S. The UICU shall employ a 50 Point Base License that supports one [1] IO-R-34 expansion module over a shielded RS-485 bus or three [3] devices via the embedded protocols.
- T. Each UICU shall have expansion ability to support additional I/O requirements through the use of a remote input/output module connected to an RS-485 local communication bus. Each UICU shall be able to support a maximum of one [1] 34 Point Expansion I/O Modules for a maximum of 44 physical I/O points.
1. 34 Point Mixed Expansion I/O Module shall communicate with UICU via a 2-wire RS-485m bus.
 2. Sixteen [16] Universal Inputs shall be supported via 34 Point Expansion I/O Module:
 - a. Type 3 10K Thermistor
 - b. 0-100K ohm
 - c. 0-10 VDC
 - d. 0-20mA with external resistor
 3. Eight [8] Analog Outputs shall be supported via 34 Point Expansion I/O Module:
 - a. 0-10.0 Vdc
 4. Ten [10] Digital Outputs (Relay) shall be supported via 34 Point Expansion I/O Module:
 - a. Form A Contacts, 24 VAC at 0.5 A rated
- U. The UICU shall not include an integrated Local Operator Interface.

2.9 ADVANCED UNITARY CONTROLLER (AUC)

- A. The advanced unitary controller (AUC) platform shall be designed specifically to control HVAC - ventilation, filtration, heating, cooling, humidification, and distribution. Equipment includes: constant volume air handlers, VAV air handlers, packaged RTU, heat pumps, unit vents, fan coils, natural convection units and radiant panels. The control shall use LonMark or BACnet based devices where the application has a LonMark profile or BTL Listed PICS defined. Where LonMark devices are not available for a particular application, devices based on LonWorks shall be acceptable. For each LonWorks device that does not have LonMark certification, the device supplier shall provide an XIF file for the device. The controller platform shall provide options and advanced system functions, programmable and configurable, using Niagara 4 Framework, that allow standard and customizable control solutions required in executing the "Sequence of Operation".
- B. Minimum Requirements:
1. The controller shall be fully programmable or configurable with full functionality on any Niagara 4 brand platform.
 - a. Support downloads to the controller in Niagara 4 platform.
 - b. Support uploads from the controller to Niagara 4 platform.
 - c. Support simulation/debug mode of the controller.
 - d. Maintain native GUI.
 - e. Native function-block programming software and all controller "Setup Wizards" shall be embedded within the Niagara 4 environment.
 2. The AUC shall be capable of either integrating with other devices or stand-alone operation.
 3. For VAV box applications, the AUC shall have an internal velocity pressure sensor.
 - a. Sensor Type: Microbridge air flow sensor with dual integral restrictors.
 - b. Operating Range: 0 to 1.5-inch H₂O (0 to 374 Pa).
 - c. Accuracy: +/- 2% of full scale at 32 degrees to 122 degrees F (0 degrees to 50 degrees C); +/- 1% of full scale at null pressure.
 4. The AUC shall have two microprocessors. The Host processor contains on-chip FLASH program memory, FLASH information memory, and RAM to run the main HVAC application. The second processor for network communications. Controller

memory minimum requirements include:

- a. FLASH Memory Capacity: 60 Kilobytes with 8 Kilobytes for application program.
 - b. FLASH Memory settings retained for ten years.
 - c. RAM: 2 Kilobytes.
5. The AUC shall have an internal time clock with the ability to automatically revert from a master time clock on failure.
- a. Operating Range: 24-hour, 365 day, multi-year calendar including day of week and configuration for automatic day-light savings time adjustment to occur on configured start and stop dates.
 - b. Accuracy: +/- 1 minute per month at 77 degrees F (25 degrees C).
 - c. Power Failure Backup: 24 hours at 32 degrees to 122 degrees F (0 degrees to 50 degrees C).
6. The AUC shall have Significant Event Notification, Periodic Update capability, and Failure Detect when network inputs fail to be detected within their configurable time frame.
7. The AUC shall have an internal DC power supply to power external sensors.
- a. Power Output: 20 VDC +/- 10% at 75 mA.
8. The AUC shall have a visual indication (LED) of the status of the device:
- a. Controller operating normally.
 - b. Controller in process of download.
 - c. Controller in manual mode under control of software tool.
 - d. Controller lost its configuration.
 - e. No power to controller, low voltage, or controller damage.
 - f. Processor and/or controller are not operating.
9. The minimum AUC Environmental ratings.
- a. Operating Temperature Ambient Rating: -40 degrees to 150 degrees F (-40 degrees to 65.5 degrees C) for an AUC in unconditioned space.
 - b. Storage Temperature Ambient Rating: -40 degrees to 150 degrees F (-40 degrees to 65.5 degrees C) for an AUC in unconditioned space.
 - c. Operating Temperature Ambient Rating: 32 degrees to 122 degrees F (0 degrees to 50 degrees C) for an AUC in conditioned space.
 - d. Storage Temperature Ambient Rating: 32 degrees to 122 degrees F (0 degrees to 50 degrees C) for an AUC in conditioned space.
 - e. Relative Humidity: 5% to 95% non-condensing.
10. The AUC shall have the additional approval requirements, listings, and approvals:
- a. UL/cUL (E87741) listed under UL916 (Standard for Open Energy Management Equipment) with plenum rating.
 - b. CSA (LR95329-3) Listed.
 - c. Meets FCC Part 15, Subpart B, Class B (radiated emissions) requirements.
 - d. Meets Canadian standard C108.8 (radiated emissions).
 - e. Conforms requirements European Consortium standard EN 61000-6-1; 2001 (EU Immunity).
 - f. Conforms requirements European Consortium standard EN 61000-6-3; 2001 (EU Emission).
11. The AUC housing shall be UL plenum rated mounting to either a panel or DIN rail (standard EN50022; 7.5mm x 35mm).
12. For VAV box applications, the AUC shall provide an integrated actuator option.
- a. Actuator type: Series Floating.
 - b. Rotation stroke: 95 degrees +/- 177;3 degrees for CW or CCW opening dampers.
 - c. Torque rating: 44 lb-inch (5 Nm).
 - d. Run time for 90-degree rotation: 90 seconds at 60 Hz.
13. The AUC shall have a mix of Universal Inputs (UI), Digital Inputs (DI), Analog Outputs (AO), and Digital Triac Outputs (DO), as well as a 2-wire, polarity insensitive, AUC communication bus providing Sensor, Actuator, and I/O expandability.

- a. Analog outputs (AO) shall be capable of being configured as digital outputs (DO).
 - b. Input and Output wiring terminal strips shall be removable from the controller without disconnecting wiring.
 - c. Input and Output wiring terminals shall be designated with color coded labels.
 - d. Universal inputs shall be capable of being configured as binary inputs, resistive inputs, voltage inputs (0-10 VDC), or current inputs (4-20 mA).
14. The AUC shall provide "continuous" automated loop tuning with an Adaptive Integral Algorithm Control Loop.
15. The AUC platform shall have standard HVAC application programs that are modifiable to support both the traditional and specialized "sequence of operations" as outlined in Section 4.
- a. Discharge air control and low limit.
 - b. Pressure-dependent dual duct without flow mixing.
 - c. Variable air volume with return flow tracking.
 - d. Economizer with differential enthalpy.
 - e. Minimum airflow coordinated with CO2.
 - f. Unit ventilator cycle (1, 2, 3) 2-pipe.
 - g. Unit ventilator cycle (1, 2, 3) 2-pipe with face/bypass.
 - h. Unit ventilator cycle (1, 2, 3) 4-pipe.
 - i. Unit ventilator cycle (1, 2, 3) 4-pipe with EOC valve.
 - j. VAV terminal unit.
 - k. VAV terminal unit fan speed control.
 - l. Series fan.
 - m. Parallel fan.
 - n. Regulated air volume (room pressurization/de-pressurization).
 - o. CV dual-duct.
 - p. Room CO2 control.
 - q. Room Humidity.
 - r. TOD occupancy sensor stand-by set points.

2.10 BACNET TOUCHSCREEN COMMUNICATING THERMOSTAT (BCT)

- A. BACnet Conformance
- 1. Touchscreen communicating thermostats shall be approved by the BTL as meeting the BACnet Application Specific Controller requirements.
 - 2. Touchscreen Communicating Thermostats shall, at a minimum, support MS/TP BACnet LAN types. They shall communicate directly through this BACnet LAN at 9.6, 19.2, 38.4 and 76.8 Kbps, as a native BACnet device.
 - 3. Standard BACnet object types supported shall include, as a minimum, Analog Input, Analog Output, Analog Value, Binary Input, Binary Output, Binary Value, Device, File, and Program Object Types.
 - 4. All proprietary object types, if used in the system, shall be thoroughly documented and provided as part of the submittal data. All necessary tools shall be supplied for working with proprietary information.
- B. BCT hardware shall:
- 1. Include a 32-Bit processor
 - 2. Include a backlit touchscreen for the user interface, buttons are not allowed.
 - 3. Include Three (3) universal inputs with 12-bit resolution that can accept 3K and 10K Type II thermistors, 0-10VDC, 0- 5 VDC, 4-20mA, and dry contact signals. Inputs on controller may be either analog or digital.
 - 4. Include built-in temperature sensor.
 - 5. Include built-in humidity sensor.
 - 6. Include Six (6) relay outputs on board.
 - 7. Include Two (2) analog outputs with 12-bit resolution. Each auto-detecting for 0-10 V

- or 4-20 mA control signals.
 - 8. Meet the requirements of Listed Underwriters Laboratory for Open Energy Management Equipment (PAZX) under the UL Standard for Safety 916.
 - 9. Meet the requirements of EMC Directive (European CE Mark) EN 60950.
 - 10. Meet the requirements for FCC Part 15, Class B.
 - 11. Be powered by 24VAC power.
- C. Wireless sensors shall be supported by the BCT when required in writing on the drawings.
- 1. Support up to eight (8) magnetic contact switches with CR2032-battery powered wireless transmitter.
 - 2. Support up to three (3) passive infrared (PIR) motion detectors with 140-degree detection angle and AAA battery-powered wireless transmitter.
 - 3. Meet the requirements for FCC Part 15, Class B.
 - 4. Individual wireless sensor inputs can be used by fully programmable DDC to create custom sequence of operations in controller.
 - 5. Sensors operate in the 433.92 MHz wireless frequency with 50-foot range

2.11 OTHER CONTROL SYSTEM HARDWARE

- A. Motorized control dampers that will not be integral to the equipment shall be furnished by the Control System Contractor. Control damper frames shall be constructed of galvanized steel, formed into channels and welded or riveted. Dampers shall be galvanized, with nylon bearings. Blade edge seals shall be vinyl. Blade edge and tip seals shall be included for all dampers. Blades shall be 16-gauge minimum and 6 inches wide maximum and frame shall be of welded channel iron. Damper leakage shall not exceed 10 CFM per square foot, at 1.5 inches water gauge static pressure. Honeywell is basis of design.
- B. Control damper actuators shall be furnished by the Control System Contractor. Two-position or proportional electric actuators shall be direct-mount type sized to provide a minimum of 5 in-lb torque per square foot of damper area. Damper actuators shall be spring return type in all applications requiring it. Operators shall be heavy-duty electronic type for positioning automatic dampers in response to a control signal. Motor shall be of sufficient size to operate damper positively and smoothly to obtain correct sequence as indicated. All applications requiring proportional operation shall utilize truly proportional electric actuators. Honeywell is basis of design.
- C. Control Valves: Control valves shall be 2-way, or 3-way pattern as shown and constructed for tight shutoff at the pump shut-off head or steam relief valve pressure. Control valves shall operate satisfactorily against system pressures and differentials. Two-position valves shall be 'line' size. Proportional control valves shall be sized for a maximum pressure drop of 5.0 psi at rated flow (unless otherwise noted or scheduled on the drawings). Valves with sizes up to and including 2 inches (51 mm) shall be "screwed" configuration and 2-1/2 inches (63.5 mm) and larger valves shall be "flanged" configuration. All control valves, including terminal unit valves, less than 2 inches (51 mm) shall be globe or characterized ball valves, globe valves are to be used where valve delta pressure exceeds 7 PSI in a modulating application. Electrically actuated control valves shall include spring return type actuators in applications requiring it, sized for tight shut-off against system pressures (as specified above) and, when specified, shall be furnished with integral switches for indication of valve position (open-closed). Pneumatic actuators for valves, when utilized, shall be sized for tight shut-off against system pressures (as specified above). Honeywell is basis of design.
- D. Control Valve Actuators: Actuators for VAV terminal unit heating coils shall be "drive-open; drive-closed" type. All actuators shall have inherent current limiting motor protection. Valve actuators shall be 24-volt, electronic type, modulating or two-position as required for the correct operating sequence. Actuators on valves needing 'fail-safe' operation shall have spring return to Normal position. Modulating valves shall be positive positioning in response to the signal. All valve actuators shall be UL listed. Honeywell is basis of design.

- E. All control valves 2-1/2 inches (63.5 mm) or larger shall have position indication capability. All hot water control valves shall be Normally Open arrangement; all chilled water control valves shall be Normally-Closed arrangement unless an open position is required for freeze protection purposes / strategies. Honeywell is basis of design.
- F. Wall Mount Room Temperature sensors: Each room temperature sensor shall provide temperature indication to the digital controller, provide the capability for a software-limited occupant set point adjustment (warmer-cooler slider bar or switch) and limited operation override capability. Room Temperature Sensors shall be 20,000-ohm thermistor type with a temperature range of -40 to 140 degrees F (-38 to 60 degrees C). The sensor shall be complete with a decorative cover and suitable for mounting over a standard electrical utility box. These devices shall have an accuracy of 0.5 degrees F (.024 degrees C) over the entire range. Honeywell is basis of design.
- G. Duct-mounted and Outside Air Temperature Sensors: 20,000-ohm thermistor temperature sensors with an accuracy of 0.2 degrees C. Outside air sensors shall include an integral sun shield. Duct-mounted sensors shall have an insertion measuring probe of a length appropriate for the duct size, with a temperature range of -40 to 160 degrees F (-38 to 71 degrees C) The sensor shall include a utility box and a gasket to prevent air leakage and vibration noise. For all mixed air and preheat air applications, install bendable averaging duct sensors with a minimum 8 feet (2438 mm) long sensor element. These devices shall have accuracy of 0.5 degrees F (.024 degrees C) over the entire range. Honeywell is basis of design.
- H. Humidity sensors shall be thin-film capacitive type sensor with on-board nonvolatile memory, accuracy to plus or minus two percent (3%) at 20 to 90% RH, 12 - 30 VDC input voltage, analog output (0 - 10 VDC or 4 - 20mA output). Operating range shall be 0 to 100% RH and 32 to 122 degrees F (0 to 60 degrees C) wall mounted, and -10 to 140 degrees F (-23 to 60 degrees C) duct and outdoor mounted. Sensors shall be selected for wall, duct or outdoor type installation as appropriate. Honeywell is basis of design.
- I. Carbon Dioxide Sensors (CO2): Sensors shall utilize Non-dispersive infrared technology (N.D.I.R.), repeatable to plus or minus 20 PPM. Sensor range shall be 0 - 2000 PPM. Accuracy shall be plus or minus five percent (5%) or 75 PPM, whichever is greater. Response shall be less than one minute. Input voltage shall be 20 to 30 VAC or DC. Output shall be 0 - 10 VDC. Sensor shall be wall or duct mounted type, as appropriate for the application, housed in a high impact plastic enclosure. Honeywell is basis of design.
- J. Current Sensitive Switches: Solid state, split core current switch that operates when the current level (sensed by the internal current transformer) exceeds the adjustable trip point. Current switch to include an integral LED for indication of trip condition and a current level below trip set point.
- K. Differential Analog (duct) Static Pressure Transmitters Provide a pressure transmitter with integral capacitance type sensing and solid-state circuitry. Accuracy shall be plus or minus 1% of full range; range shall be selected for the specific application. Provide zero and span adjustment capability. Device shall have integral static pickup tube. Honeywell is basis of design.
- L. Differential Air Pressure Switches: Provide SPDT type, UL-approved, and selected for the appropriate operating range where applied. Switches shall have adjustable set points and barbed pressure tips. Honeywell is basis of design.
- M. Water Flow Switches: Provide a SPST type contact switch with bronze paddle blade, sized for the actual pipe size at the location. If installed outdoors, provide a NEMA-4 enclosure. Flow switch shall be UL listed.

- N. Temperature Control Panels: Furnish temperature control panels of code gauge steel with locking doors and removable backplates, for mounting all devices as shown. complete set of 'as-built' control drawings (relating to the controls within that panel) shall be furnished within each control panel.
- O. Pipe and Duct Temperature sensing elements: 20,000-ohm thermistor temperature sensors with and accuracy of: 1% Their range shall be -40 to 250 degrees F (-40 to 121 degrees C). Limited range sensors shall be acceptable provided they are capable of sensing the range expected for the point at the specified accuracy. Thermal wells with heat conductive gel shall be included. Honeywell is basis of design.
- P. Low Air Temperature Sensors: Provide SPST type switch, with 15 to 55 degrees F (-9 to 13 degrees C), range, vapor-charged temperature sensor. Honeywell model L482A, or approved equivalent.
- Q. Variable Frequency Drives: The variable frequency drive (VFD) shall be designed specifically for use in Heating, Ventilation, and Air Conditioning (HVAC) applications in which speed control of the motor can be applied. The VFD, including all factory installed options, shall have UL & CSA approval. VFD's shall include communications capability with DDC BMS via built-in interface card (MODBUS or BACnet). Honeywell SmartVFD is basis of design.
- R. Relays: Start/stop relay model shall provide either momentary or maintained switching action as appropriate for the motor being started. Relays shall have an indicating lamp. Relays installed outside of controlled devices shall be enclosed in a NEMA enclosure suitable for the location. Relays shall be labeled with UL symbol. RIB-style relays are acceptable for remote enable/disable.
- S. Emergency Stop Switches: Provide push button to disable, pull to reset type switch. Switch shall be labeled as to the appropriate function for the application.
- T. Transducers: Differential pressure transducers shall be electronic with a 4-20 mA output signal compatible to the Direct Digital Controller. Wetted parts shall be stainless steel. Unit shall be designed to operate in the pressure ranges involved.
- U. Control Power Transformers: Provide step-down transformers for all DDC controllers and devices as required. Transformers shall be sized for the load, but shall be sized for 50 watts, minimum. Transformers shall be UL listed Class 2 type, for 120 VAC/24 VAC operation.

2.12 BAS SERVER & WEB BROWSER GUI - SYSTEM OVERVIEW

- A. The BAS Contractor shall provide system software based on server/thin-client architecture, designed around the open standards of web technology. The BAS server shall communicate using Ethernet and TCP. Server shall be accessed using a web browser over Owner intranet and remotely over the Internet.
- B. The intent of the thin-client architecture is to provide the operator(s) complete access to the BAS system via a web browser. The thin-client web browser Graphical User Interface (GUI) shall be browser and operating system agnostic, meaning it will support HTML5 enabled browsers without requiring proprietary operator interface and configuration programs or browser plug-ins. Microsoft, Firefox, and Chrome browsers (current released versions), and Windows as well as non-Window operating systems.
- C. The BAS server software shall support at least the following server platforms (Windows 7, 8.1, Server 12). The BAS server software shall be developed and tested by the manufacturer of the system stand-alone controllers and network controllers/routers.

- D. The web browser GUI shall provide a completely interactive user interface and shall provide a HTML5 experience that supports the following features as a minimum:
1. Trending.
 2. Scheduling.
 3. Electrical demand limiting.
 4. Duty Cycling.
 5. Downloading Memory to field devices.
 6. Real time 'live' Graphic Programs.
 7. Tree Navigation.
 8. Parameter change of properties.
 9. Set point adjustments.
 10. Alarm / event information.
 11. Configuration of operators.
 12. Execution of global commands.
 13. Add, delete, and modify graphics and displayed data.
- E. Software Components: All software shall be the most current version. All software components of the BAS system software shall be provided and installed as part of this project. BAS software components shall include:
1. Server Software, Database and Web Browser Graphical User Interface.
 2. 5 Year Software Maintenance license. Labor to implement not included.
 3. Embedded System Configuration Utilities for future modifications to the system and controllers.
 4. Embedded Graphical Programming Tools.
 5. Embedded Direct Digital Control software.
 6. Embedded Application Software.
- F. BAS Server Database: The BAS server software shall utilize a Java Database Connectivity (JDBC) compatible database such as: MS SQL 8.0, Oracle 8i or IBM DB2. BAS systems written to Non -Standard and/or Proprietary databases are NOT acceptable.
- G. Thin Client - Web Browser Based: The GUI shall be thin client or browser based and shall meet the following criteria:
1. Web Browser's for PC's: Only the current released browser (Explorer/Firefox/Chrome) will be required as the GUI and a valid connection to the server network. No installation of any custom software shall be required on the operator's GUI workstation/client. Connection shall be over an intranet or the Internet.
 2. Secure Socket Layers: Communication between the Web Browser GUI and BAS server shall offer encryption using 128-bit encryption technology within Secure Socket Layers (SSL). Communication protocol shall be Hyper-Text Transfer Protocol (HTTP).

2.13 WEB BROWSER GRAPHICAL USER INTERFACE

- A. Web Browser Navigation: The Thin Client web browser GUI shall provide a comprehensive user interface. Using a collection of web pages, it shall be constructed to "feel" like a single application, and provide a complete and intuitive mouse/menu driven operator interface. It shall be possible to navigate through the system using a web browser to accomplish requirements of this specification. The Web Browser GUI shall (as a minimum) provide for navigation, and for display of animated graphics, schedules, alarms/events, live graphic programs, active graphic set point controls, configuration menus for operator access, reports and reporting actions for events.
- B. Login: On launching the web browser and selecting the appropriate domain name or IP address, the operator shall be presented with a login page that will require a login name and strong password. Navigation in the system shall be dependent on the operator's role-based application control privileges.

- C. Navigation: Navigation through the GUI shall be accomplished by clicking on the appropriate level of a navigation tree (consisting of an expandable and collapsible tree control like Microsoft's Explorer program) and/or by selecting dynamic links to other system graphics. Both the navigation tree and action pane shall be displayed simultaneously, enabling the operator to select a specific system or equipment and view the corresponding graphic. A navigation tree shall as a minimum provide the following views: Geographic, Network, Groups and Configuration.
1. Geographic View shall display a logical geographic hierarchy of the system including: cities, sites, buildings, building systems, floors, equipment and objects.
 2. Groups View shall display Scheduled Groups and custom reports.
 3. Configuration View shall display all the configuration categories (Operators, Schedule, Event, Reporting and Roles).
- D. Action Pane: The Action Pane shall provide several functional views for each subsystem specified. A functional view shall be accessed by clicking on the corresponding button:
1. Graphics: Using graphical format suitable for display in a web browser, graphics shall include aerial building/campus views, color building 3D floorplans, equipment drawings, active graphic set point controls, web content and other valid HTML elements. The data on each graphic page shall automatically refresh.
 2. Dashboards: User customizable data using drag and drop HTML5 elements. Shall include Web Charts, Gauges, and other custom developed widgets for web browser. User shall have ability to save custom dashboards.
 3. Search: User shall have multiple options for searching data based upon Tags. Associated equipment, real time data, Properties, and Trends shall be available in result.
 4. Properties: Shall include graphic controls and text for the following: Locking or overriding objects, demand strategies, and any other valid data required for setup. Changes made to the properties pages shall require the operator to depress an 'accept/cancel' button.
 5. Schedules: Shall be used to create, modify/edit and view schedules based on the systems hierarchy (using the navigation tree).
 6. Alarms: Shall be used to view alarm information geographically (using the navigation tree), acknowledge alarms, sort alarms by category, actions and verify reporting actions.
 7. Charting: Shall be used to display associated trend and historical data, modify colors, date range, axis and scaling. User shall have ability to create HTML charts through web browser without utilizing chart builder. User shall be able to drag and drop single or multiple data points, including schedules, and apply status colors for analysis.
 8. Logic - Live Graphic Programs: Shall be used to display 'live' graphic programs of the control algorithm, (micro block programming) for the mechanical/electrical system selected in the navigation tree.
 9. Other actions such as Print, Help, Command, and Logout shall be available via a drop-down window.
- E. Color Graphics: The Web Browser GUI shall make extensive use of color in the graphic pane to communicate information related to set points and comfort. Animated gifs or .jpg, vector scalable, active set point graphic controls shall be used to enhance usability. Graphics tools used to create Web Browser graphics shall be non-proprietary and conform to the following basic criteria:
1. Display Size: The GUI workstation software shall graphically display in a minimum of 1024 by 768 pixels 24-bit True Color.
 2. General Graphic: General area maps shall show locations of controlled buildings in relation to local landmarks.
 3. 3D Floor Plans in 2D format: Floor plan graphics shall show heating and cooling zones throughout the buildings with areas served by a device (zones) being highlighted by mouseover. Provide a visual display of temperature relative to their

- respective set points. The colors shall be updated dynamically as a zone's actual comfort condition changes.
4. Mechanical Components: Mechanical system graphics shall show the type of mechanical system components serving any zone through the use of a pictorial representation of components. Selected I/O points being controlled or monitored for each piece of equipment shall be displayed with the appropriate engineering units. Animation shall be used for rotation or moving mechanical components to enhance usability.
 5. Minimum System Color Graphics: Color graphics shall be selected and displayed via a web browser for the following:
 - a. Each piece of equipment monitored or controlled including each terminal unit.
 - b. Each building.
 - c. Each floor and zone controlled.
- F. Hierarchical Schedules: Utilizing the Navigation Tree and/or a custom graphical interface displayed in the web browser GUI, an operator (with proper access credentials) shall be able to define a Normal, Holiday or Override schedule for an individual piece of equipment or room, or choose to apply a hierarchical schedule to the entire system, site or floor area. For example, Independence Day ' Holiday' for every level in the system would be created by clicking at the top of the geographic hierarchy defined in the Navigation Tree. No further operator intervention would be required and every control module in the system would be automatically downloaded with the ' Independence Day' Holiday. All schedules that affect the system/area/equipment highlighted in the Navigation Tree shall be shown in a summary schedule table and graph.
1. Schedules: Schedules shall comply with the LonWorks and BACnet standards, (Schedule Object, Calendar Object, Weekly Schedule property and Exception Schedule property) and shall allow events to be scheduled based on:
 - a. Types of schedule shall be Normal, Holiday or Override.
 - b. A specific date.
 - c. A range of dates.
 - d. Any combination of Month of Year (1-12, any), Week of Month (1-5, last, any), Day of Week (M-Sun, Any).
 - e. Wildcard (example, allow combinations like second Tuesday of every month).
 2. Schedule Categories: The system shall allow operators to define and edit scheduling categories (different types of "things" to be scheduled; for example, lighting, HVAC occupancy, etc.). The categories shall include: name, description, icon (to display in the hierarchy tree when icon option is selected) and type of value to be scheduled.
 3. Schedule Groups: In addition to hierarchical scheduling, operators shall be able to define functional Schedule Groups, comprised of an arbitrary group of areas/rooms/equipment scattered throughout the facility and site. For example, the operator shall be able to define an ' individual tenant' group - who may occupy different areas within a building or buildings. Schedules applied to the ' tenant group' shall automatically be downloaded to control modules affecting spaces occupied by the ' tenant group'.
 4. Intelligent Scheduling: The control system shall be intelligent enough to automatically turn on any supporting equipment needed to control the environment in an occupied space. If the operator schedules an individual room in a VAV system for occupancy, for example, the control logic shall automatically turn on the VAV air handling unit, chiller, boiler and/or any other equipment required to maintain the specified comfort and environmental conditions within the room.
 5. Partial Day Exceptions: Schedule events shall be able to accommodate a time range specified by the operator (ex: board meeting from 6 pm to 9 pm overrides Normal schedule for conference room).
 6. Schedule Summary Graph: The schedule summary graph shall clearly show Normal versus Holiday versus Override Schedules and the net operating schedule that results from all contributing schedules. Note: In case of priority conflict between schedules at

the different geographic hierarchy, the schedule for the more detailed geographic level shall apply.

- G. Alarms: Alarms associated with a specific system, area, or equipment selected in the Navigation Tree, shall be displayed in the Action Pane by selecting an ' Alarms' view. Alarms, and reporting actions shall have the following capabilities:
1. Alarms View: Each Alarm shall display an Alarms Category (using a different icon for each alarm category), date/time of occurrence, current status, alarm report and a bold URL link to the associated graphic for the selected system, area or equipment. The URL link shall indicate the system location, address and other pertinent information. An operator shall easily be able to sort events, edit event templates and categories, acknowledge or force a return to normal in the Events View as specified in this section.
 2. Alarm Categories: The operator shall be able to create, edit or delete alarm categories such as HVAC, Maintenance, Fire, or Generator. An icon shall be associated with each alarm category, enabling the operator to easily sort through multiple events displayed.
 3. Alarm Templates: Alarm template shall define different types of alarms and their associated properties. As a minimum, properties shall include a reference name, verbose description, severity of alarm, acknowledgement requirements, and high/low limit and out of range information.
 4. Alarm Areas: Alarm Areas enable an operator to assign specific Alarm Categories to specific Alarm Reporting Actions. For example, it shall be possible for an operator to assign all HVAC Maintenance Alarm on the 1st floor of a building to email the technician responsible for maintenance. The Navigation Tree shall be used to setup Alarm Areas in the Graphic Pane.
 5. Alarm Time/Date Stamp: All events shall be generated at the DDC control module level and comprise the Time/Date Stamp using the standalone control module time and date.
 6. Alarm Configuration: Operators shall be able to define the type of Alarm generated per object. A ' network' view of the Navigation Tree shall expose all objects and their respective Alarm Configuration. Configuration shall include assignment of Alarm, type of Acknowledgement and notification for return to normal or fault status.
 7. Alarm Summary Counter: The view of Alarm in the Graphic Pane shall provide a numeric counter, indicating how many Alarms are active (in alarm), require acknowledgement and total number of Alarms in the BAS Server database.
 8. Alarm Auto-Deletion: Alarms that are acknowledged and closed shall be auto-deleted from the database and archived to a text file after an operator defined period.
 9. Alarm Reporting Actions: Alarm Reporting Actions specified shall be automatically launched (under certain conditions) after an Alarm is received by the BAS server software. Operators shall be able to easily define these Reporting Actions using the Navigation Tree and Graphic Pane through the web browser GUI. Reporting Actions shall be as follows:
 - a. Print: Alarm information shall be printed to the BAS server's PC or a networked printer.
 - b. Email: Email shall be sent via any POP3-compatible e-mail server (most Internet Service Providers use POP3). Email messages may be copied to several email accounts. Note: Email reporting action shall also be used to support alphanumeric paging services, where email servers support pagers.
 - c. File Write: The ASCII File write reporting action shall enable the operator to append operator defined alarm information to any alarm through a text file. The alarm information that is written to the file shall be completely definable by the operator. The operator may enter text or attach other data point information (such as AHU discharge temperature and fan condition upon a high room temperature alarm).
 - d. Write Property: The write property reporting action updates a property value in

- a hardware module.
 - e. SNMP: The Simple Network Management Protocol (SNMP) reporting action sends an SNMP trap to a network in response to receiving an alarm.
 - f. Run External Program: The Run External Program reporting action launches specified program in response to an event.

- H. Trends: As system is engineered, all points shall be enabled to trend. Trends shall both be displayed and user configurable through the Web Browser GUI. Trends shall comprise analog, digital or calculated points simultaneously. A trend log's properties shall be editable using the Navigation Tree and Graphic Pane.
 1. Viewing Trends: The operator shall have the ability to view trends by using the Navigation Tree and/or a custom graphical interface and selecting a Trends button in the Graphic Pane. The system shall allow y- and x-axis maximum ranges to be specified and shall be able to simultaneously graphically display multiple trends per graph.
 2. Local Trends: Trend data shall be collected locally by Multi-Equipment/Single Equipment general-purpose controllers, and where installed periodically uploaded to the BAS server if historical trending is enabled for the object. Trend data, including run time hours and start time date shall be retained in non-volatile module memory. Systems that rely on a gateway/router to run trends are NOT acceptable.
 3. Resolution. Sample intervals shall be as small as one second. Each trended point will have the ability to be trended at a different trend interval. When multiple points are selected for displays that have different trend intervals, the system will automatically scale the axis.
 4. Dynamic Update. Trends shall be able to dynamically update at operator-defined intervals.
 5. Zoom/Pan. It shall be possible to zoom-in on a particular section of a trend for more detailed examination and 'pan through' historical data by simply scrolling the mouse.
 6. Numeric Value Display. It shall be possible to pick any sample on a trend and have the numerical value displayed.
 7. Copy/Paste. The operator shall have the ability to pan through a historical trend and copy the data viewed to the clipboard using standard keystrokes (i.e. CTRL+C, CTRL+V).

- I. Security Access: Systems that are accessed from the web browser GUI to BAS server shall require a Login Name and Strong Password. Access to different areas of the BAS system shall be defined in terms of Role-Based Access Control privileges as specified:
 1. Roles: Roles shall reflect the actual roles of different types of operators. Each role shall comprise a set of 'easily understood English language' privileges. Roles shall be defined in terms of View, Edit and Function Privileges.
 - a. View Privileges shall comprise: Navigation, Network, and Configuration Trees, Operators, Roles and Privileges, Alarm/Event Template and Reporting Action.
 - b. Edit Privileges shall comprise: Set point, Tuning and Logic, Manual Override, and Point Assignment Parameters.
 - c. Function Privileges shall comprise: Alarm/Event Acknowledgement, Control Module Memory Download, Upload, Schedules, Schedule Groups, Manual Commands, Print and Alarm/Event Maintenance.
 2. Geographic Assignment of Roles: Roles shall be geographically assigned using a similar expandable/collapsible navigation tree. For example, it shall be possible to assign two HVAC Technicians with similar competencies (and the same operator defined HVAC Role) to different areas of the system.

2.14 GRAPHICAL PROGRAMMING

- A. The system software shall include a Graphic Programming Language (GPL) for all DDC control algorithms resident in all control modules. Any system that does not use a drag and

drop method of graphical icon programming shall not be accepted. All systems shall use a GPL method used to create a sequence of operations by assembling graphic microblocks that represent each of the commands or functions necessary to complete a control sequence. Microblocks represent common logical control devices used in conventional control systems, such as relays, switches, high signal selectors etc., in addition to the more complex DDC and energy management strategies such as PID loops and optimum start. Each microblock shall be interactive and contain the programming necessary to execute the function of the device it represents.

- B. Graphic programming shall be performed while on screen and using a mouse; each microblock shall be selected from a microblock library and assembled with other microblocks necessary to complete the specified sequence. Microblocks are then interconnected on screen using graphic "wires," each forming a logical connection. Once assembled, each logical grouping of microblocks and their interconnecting wires then forms a graphic function block which may be used to control any piece of equipment with a similar point configuration and sequence of operation.
- C. Graphic Sequence: The clarity of the graphic sequence shall be such that the operator has the ability to verify that system programming meets the specifications, without having to learn or interpret a manufacturer's unique programming language. The graphic programming shall be self-documenting and provide the operator with an understandable and exact representation of each sequence of operation.
- D. GPL Capabilities: The following is a minimum definition of the capabilities of the Graphic Programming software:
 - 1. Function Block (FB): Shall be a collection of points, microblocks and wires which have been connected together for the specific purpose of controlling a piece of HVAC equipment or a single mechanical system.
 - 2. Logical I/O: Input/Output points shall interface with the control modules in order to read various signals and/or values or to transmit signal or values to controlled devices.
 - 3. Microblocks: Shall be software devices that are represented graphically and may be connected together to perform a specified sequence. A library of microblocks shall be submitted with the control contractors bid.
 - 4. Wires: Shall be Graphical elements used to form logical connections between microblocks and between logical I/O.
 - 5. Reference Labels: Labels shall be similar to wires in that they are used to form logical connections between two points. Labels shall form a connection by reference instead of a visual connection, i.e. two points labeled 'A' on a drawing are logically connected even though there is no wire between them.
 - 6. Parameter: A parameter shall be a value that may be tied to the input of a microblock.
 - 7. Properties: Dialog boxes shall appear after a microblock has been inserted which has editable parameters associated with it. Default parameter dialog boxes shall contain various editable and non-editable fields and shall contain 'push buttons' for the purpose of selecting default parameter settings.
 - 8. Icon: An icon shall be graphic representation of a software program. Each graphic microblock has an icon associated with it that graphically describes its function.
 - 9. Menu-bar Icon: Shall be an icon that is displayed on the menu bar on the GPL screen, which represents its associated graphic microblock.
 - 10. Live Graphical Programs: The Graphic Programming software shall support a 'live' mode, where all input/output data, calculated data and set points shall be displayed in a 'live' real-time mode.

2.15 LONWORKS NETWORK MANAGEMENT

- A. Systems requiring the use of third-party LonWorks network management tools shall not be accepted.
- B. Network management shall include the following services: device identification, device installation, device configuration, device diagnostics, device maintenance and network variable binding.
- C. The Network configuration tool shall also provide diagnostics to identify devices on the network, to reset devices and to view health and status counters within devices.
- D. These tools shall provide the ability to "learn" an existing LonWorks network, regardless of what network management tool(s) were used to install the existing network, so that existing LonWorks devices and newly added devices are part of a single network management database.
- E. The network management database shall be resident in the Network Area Controller (NAC), ensuring that anyone with proper authorization always has access to the network management database. Systems employing network management databases that are not resident, at all times and within the control system shall not be accepted.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 GENERAL

- A. Install system and materials in accordance with manufacturer's instructions, and as detailed on the project drawing set.
- B. Line and low voltage electrical connections to control equipment shown specified or shown on the control diagrams shall be furnished and installed by the Control System Contractor in accordance with these specifications.
- C. Equipment furnished by the Mechanical Contractor that is normally wired before installation shall be furnished completely wired. Control wiring normally performed in the field will be furnished and installed by the Control System Contractor.
- D. All control devices mounted on the face of control panels shall be clearly identified as to function and system served with permanently engraved phenolic labels.

3.4 WIRING

- A. All electrical control wiring to the control panels shall be the responsibility of the Control System Contractor.
- B. All wiring shall be in accordance with the Project Electrical Specifications the National

Electrical Code and any applicable local codes. All control wiring shall be installed in raceways.

- C. Excess wire shall not be looped or coiled in the controller cabinet.
- D. Incorporate electrical noise suppression techniques in relay control circuits where required.
- E. There shall be no drilling on the controller cabinet after the controls are mounted inside.
- F. Careful stripping of wire while inside the cabinet is required to ensure that no wire strand fragments land on circuit boards.
- G. Use manufacturer-specified wire for all network connections.
- H. Use approved optical isolation and lightning protection when penetrating building envelope.
- I. Read installation instructions carefully. Any unavoidable deviations shall be approved by owner's rep prior to installation.

3.5 ACCEPTANCE TESTING

- A. Upon completion of the installation, the Control System Contractor shall load all system software and start-up the system. The Control System Contractor shall perform all necessary calibration, testing and de-bugging and perform all required operational checks to ensure that the system is functioning in full accordance with these specifications.
- B. The Control System Contractor shall perform tests to verify proper performance of components, routines and points. Repeat tests until proper performance results.
- C. System Acceptance: Satisfactory completion is when the Control System Contractor has performed successfully all the required testing to show performance compliance with the requirements of the Contract Documents to the satisfaction of the Owner's Representative. System acceptance shall be contingent upon completion and review of all corrected deficiencies.

3.6 OPERATOR TRAINING

- A. During system commissioning and at such time acceptable performance of the Control System hardware and software has been established, the Control System Contractor shall provide on-site operator instruction to the owner's operating personnel. Operator instruction shall be done during normal working hours and shall be performed by a competent representative familiar with the system hardware, software and accessories.
- B. The Control System Contractor shall provide up to 8 total hours of comprehensive training in two sessions if required for system orientation, product maintenance and troubleshooting, programming and engineering. Additionally, the Control System Contractor shall provide up to 8 total hours of additional training or system assistance if requested by the owner within the warranty period.

3.7 WARRANTY PERIOD SERVICES

- A. Equipment, materials and workmanship incorporated into the work shall be warranted for a period of one year from the time of system acceptance.
- B. Within this period, upon notice by the Owner, any defects in the BMS due to faulty materials, methods of installation or workmanship shall be promptly repaired or replaced by the Control System Contractor at no expense to the Owner.

- C. Maintenance of Computer Software Programs: The Control System Contractor shall maintain all software during the standard first year warranty period. In addition, all factory or sub-vendor upgrades to software during the first-year warranty period shall be added to the systems, when they become available, at no additional cost. In addition to first year standard warranty, software provided by Control System Contractor shall come with a 5 Year Software Maintenance license. All SNC and BAS Servers are included in this coverage. Labor to implement upgrades in years two through five are not included in standard warranty.
- D. Maintenance of Control Hardware: The Control System Contractor shall inspect, repair, replace, adjust, and calibrate, as required, the controllers, control devices and associated peripheral units during the warranty period. The Control System Contractor shall then furnish a report describing the status of the equipment, problem areas (if any) noticed during service work, and description of the corrective actions taken. The report shall clearly certify that all hardware is functioning correctly.
- E. Service Period: Calls for service by the Owner shall be honored within 24 hours and are not to be considered as part of routine maintenance.
- F. Service Documentation: A copy of the service report associated with each owner-initiated service call shall be provided to the owner.

3.8 WARRANTY ACCESS

- A. The Owner shall grant to the Control System Contractor reasonable access to the BMS during the warranty period. Remote access to the BMS (for the purpose of diagnostics and troubleshooting, via the Internet, during the warranty period) will be allowed.

3.9 OPERATION & MAINTENANCE MANUALS

- A. See Division 1 for requirements. O&M manuals shall include the following elements, as a minimum:
 1. As-built control drawings for all equipment.
 2. As-built Network Communications Diagram.
 3. General description and specifications for all components.

3.10 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

END OF SECTION