

# **Enhanced Water Quality And Disinfection Through Ozone Gas Contacting**

Jim Jackson

Mazzei Injector Company LLC.

# TOPICS

- **Ozone Basics**
  - Discovery, Basic Chemistry, Disinfection, Oxidation, Commercial Generation
- **Ozone Contacting: Dissolving Ozone Into Water**
  - Fine Bubble Diffusion Contact Basins
  - Sidestream Venturi Gas Injection
  - Secondary Gas Mixing Devices: Pipeline Flash Reactor & Basin Nozzle Manifolds
- **Case Histories:**
  - OUC SW WTP: Retrofit of 45 MGD O<sub>3</sub> diffusion basins with SVI and Pipeline Flash Reactor for H<sub>2</sub>S oxidation
  - SW WWTP: Retrofit of 100 MGD wastewater ozone contact basin with SVI Basin Nozzle Manifolds

**OZONE ?**

# FATHER OF OZONE




Christian Friedrich Schönbein  
1799 - 1868



# OZONE DISCOVERY

## ELECTROLYSIS OF WATER


(March 13, 1839)



Electrode used non-oxidizable platinum and gold probes. Oxygen collected at the positive, platinum probe and gave off a smell.

# BASIC CHEMISTRY



## Ozone Generation



# BASIC CHEMISTRY

## Ozone Generation

- Ozone gas is formed from oxygen gas *via* an electrical discharge
- Ozone generators create “lightning strikes” within a narrow discharge gap
  - Gas must be dry
  - Gas must be particle free
  - Gas must be cooled




# BASIC CHEMISTRY

## Relative Strength of Ozone

OXIDIZING AGENT	EOP (VOLT)	EOP VS CL2
Fluorine	3.06	2.25
Oxygen (atomic)	2.42	1.78
Ozone	2.08	1.52
Hydrogen Peroxide	1.78	1.30
Hypochlorite	1.49	1.10
Chlorine	1.36	1.00
Chlorine Dioxide	1.27	0.93
Oxygen (molecular)	1.23	0.90

# BASIC CHEMISTRY

-Ozone Is A Pale Blue Gas-



Ozone Concentration : 23 w/w%

# BASIC CHEMISTRY


- Ozone does not combined with organics like chlorine.
  - All measured dissolved O<sub>3</sub> is “free” O<sub>3</sub>
- Dissolved O<sub>3</sub> is volatile and constantly leaves water as O<sub>3</sub> gas.

**OZONE SAFETY**

**ISSUES**




# OZONE OFF-GAS






# OZONE DESTRUCT + BLOWER



# CATALYTIC DESTRUCTION OF OZONE

OZONE Destruction Efficiency is:

- A. Consistent
- B. Predictable



# EFFECTS OF OZONE EXPOSURE

Condition	Ozone Concentration
Detectable odor	0.01 to 0.04 ppm <sub>v</sub>
TLV-TWA 8-hr limit	0.10 ppm <sub>v</sub>
Headache, shortness of breath	>0.10 ppm <sub>v</sub>
TLV-STEL 15-min limit	0.30 ppm <sub>v</sub>
Chest pain, dry cough, lung irritation, severe fatigue	0.6 - 1.0 ppm <sub>v</sub> (1 - 2 hrs)
Immediately dangerous to life & health	10.0 ppm <sub>v</sub>
Expected to be fatal	50 ppm <sub>v</sub> (30 min)

Data from "Ozone Manual of Standard Practice", Workers Compensation Board of British Columbia, 1992

# AMBIENT OZONE MONITORS

- Sound, visual, and computer alarms
- Sample from near floor level since ozone is heavier than air



Ambient Ozone



# UV OZONE MONITOR IS THE GOLD STANDARD




- Measures based on the decay of ozone gas with UV.
- Does not alarm when contacted with chemical fumes and gases.

# BASIC CHEMISTRY

- Ozone does not combined with organics like chlorine.
  - All measured dissolved O<sub>3</sub> is “free” O<sub>3</sub>
- Dissolved O<sub>3</sub> is volatile and constantly leaves water as O<sub>3</sub> gas.
- Dissolved O<sub>3</sub> concentrations change over time. Ozone constantly decays to secondary oxidants and oxygen.

# OZONE DECAY CURVES



WHY


OZONE?



# A 1993 WATERBOURNE DISEASE OUTBREAK

- Gastro Intestinal Illness: > 400,000 Milwaukee, WI Residents
- Mortality: 104 deaths, primarily the elderly and immunocompromised
- Financial Impact: \$ 96 million in health care cost & productivity loss
- Pathogen: 4 – 5 um sized, chlorine resistant, *Cryptosporidium parvum* oocysts.
- *C. parvum* can be inactivated with exposure to small concentrations of ozone over a short period of time.

# Giardia Cyst-Effects of O3 Attack



Control  
pH 6, 25 C

**Active  
Pathogen  
Will infect host**

Moderate  
Exposure:  
0.5 mg/l  
2 min

**Inactive  
Pathogen  
Will not infect host**

High:  
Exposure:  
.5 mg/l,  
5 min

# DISINFECTION JARGON

Pathogen Inactivation

Pathogen Can No Longer Infect A Host.

Log Removal/Log Inactivation

Number Of Removed/Inactivated Cells

$$\text{Log Removal} = \text{Log} \left[ \frac{\text{Number of Organism In Raw Water}}{\text{Number of Organisms In Effluent}} \right]$$

Log Removal/Inactivation	Percent Removal/ Inactivation
1	99 %
2	99.9 %
3	99.99 %

# Cryptosporidium Oocysts

Direct Fluorescent Antibody Assay

Alive /Active?

Dead /In-active ?

Alive /Active ?

Dead /In-active ?


Dead /In-active ?

Alive /Active ?

10  $\mu$ m



# DISINFECTION JARGON



# DISINFECTION JARGON

## Jargon Relationship

CT Values for Cryptosporidium Inactivation/Removal (40 CFR 141.730 Abridged )

LOG REMOVAL	INACTIVATION %	WATER TEMPERATURE, C°					
		5	7	10	15	20	25
1	90	16	13	9.9	6.2	3.8	2.5
2	99	32	26	20	12	7.8	4.9
3	99.9	47	39	30	19	12	7.4

**Coagulation – Filtration (Cell Removal) + O3 Contact Time (Cell Inactivation) = CT Value**

OZONE

OXIDATION

# OXIDATION APPLICATIONS

- Taste & Odor
  - Geosmin & MIB
  - H<sub>2</sub>S
- Metals
  - Iron and Manganese
- Toxins
  - Microcystins & Anatoxins ( Blue-Green Algae)
- Micro-flocculation
  - Raw water pin-floc development with low dose ozone



**MUNICIPAL**

**OZONE**

**SYSTEMS**

# OXYGEN SOURCE





# OZONE GENERATION


(400 PPD O<sub>3</sub> Generator)

Power Supply

Ozone  
Generator







Ozone Destruct  
Module

Oxygen

O<sub>3</sub> Gas

O<sub>3</sub> Off Gas

O Z O N E   C O N T A C T I N G

Water

O<sub>3</sub> Treated



**> 90% of US municipal ozone installations use FBD contact basins.**





# Southwest WWTP

## -Ozone Gas Injectors-



Injector No. 1

Injector No. 2

# N. AMERICAN O3 CONTACT BASINS

## Why Retrofit With Gas Injection?

Improved O3 Transfer Efficiency ?

No. Well designed FBD is efficient !


Yes. Poorly maintained FBD is inefficient!

Confined Space Safety Concerns ?

Maybe.







300 done !  
256 to do !!

# N. AMERICAN O3 CONTACT BASINS

## Why Retrofit With Gas Injection?

Improved O3 Transfer Efficiency ?

No. Well designed FBD is efficient !


Yes. Poorly maintained FBD is inefficient!

Confined Space Safety Concerns ?

Maybe.

Retrofit To Reduce Maintenance ?

Yes !



300 done !  
256 to do !!

**Checking Diffuser Gas Distribution**

# REVENUE LOSS DECREASES STAFFING

Injection Retrofit Replaces Man Hours With Kilowatt Hours

# N. AMERICAN O3 CONTACT BASINS

## Why Retrofit With Gas Injection?

Improved O3 Transfer Efficiency ?

No. Well designed FBD is efficient !

Yes. Poorly maintained FBD is inefficient!

Confined Space Safety Concerns ?


Maybe.

Retrofit To Reduce Maintenance ?

Yes !

Retrofit To Reduce Bromate ?

Yes !



**Water Research Foundation Project No. 4588**

# **Venturi**

## **Gas Injection**

# VENTURI GAS INJECTORS







# VENTURI GAS INJECTION SKIDS



# Stage 1 of Ozone Transfer (CFD Driven Simulation)



# VENTURIE GAS INJECTOR







INLET  
PRESSURE

4" OS 60 psi

# Injector Inlet Pressures

## Determines Water Flow Rate

Mazda				ble			
Injector Model						3090	7/23/2004
Operating Pressure PSIG		Air Suction		Operating Pressure PSIG		Air Suction	
Injector Inlet	Injector Outlet	Motive Flow GPM	Air Suction SCFM	Injector Inlet	Injector Outlet	Motive Flow GPM	Air Suction SCFM
5	0	73		50	2	231	25.8
	1				10		19.5
	2				15		13.1
	3				20		9.1
	4				25		7.1
10	1	103	11.9		30		5.1
	2		10.6		35		3.8
	5		6.3		40		Trace
	7		4.9	60	2	253	28.5
	8		0.5		10		21.6
15	2	127	16.4		20		10.5
	5		11.2		25		8.0
	7		7.0		30		6.9
	10		4.4		35		5.2
	12		2.0		40		3.7
20	2	146	19.0		45		2.0
	5		14.2	70	2	274	30.2
	10		6.5		10		25.3
	12		4.9		20		13.7
	15		3.6		30		9.6
25	2	164	20.7		35		7.4
	5		16.7		40		5.4
	10		9.0		45		4.2
	15		5.2		50		3.3
	20		1.0		55		1.5
30	2	179	22.9	80	2	293	33.0
	5		19.0		20		18.5
	10		11.3		30		11.6
	15		6.4		35		9.6
	20		4.2		40		8.3
	25		0.0		45		6.3
	2		24.2		50		4.3



# PRESSURE DIFFERENTIAL SETS GAS SUCTION

OUTLET PRESSURE



INLET PRESSURE



# Injector Pressure Differential Determines Gas Suction

3090

7/23/2004

Injector Mo									
Operating Pressure PSIG		Air Suction		Operating Pressure PSIG		Air Suction			
Injector Inlet	Injector Outlet	Motive Flow GPM	Air Suction SCFM	Injector Inlet	Injector Outlet	Motive Flow GPM	Air Suction SCFM		
5	0	73		50	2	231	25.8		
	1				10		19.5		
	2				15		13.1		
	3				20		9.1		
	4				25		7.1		
10	1	103	11.9	60	30	253	5.1		
	2		10.6		35		3.8		
	5		6.3		40		Trace		
	7		4.9		2		28.5		
	8		0.5		10		21.6		
15	2	127	16.4		20	274	10.5		
	5		11.2		25		8.0		
	7		7.0		30		6.9		
	10		4.4		35		5.2		
	12		2.0		40		3.7		
20	2	146	19.0	70	45	293	2.0		
	5		14.2		2		30.2		
	10		6.5		10		25.3		
	12		4.9		20		13.7		
	15		3.6		30		9.6		
25	2	164	20.7		35		7.4		
	5		16.7		40		5.4		
	10		9.0		45		4.2		
	15		5.2		50		3.3		
	20		1.0		55		1.5		
30	2	179	22.9	80	2		33.0		
	5		19.0		20		18.5		
	10		11.3		30		11.6		
	15		6.4		35		9.6		
	20		4.2		40		8.3		
	25		0.0		45		6.3		
	2		24.2		50		4.3		

# VENTURI INJECTOR OPERATION

INCREASING GAS FEED PRESSURE INCREASES INJECTOR GAS CAPACITY

Basin MGD	Ozone SCFM	NO. Inj	Inj SCFM	Injector Model	Inlet PSIG	O3 PSIG	Flow GPM	Outlet PSIG	Pump BHP	Pump Rated HP
45	105.27	2	52.6	4091	40	6	345	10	10.7	15
	45.12	1	45.1			3	356	10	11.0	15
20	46.79	1	46.8			4	351	10	10.9	15
	20.05	1	20.1			0	371	10	11.5	15



# VENTURI INJECTOR OPERATION

...BUT DECREASES THE INJECTOR FLOW RATE

Basin MGD	Ozone SCFM	NO. Inj	Inj SCFM	Injector Model	Inlet PSIG	O3 PSIG	Flow GPM	Outlet PSIG	Pump BHP	Pump Rated HP
45	105.27	2	52.6	4091	40	6	345	10	10.7	15
	45.12	1	45.1			3	356	10	11.0	15
20	46.79	1	46.8			4	351	10	10.9	15
	20.05	1	20.1			0	371	10	11.5	15

# SECONDARY GAS MIXING DEVICE

- Basin Nozzle Manifold

# Basin Nozzle Manifold

## Stage 2 Of Gas Transfer



Mazzei Injector Company, LLC  
Job: 1289


# BASIN NOZZLE MANIFOLDS

## Stage 2 of Gas Transfer




# Dual Basin Nozzle Manifold

Dublin Road WTP  
Columbus, OH




# Dual Basin Nozzle Manifold

## Dublin Road WTP Columbus, OH



*Dublin Road WTP, Columbus, OH -Isometric view of velocity streamlines at larger velocity scale*

# 2-Stage Ozone Transfer



# **CASE HISTORY**

## **WASTEWATER DISINFECTION & REUSE**




# Southwest WWTP

Springfield, MO USA



# SOUTHWEST WWTP

- Continuously using ozone disinfection since 1978
- 50 Ton cryogenic oxygen plant + plate ozone generators
- Replaced O<sub>3</sub> generators in 1988: Emery 1,800 ppd @ 3% wt.



## O3 Disinfection Targets

- E. Coli:  $\leq 126$  MPN/ml (Daily )
- Fecal Colifom:  $\leq 200$  MPN/ml (Mo. Avg.)

# **OZONE GENERATOR SYSTEM**

## **2008 MAINTENANCE COST**

**> \$ 95,000 / Yr. !**

# OZONE SYSTEM UPGRADE

## EXISTING

- 50 Ton Cryogenic Oxygen Plant
- Emery Gen: 3 X 800 PPD
- O3 Conc.: 3 - 3.5 % wt.
- Three Ozone Contact Basins
  - O3 Turbine Mixers: 9 x 30 HP
  - Min to Average PPD: 270 HP
  - Max PPD: 270

## UPGRADE

- 50 Ton Cryogenic Oxygen Plant
- Mitsubishi: 2 x 2,800 PPD
- O3 Conc.: 4 – 10 % wt.
- Three Ozone Contact Basins
  - O3 SVI: 2 x 60 HP pumps
  - Min to Average PPD: 60 HP
  - Max PPD: 120 HP

# SOUTHWEST WWTP

## Contact Basin Gas Injection Retrofit


### Minimizing Injector Pump HP

Basin Operation	Basin MGD	Basin O3 lbs/d	Basin O3 SCFM	No. Injectors	Inj. O3 lbs/d	Inj. O3 SCFM	Inj. Model	Inj. Inlet PSIG	O3 Feed PSIG	Injector Flow GPM	Inj. Outlet PSIG	Inj. Capacity O3 SCFM
Future	53.3	1,868	606	3	622.6	70.0	4091	40	6	339	10	73.5
Peak	33.3	1,434	328	2	716.9	58.8			4	351	8.8	59
Max	21.3	931	303	2	465.6	52.5			4	351	8.7	59
Avg	3.7	249	82	1	248.7	28.4			0	371	2.5	44
Min	5	85	2	1	84.7	16.7			0	371	2	47


# SW WWTP O3 INJECTION RETROFIT

## Contact Basin Energy Cost

### O3 Injection kWh/kg








O3 Injector No. 1

O3 Injector No. 2

Future O3 Injector No. 3

# Ozone Contact Basin


## Retrofit Challenge








# Basin Inlet Modification



# SOUTHWEST WWTP

## Min Flow Channel CFD



Low Flow - 5 MGD concentration contours at the different cross sections

# SOUTHWEST WWTP

## Injection Retrofit Energy Savings

**O3 TRANSFER (Average): 88 % @ 750 PPD - 6.1% wt. O3**

Plant Flow Condition	Ozone Production (PPD)	Daily Pump (kW hrs)	SVI-BNM Energy (kWh/ppd O3)	Daily Turbine (kW hrs)	Turbine Energy (kWh/ppd O3)	SVI-BNM Energy Savings (kWh/d)
Average	750	664.2	0.89	3,865.7	4,365.4	3,201.6
Maximum	2800	1,328.3	0.47	3,865.7	8,148.7	2,537.4
Storm	4300	1,328.3	0.31	3,865.7	12,514.1	2,537.4

Note: kWh based on motor brake hp @ 80% motor efficiency



# WWTP OUTFALL



## WATER REUSE

**Local Power Generation Utility Using  
Plant Effluent for Cooling Water**



# Southwest Clean Water Plant

## Springfield, MO USA



# SECONDARY GAS MIXING DEVICE

- Pipeline Flash Reactor (PFR)

# PIPELINE FLASH REACTOR




# PIPELINE FLASH REACTOR

## Stage 2 of Gas Transfer




# SIDESTREAM GAS INJECTION

## Pipeline Flash Reactor




**A 2- Stage Transfer of Gas to Solution.**

# 2-Stage Ozone Transfer



# OPTIMIZING PFR PERFORMANCE

## Computational Fluid Dynamics




Buckingham WTP PFR, Gatineau, QC Canada

Homogenous Blend  
 $C o V \leq 5 \%$



# OPTIMIZING PFR PERFORMANCE

## Computational Fluid Dynamics



# **CASE HISTORY**

## **GROUND WATER OXIDATION**

# ORLANDO UTILITY COMMISSION

## SW WTP



**Commission Date:** 1997

**Peak Water Production:** 45.6 MGD

**Water Quality Issue:** T & O (H<sub>2</sub>S)

**Water Source:** Ground Water (5 wells)

**Initial Treatment:** O<sub>3</sub> + Cl<sub>2</sub>



**Air Fed Ozone Generators**

# OUC SW WTP

Spare parts availability  
Operating costs:  
-LOX Vs Elect. Power

## ORIGINAL DESIGN 1997-2000

- O3 On Site: 4 x 950 ppd
- O3 Generator Feed Gas: Air
- Peak O3 Flow: 1,600 SCFM
- No. Contactors: 3
- No. Gas Diffusion Stones: 1,656
- Confine Space Entry: Yes
- Maintenance: Clean or replace diffusers and gaskets bi-annually.

## OZONE UPGRADE 2014

- O3 On Site: 3 x 1,260 ppd
- O3 Generator Feed Gas: O2
- Peak O3 Flow: 382 SCFM
- No PFRs: 1
- No. Gas Injectors: 5
- Confine Space Entry: 1
- Maintenance: Clean or replace injector gas check valves annually.

# OUC SW WTP

## ORIGINAL DESIGN 1997-2000

- O3 On Site: 4 x 950 ppd
- O3 Generator Feed Gas: Air
- Peak O3 Flow: 1,600 SCFM
- No. Contactors: 3
- No. Gas Diffusion Stones: 1,656
- Confine Space Entry: Yes
- Maintenance: Clean or replace diffusers and gaskets bi-annually.

## OZONE UPGRADE 2014

- O3 On Site: 3 x 1,260 ppd
- O3 Generator Feed Gas: O2
- Peak O3 Flow: 382 SCFM
- No PFRs: 1
- No. Gas Injectors: 5
- Confine Space Entry: 1
- Maintenance: Clean or replace injector gas check valves annually.



Safety  
Maintenance requirements



# OZONE SYSTEM DESIGN PARAMETERS

Design Criteria	Units <sup>1</sup>	Value
Average Day Flow	MGD	26.6
Maximum Day Flow (wellfield capacity)	MGD	45.6
Permitted Max Day Flow (2023 CUP Allocation)	MGD	39.9
Minimum Day Flow ( <u>2</u> wells operating)	MGD	10.4
Minimum Day Flow ( <u>3</u> wells operating)	MGD	17.4
Average Ozone Dose	mg/L	8.4
Maximum Ozone Dose	mg/L	9.84
Minimum Ozone Dose	mg/L	7.4
Average Ozone Production	ppd	1,862 @ 12%
Maximum Ozone Production (45.6 MGD)	ppd	3,740 @ 8%
Maximum Ozone Production (39.9 MGD)	ppd	3,272 @ 9.5%
Minimum Ozone Production (2 wells)	ppd	644 @ 12%
Minimum Ozone Production (3 wells)	ppd	1,079 @ 10%

Ozone Dissolution Modifications and Feed Gas Conversion from Air Prep to LOX in Orlando Fl, Greg Taylor et. al, IOA IUVA World Congress, Las Vegas, NV Sept 2013

# INJECTION SYSTEM DESIGN

## Minimizing Injector Pump HP


Plt MGD	Plt GPM	O3 kg/Hr	O3 SCFM	Duty PFRs	PFR SCFM	No Inj	Inj SCFM	Inj Model	Inj. Inlet PSIG	Inj. O3 PSIG	Inj Wtr GPM	Inj. Outlet PSIG	Inj. Design SCFM	Inj Pump BHP*	Total PFR BHP	Plant Total BHP	O3 % TE
45.6	31,667	70.5	376.0	1	376.0	5	75.2	4091	55	5	421	12	82.4	17.3	86.4	86.4	≥ 96
		60.4	322.3		322.3		64.5			3	426		66.9	17.5	87.4	87.4	
		53.2	283.9		283.9		56.8			2	431		59.6	17.7	88.5	88.5	
39.9	27,708	61.9	276.7	1	276.7	4	69.2			4	424		74.4	17.4	69.6	69.6	
26.6	18,472	52.9	236.2		236.2		59.1			3	426		66.9	17.5	70.0	70.0	
		46.6	208.1		208.1		52.0			2	431		59.6	17.7	70.8	70.8	
		41.1	144.2	1	144.2	3	48.1			1	433		52.8	17.8	53.3	53.3	
		35.2	123.6		123.6		41.2			0	436		47	17.9	53.7	53.7	
		31.0	108.9		108.9		36.3						47	17.9	53.7	53.7	
17.6	12,222	27.2	95.4	1	95.4	2	47.7			1	433		52.8	17.8	35.6	35.6	
		23.3	81.8		81.8		40.9			0	436		47	17.9	35.8	35.8	
		20.5	72.0		72.0		36.0			0	436		47	17.9	35.8	35.8	

55      0      436  
Pump Design Pt

\*Pump NPSH = 5 psig + 70 % Pump Eff.

# INJECTION SYSTEM DESIGN

## -Energy Cost-




# SW WTP

## OZONE TRANSFER CHALLENGE


- Gas Injection: 5 Sets of nozzle jets in 80 " of water.
- Max Design O<sub>3</sub> Dose: 9.8 mg/l
- Peak O<sub>3</sub> Dose:  $\geq$  9.0 mg/l
- Injector G/L:  $\geq$  0.8
- Max Water Temperature: 25 C
- Historical Performance: 1,656 diffusion stones in 22 ' water

# PIPELINE FLASH REACTOR LOCATION



## OUC SW WTP INJECTION SYSTEM LAYOUT


# COMMISSIONING INJECTION SYSTEM





# Case 1: Specified Injector, PFR and Mixer

## 26.6 MGD & 3 Gas Injectors



Contours of Volume fraction (phase-2)

ANSYS Fluent 15.0 (3d, dp, pbns, mixture, sstkww)

## Mazzei Injector Pipeline Flash Reactor Ozone Transfer Projections


<b>Prepared For:</b>	Wharton Smith
<b>Project:</b>	OUC SW WTP: 26.6 MGD flow to 3 contact basins
<b>Purpose for Ozonation:</b>	H2S Oxidation
<b>Date:</b>	8-May-15

26.6 MGD	Gas contacting all of the water. Low pipeline hydrostatic water pressure								
Contacted Flow Volume GPM	Contactor Operating Pressure PSIG	Applied Ozone Dose mg/l	Ozone Gas Concentration wt %	Ozone Demand Ratio	Required Ozone Injection Rate lbs./hr	Required Ozone Gas Flow SCFM	Calculated Gas/Liquid Ratio Vg/Vl	Mass Transfer Efficiency, MTE %	Calculated Ozone Residual mg/l
18472	2	9.8	12	0.75	90.59	144.00	0.06	96.4	2.36
15.96 MGD (60%)	Gas contacting only 60% of the water. Low pipeline hydrostatic water pressure.								
Contacted Flow Volume GPM	Contactor Operating Pressure PSIG	Applied Ozone Dose mg/l	Ozone Gas Concentration wt%	Ozone Demand Ratio	Required Ozone Injection Rate #/hr	Required Ozone Gas Flow SCFM	Calculated Gas/Liquid Ratio Vg/Vl	Mass Transfer Efficiency, MTE %	Calculated Ozone Residual mg/l
11083	2	16.33	12	0.75	90.59	144.00	0.10	82.8	1.27

Copyright Mazzei Injector Co. LLC. 500 Rooster Dr. Bakersfield CA 93307 Phone 661-363-6500, Fax 661-363-7500 www.mazzei.net

# Specified vs Custom High Flow Injectors


## 26.6 MGD & 3 Gas Injectors




Contours of Volume fraction (phase-2)

Oct 31, 2014  
ANSYS Fluent 15.0 (3d, dp, pbns, mixture, sstk)

# CUSTOM INJECTOR PERFORMANCE




# RE-LOCATE PIPELINE FLASH REACTOR ?





## OUC SW WTP INJECTION SYSTEM LAYOUT

24" STATIC MIXER MODEL 2800  
PLATE STYLE MIXER  
316SS CONSTRUCTION  
.8 BETA PLATE DESIGN



## CFD DRIVEN MODIFICATION OF SHAPE TO REDUCE LOSS AND OPTIMIZE MIXING OF PIPELINE CROWN GAS



CLIENT APPROVAL:

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

PRINT NAME: \_\_\_\_\_ TITLE: \_\_\_\_\_

COMPANY: \_\_\_\_\_

**WESTFALL**

WESTFALL MANUFACTURING COMPANY  
15 BROAD COMMON ROAD, BRISTOL RI 02809 U.S.A.  
P: 401-253-3799 F: 401-253-6530 www.westfallmfg.com

WESTFALL STATIC MIXER  
MODEL 2800 - 24" PLATE STYLE

DIMENSIONS ARE IN INCHES (UNLESS OTHERWISE NOTED)

SCALE \_\_\_\_\_ DATE 6.06.2013

DRAWN BY MGP CHECKED BY \_\_\_\_\_ APPROVED BY \_\_\_\_\_

PROJECT \_\_\_\_\_  
EQUIPMENT \_\_\_\_\_  
PLANT \_\_\_\_\_  
SHEET \_\_\_\_\_  
DWG. NO. 99  
24-2800-C




Orifice Plate  
(Modified Wafer Mixer)

Pipeline Crown Gas



# PIPELINE CFD COMPARISON


## 26.6 MGD & 3 Gas Injectors



Contours of Volume fraction (phase-2)

Oct 31, 2014  
ANSYS Fluent 15.0 (3d, dp, pbns, mixture, sstk)

# CUSTOM INJECTOR + ORIFICE PLATE




# INJECTION SYSTEM IMPROVEMENT

## -Energy Cost-

Energy cost savings of 27 kwh/kg of ozone applied !


Injection System Design

O3 Injection kw/kg



Injection System Improvement

O3 Injection kw/kg



# **ADDITIONAL SAVINGS**

**REDUCED LOX AND OZONE GENERATOR POWER**

**DUE TO OZONE TE OF 98 – 99 % !**



# OUC SW WTP

- Operating at 98 – 99% O<sub>3</sub> transfer since Dec 2014 modification.
  - ✓ High Flow Injectors + Orifice Plate (Modified Wafer Mixer)
  - ✓ No pump change / extensive modification not required.
- OUC has better dosage control and lower operating costs.
  - ✓ DO<sub>3</sub> stabilizes in 15 minutes after dosage or flow change
  - ✓ Never more than 3 duty sidestream injectors.
  - ✓ Bi-annual diffuser maintenance eliminated.
- OUC committed to converting the remaining 6 WTP's to sidestream gas injection.



# SUMMARY

- Ozone was discovered in the mid-1800's.
- Ozone is generated on site using Oxygen and Electricity.
- Regulators promoted use of ozone disinfection after 1993 outbreak of Cryptosporidium.
- Ozone is dissolved into water using gas diffusion or Venturi gas injection.
- Ozone contactors are enclosed and pass ozone off gas through a ozone destruct module which converts  $O_3$  to  $O_2$  before gas discharge to atmosphere.

# SUMMARY

- All ozone plants must have ambient air ozone gas monitors to prevent operator exposure to ozone gas.
- Venturi gas injection uses secondary gas mixing devices: Basin Nozzle Manifolds or Pipeline Flash Reactors.
- High ozone transfer efficiency requires water depth !

# QUESTIONS ?

Jim Jackson  
jjackson mazzei.net

[www.mazzei.net](http://www.mazzei.net)