

# **2017 Annual Drinking Water Quality Report**

## **McVeytown Borough Authority**

PWS ID #4440011

Este informe contiene informacion importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you or speak with someone who understands it.)

### **WATER SYSTEM INFORMATION & SOURCE OF WATER:**

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our primary water source is Well #8 located off Furnace Road, northeast of Queen Street and our back-up water source is Well #3 located in the same area as Well #8.

We are pleased to report that our drinking water meets federal and state requirements. If you have any questions about this report or concerning your water utility, please contact Randy Stoner at (717) 899-7436. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held monthly on the first Wednesday at 6:30 p.m. in the Borough Building on Queen Street.

**Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).**

### **MONITORING YOUR WATER:**

McVeytown Borough Authority routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2017. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

### **DEFINITIONS AND ABBREVIATIONS:**

**Action Level (AL)** – the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant that is allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Minimum Residual Disinfectant Level (MinRDL)** – The minimum level of residual disinfectant required at the entry point to the distribution system.

**Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.

**Mren/year** = millirems per year (a measure of radiation absorbed by the body).

**pCi/L** = picocuries per liter (a measure of radioactivity)

**ppb** = parts per billion, or micrograms per liter (µg/L)

**ppm** = parts per million, or milligrams per liter(mg/L)

**ppq** = parts per quadrillion, or pictograms per liter

**ppt** = parts per trillion, or nanograms per liter

**DETECTED SAMPLE RESULTS:**

Chemical Contaminants								
Chemical Contaminant	MCL in CCR units	MCLG	Highest Level Detected	Range of Detects	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine (Distribution)	MRDL=4	MRDLG =4	1.51 (Feb)	0.69–1.51	ppm	2017	N	Added to water to control microbes
Barium	2	2	.0944	N/A	ppm	6/11/15	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of Natural deposits
Trihalomethanes (TTHM)	80	n/a	22.2	N/A	ppb	8/6/15	N	By-product of drinking water chlorination

Entry Point Disinfectant Residual							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Lowest Sample Date	Violation Y/N	Sources of Contamination
Chlorine 2017	0.4	0.62	.062 - 2	ppm	4/17/17	N	Water additive to control microbes.

Lead and Copper							
Contaminant	Action Level (AL)	MCLG	90 <sup>th</sup> Percentile Value	Units	#of Sites Above AL of Total Sites	Violation of TT Yes or No	Sources of Contamination
Lead 2017	15	0	0 1.35	ppb	0 of 10 0 of 10	No No	Corrosion of household plumbing
Copper 2017	1.3	1.3	0.262 0.277	ppm	0 of 10 0 of 10	No No	Corrosion of household plumbing

## **OTHER VIOLATIONS:**

In 2016 we failed to submit the Annual Drinking Water Report for the McVeytown Borough Authority to Pa Department of Environmental Protection and to our customers by the required due date resulting in a violation. We have since completed it and distributed it with this report.

## **EDUCATIONAL INFORMATION:**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, also, come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

## **Information about Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. McVeytown Borough Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Please call our office if you have questions. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.