

इंटरनेट

मानक

Disclosure to Promote the Right To Information

Whereas the Parliament of India has set out to provide a practical regime of right to information for citizens to secure access to information under the control of public authorities, in order to promote transparency and accountability in the working of every public authority, and whereas the attached publication of the Bureau of Indian Standards is of particular interest to the public, particularly disadvantaged communities and those engaged in the pursuit of education and knowledge, the attached public safety standard is made available to promote the timely dissemination of this information in an accurate manner to the public.

“जानने का अधिकार, जीने का अधिकार”

Mazdoor Kisan Shakti Sangathan

“The Right to Information, The Right to Live”

“पुराने को छोड़ नये के तरफ”

Jawaharlal Nehru

“Step Out From the Old to the New”

IS 10553-4 (1983): Requirements for chlorination equipment, Part 4: Gravity feed type gaseous chlorinators [CED 24: Public Health Engineering.]



“ज्ञान से एक नये भारत का निर्माण”

Satyanarayan Gangaram Pitroda

“Invent a New India Using Knowledge”



“ज्ञान एक ऐसा खजाना है जो कभी चुराया नहीं जा सकता है”

Bhartrhari—Nitiśatakam

“Knowledge is such a treasure which cannot be stolen”

BLANK PAGE



“भारतीय मानक”
“RE-AFFIRMED 1996”

IS : 10553 (Part 4) - 1983

Indian Standard

REQUIREMENTS FOR
CHLORINATION EQUIPMENT

**PART 4 GRAVITY FEED TYPE GASEOUS
CHLORINATORS**

(First Reprint OCTOBER 1995)

UDC 628.162.84.06

© Copyright 1983

BUREAU OF INDIAN STANDARDS
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 110002

Indian Standard

REQUIREMENTS FOR CHLORINATION EQUIPMENT

PART 4 GRAVITY FEED TYPE GASEOUS CHLORINATORS

Public Health Engineering Equipment Sectional Committee, BDC 40

Chairman

DR B. B. SUNDARESAN

Representing

National Environmental Engineering Research
Institute (CSIR), Nagpur

Members

<p>SHRI R. PARAMASIVAM (<i>Alternate to</i> Dr B. B. Sundaresan) ADVISER (PHE) DR S. R. SUKLA (<i>Alternate</i>) SHRI S. V. BOPARDIKAR SHRI R. C. P. CHAUDHARY CHIEF ENGINEER SHRI T. N. CHATTERJEE (<i>Alternate</i>) CHIEF ENGINEER (WATER) SHRI JAI NARAIN (<i>Alternate</i>) SHRI D. K. CHOUDHURY SHRI D. R. MALL (<i>Alternate</i>) SHRI S. K. DASGUPTA SHRI S. J. DUTTA (<i>Alternate</i>) DEPUTY MUNICIPAL COMMISSIONER HYDRAULIC ENGINEER (<i>Alternate I</i>) CHIEF ENGINEER (SEWERAGE) (<i>Alternate II</i>) SHRI B. R. N. GUPTA SHRI K. V. KRISHNAMURTHY (<i>Alternate</i>) SHRI S. P. JAMES SHRI R. KRISHNASWAMY SHRI S. A. JAGDESAN (<i>Alternate</i>)</p>	<p>Ministry of Works & Housing, New Delhi Directorate General of Technical Development, New Delhi Engineers India Limited, New Delhi Department of Health, Government of West Bengal, Calcutta Municipal Corporation of Delhi, Delhi Geo-Miller & Co, Calcutta Calcutta Metropolitan Development Authority, Calcutta Municipal Corporation of Greater Bombay, Bombay Engineer-in-Chief's Branch, Army Headquarters, New Delhi Local Administration & Social Welfare (F) Department, Trivandrum Tamil Nadu Water Supply & Drainage Board, Madras</p>
---	---

(Continued on page 2)

© Copyright 1983

BUREAU OF INDIAN STANDARDS

This publication is protected under the *Indian Copyright Act* (XIV of 1957) and reproduction in whole or in part by any means except with written permission of the publisher shall be deemed to be an infringement of copyright under the said Act.

Indian Standard
REQUIREMENTS FOR
CHLORINATION EQUIPMENT

**PART 4 GRAVITY FEED TYPE GASEOUS
CHLORINATORS**

0. FOREWORD

0.1 This Indian Standard was adopted by the Indian Standards Institution on 23 June 1983, after the draft finalized by the Public Health Engineering Equipment Sectional Committee had been approved by the Civil Engineering Division Council.

0.2 Gravity feed type gas apparatus by means of which chlorine is added as solution in a minor flow of water, is suitable for cases where it is required to apply chlorine to water flowing through an open channel or to water entering or leaving a sump or well under atmospheric pressure. The apparatus consists of a control panel with provision for connecting the requisite number of chlorine cylinders and a solutionizer or absorption tower with a suitable connection to the point of application.

0.3 The apparatus is made in different sizes with chlorine supply up to 15 kg/h.

0.4 The line diagram for gravity feed type gaseous chlorinators is given in Fig. 1.

0.5 This standard is being published in 5 parts. Other parts in the series are given below:


Part 1 General guidelines for chlorination plants including handling, storage and safety of chlorine cylinders and drums.

Part 2 Vacuum feed type chlorinators.

Part 3 Pressure feed chlorinators.

Part 5 Bleaching powder solution dosing equipment.

0.6 In the formulation of this standard due weightage has been given to international co-ordination among the standards and practices prevailing in different countries in addition to relating it to the practices in the field in this country.



1. CHLORINE CYLINDER
 2. AUXILIARY CYLINDER VALVE
 3. CHLORINE FILTER
 4. SHUT OFF VALVE
 5. HIGH PRESSURE GAUGE
 6. LOW PRESSURE GAUGE
 7A. REDUCING VALVE
 7B. REDUCING VALVE IN CASE
 CAPACITY MORE THAN 500 g/h

8. REGULATING VALVE
 9. ORIFICE
 10. MANOMETER TUBE
 11. MOISTURE SEAL
 12. WATER AT CONSTANT HEAD
 13. SOLUTION TOWER
 14. CHLORINE SOLUTION LINE
 15. FILTERED WATER CHANNEL
 16. DIFFUSER

0.7 For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test or analysis, shall be rounded off in accordance with IS:2-1960*. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

1. SCOPE

1.1 This standard lays down the requirements for materials of construction, types and performance requirements of gravity feed type gaseous chlorinators.

2. TYPES

2.1 The chlorinators shall be of the following three types:

- a) Wall mounted,
- b) Pedestal mounted, and
- c) Cylinder mounted.

3. MATERIAL

3.1 **Control Panel** — The control panel should be of fibre glass moist chlorine/acid resistance plastics or mild steel with 3 coats of epoxy.

3.2 **Solutionizer Tower** — The solutionizer tower should either be made of glazed porcelain, polyvinyl chloride or of rubber lined mild steel plates. The solutionizer tower is generally of a type as shown in Fig. 2 and shall be packed with pebbles of varying sizes. The pebbles shall be of round water worn type. Pumicestone or porcelain or moist chlorine/acid resistant plastic rashing rings may be used as packing materials in place of pebbles.

3.2.1 The water shall be fed in the solutionizer tower at a constant head.

3.2.2 The outlet from the solutionizer tower to the water channel shall be designed for maximum flow.

3.3 **Tubes** — The tubes used in chlorination plant shall be either phosphorus deoxidised non-arsenical copper conforming to IS:191 (Part 8)-1980† or phosphorus deoxidised arsenical copper conforming to IS:191 (Part 10)-1980‡ or carbon steel conforming to IS:1030-1974§.

*Rules for rounding off numerical values (*revised*).

†Specification for copper: Part 8 Phosphorized copper (DHP) (*third revision*).

‡Specification for copper: Part 10 Phosphorus deoxidized arsenical copper (DPA) (*third revision*).

§Specification for carbon steel castings for general engineering purposes (*second revision*).

NOTE — Minimum wall thickness for tubes is given below:

	<i>Outside diameter mm</i>	<i>Min Wall Thickness mm</i>	<i>Tolerances mm</i>
For copper tubes	up to 5	0·8	± 0·08
	above 5 up to 12	1·0	± 0·10
	above 12 up to 20	1·2	± 0·10
carbon steel	up to 20	2·5	± 0·10
	above 20 up to 30	3·0	± 0·15
	above 30 up to 40	3·2	± 0·20




FIG. 2 SOLUTIONISER TOWER

3.3.1 For carrying moist chlorine, the pipelines should be made of silver, platinum, corrosion resistance alloy steel conforming to grade 19 of IS:3444-1978*, HDEP conforming to IS:4984-1978† or UPVC conforming to IS:4985-1981‡.

3.4 Nuts Bolts and Brackets — Nuts bolts and brackets shall be of chromium plated brass or cadmium plated mild steel.

3.5 Chlorine gas filter media shall be of glass wool.

3.6 Other Components — The ancillary components incorporate a chlorine gas, filter, pressure reducing valves, manometer or rate of discharge meter, regulating valve, moisture trap, chlorine pressure gauge and a stop valve. All metallic parts coming in contact with gas should be made of silver-plated brass or nickel. Stainless steel may also be used for components coming in contact with dry chlorine gas only. Non-metallic materials used in construction of various components shall be of glass, ebonite and moist chlorine/acid resistant plastic.

4. PERFORMANCE REQUIREMENTS

4.1 Concentration of chlorine gas in solution after the solutionizer tower shall be at least 90 percent of the saturation value of chlorine gas at that temperature.

4.1.1 Solubility of chlorine gas in water in the solutionizer tower depends on the surrounding temperature. For guidance Table 1 may be adopted for designing solutionizer tower.

5. CHLORINATION REQUIREMENT

5.1 Rate of withdrawal of chlorine from container depends upon the size of container and the surrounding temperature. For guidance Table 2 may be followed.

NOTE — If the discharge rate of chlorine is exceeded beyond the recommended rate, the liquid chlorine may freeze.

5.2 When the gas discharge rate from a single container may not meet the requirements, two or more containers may be connected to a manifold so as to discharge simultaneously. It is advisable not to couple more than four containers to a manifold.

*Specification for corrosion resistant alloy steel and nickel based castings for general applications (*first revision*).

†Specification for high density polyethylene pipes for potable water supplies sewage and industrial effluent (*second revision*).

‡Specification for unplasticised PVC pipes for potable water supplies (*first revision*).

**TABLE 1 SOLUBILITY OF CHLORINE IN WATER AT
DIFFERENT TEMPERATURES**

(Clause 4.1.1)

TEMPERATURE °C	PERCENTAGE SOLUBILITY (wt/wt)
10	0.997 2
11	0.965 4
12	0.934 6
13	0.905 0
14	0.876 8
15	0.849 5
16	0.823 2
17	0.797 9
18	0.773 8
19	0.751 0
20	0.729 3
21	0.710 0
22	0.691 8
23	0.673 9
24	0.657 2
25	0.641 3
26	0.625 9
27	0.611 2
28	0.597 5
29	0.584 7
30	0.572 3
35	0.510 4
40	0.459 0

5.2.1 When discharging through a manifold, all the containers shall be at the same temperature, particularly when connecting a new cylinder to the manifold.

5.2.2 When more than 3 cylinders are used, the connections should be arranged in groups so that one complete group may be changed at a time.

6. INSTALLATION AND SAFETY

- 6.1** For installation of the chlorination plants including handling, storage and safety of chlorine cylinders and drums IS: 10553 (Part 1)-1983* may be followed.

*Requirements of chlorination equipment: Part 1 Guidelines for chlorination plants including handling, storage and safety of chlorine cylinders and drums.

**TABLE 2 RATE OF WITHDRAWAL OF CHLORINE
FROM CONTAINER**

(Clause 5.1)

TEMPERATURE °C	kg OF CHLORINE DISCHARGE PER DAY		
	Cylinders		Tonne Container
	45 kg	67 kg	
4	2.72	4.08	45
10	6.35	9.5	110
15	10.75	16.10	130
20	14.50	21.54	245
Above 27	18.70	28.12	315

IS : 10553 (Part 4) - 1983

(Continued from page 2)

<i>Members</i>	<i>Representing</i>
DR A. G. BHOLE	Visvesvaraya Regional College of Engineering, Nagpur
DR S. M. DHABDGAONKAR (<i>Alternate</i>)	
SHRI D. K. CHOUDHURY	Geo-Miller & Co Pvt Ltd, Calcutta
SHRI A. K. MAZUMDAR (<i>Alternate</i>)	
SHRI M. M. DATTA	Central Public Health and Environmental Engineering Organization, New Delhi
SHRI I. RADHAKRISHNAN (<i>Alternate</i>)	
SHRI K. GOVINDAN NAIR	Public Health Engineering Department, Trivandrum
DR R. P. MATHUR	University of Roorkee, Roorkee
SHRI N. W. MIRCHANDANI	Municipal Corporation of Greater Bombay
SHRI K. MOHAN	Engineers India Ltd, New Delhi
SHRI S. S. NAIK	Hydraulic & General Engineers (P) Ltd, Bombay
SHRI D. R. KENKRE (<i>Alternate</i>)	
SHRI R. NATARAJAN	Hindustan Dorr-Oliver Ltd, Bombay
SHRI B. M. RAHUL (<i>Alternate</i>)	
SHRI R. PARAMASIVAM	National Environmental Engineering Research Institute (CSIR), Nagpur
SHRI N. G. SWARNAKAR (<i>Alternate</i>)	
SHRI N. RAMACHANDRAN	Ion Exchange (India) Ltd, Bombay
SHRI A. M. JOSHI (<i>Alternate</i>)	
SHRI C. E. S. RAO	The Hindustan Construction Co Ltd, Bombay
SHRI C. L. SASTRI	Candy Filters (India) Ltd, Bombay
SHRI V. SATYAMURTHI	EIMCO — KCP Ltd, Madras
SHRI T. SUBRAHMANYAM (<i>Alternate</i>)	
SHRI S. S. SRIVASTAVA	Uttar Pradesh Jal Nigam, Lucknow
PROF S. SUBBA RAO	All India Institute of Hygiene & Public Health, Calcutta
SHRI K. J. NATH (<i>Alternate</i>)	

BUREAU OF INDIAN STANDARDS

Headquarters:

Manak Bhavan, 9 Bahadur Shah Zafar Marg, NEW DELHI-110002

Telephones : 331 01 31

331 13 75

Telegrams : Manaksanstha
(Common to all Offices)

Regional Offices:

Telephone

Central : Manak Bhavan, 9 Bahadur Shah Zafar Marg, NEW DELHI 110002 331 01 31
331 13 75

*Eastern : 1/14 CIT Scheme VII M, V.I.P. Road, Maniktola, CALCUTTA 700054 37 86 62

Northern : SCO 335-336, Sector 34-A, CHANDIGARH 160 022 60 38 43

Southern : C.I.T. Campus, IV Cross Road, MADRAS 600113 235 23 15

†Western : Manakalaya, E9 MIDC, Marol, Andheri (East), BOMBAY 400093 832 92 95

Branch Offices:

'Pushpak', Nurmohamed Shaikh Marg, Khanpur, AHMADABAD 380001	30 13 48
‡Peenya Industrial Area, 1st Stage, Bangalore-Tumkur Road,, BANGALORE 560058	39 49 55
Gangotri Complex, 5th Floor, Bhadbhada Road, T.T. Nagar, BHOPAL 462003	55 40 21
Plot No. 21 Satyanagar, BHUBANESHWAR 751007	40 36 27
Kalaikathir Building, 6/48 Avanashi Road, COIMBATORE 641037	21 01 41
Plot No. 43, Sector 16 A, Mathura Road, FARIDABAD 121001	8-28 88 01
Savitri Complex, 116 G.T. Road, GHAZIABAD 201001	8-71 19 96
53/5 Ward No. 29, R.G. Barua Road, 5th By-lane, GUWAHATI 781003	54 11 37
5-8-56C L.N. Gupta Marg, Nampally Station Road, HYDERABAD 500001	20 10 83
R 14 Yudhister Marg, C Scheme, JAIPUR 302005	38 13 74
117/418 B Sarvodaya Nagar, KANPUR 208005	21 68 76
Seth Bhawan, 2nd Floor, Behind Leela Cinema, Naval Kishore Road, LUCKNOW 226001	23 89 23
Patliputra Industrial Estate, PATNA 800013	26 23 05
C/o Smt. Sunita Mirakhur,, 66 D/C Annexe, Gandhi Nagar, JAMMU TAWI 180004	—
T.C. No. 14/1421, University P.O., Palayam, THIRUVANANTHAPURAM 695034	6 21 17
Inspection Offices (With Sale Point):	
Pushpanjali, 1st floor, 205-A, West High Court Road, Shankar Nagar Square, NAGPUR 440010	525171
Institution of Engineers (India) Building 1332 Shivaji Nagar, PUNE 411005	32 36 35
<hr/>	
* Sales Office is at 5 Chowringhee Approach, P.O. Princep Street, CALCUTTA 700072	27 99 65
†Sales Office is at Novelty Chambers, Grant Road, BOMBAY 400007	309 65 28
‡Sales Office is at 'F' Block, Unity Building, Narasimharaja Square, BANGALORE 560002	22 39 71