

Boil Water Notice Rescinded LIFTED 07/29/2025

******ELYSIAN FIELDS WATER SUPPLY CUSTOMERS ******

On JULY 22, 2025, the Texas Commission on Environmental Quality required the Elysian Fields Water Supply, public water system, PWSTX1020014, to issue a Boil Water Notice to inform customers, individuals, or employees that due to conditions which occurred recently in the public water system, the water from this public water system was required to be boiled prior to use for drinking water or human consumption purposes.

The public water system has taken the necessary corrective actions to restore the quality of the water distributed by this public water system used for drinking water or human consumption purposes and has provided TCEQ with laboratory test results that indicate that the water no longer requires boiling prior to use as of June 29,2025.

If you have questions concerning this matter, you may contact Angelia Mason at 903-633-2250 or our Operator: Colton at 903-399-1144

The low disinfectant residual levels caused by recent ongoing extreme heat have been addressed. We added an ac unit to our chemical storage area to lower temperatures and help chemical feed pumps from overheating. Disinfectant residuals levels have returned to allowable limits. The water has been tested and results for samples taken to the lab on July 28, 2025 show the water is safe.