

July 22, 2025

PWS:TX1020014

Boil Water Notice ELYSIAN FIELDS WSC

EXCLUDING: This notice does NOT include EFWSC customers located on: Strickland Springs, Floyd Evans, Old Town Rd between FM 31 and Mollie Lane****

Due to low disinfection residuals, the Texas Commission on Environmental Quality has required the ELYSIAN FIELDS WSC public water system to notify all customers to boil their water prior to consumption (e.g., washing hands/face, brushing teeth, drinking, etc). Children, seniors, and persons with weakened immune systems are particularly vulnerable to harmful bacteria, and all customers should follow these directions).

To ensure destruction of all harmful bacteria and other microbes, water for drinking, cooking, and ice making should be boiled and cooled prior to use for drinking water or human consumption purposes. The water should be brought to a vigorous rolling boil and then boiled for two minutes.

In lieu of boiling, individuals may purchase bottled water or obtain water from some other suitable source for drinking water or human consumption purposes.

When it is no longer necessary to boil the water, the public water system officials will notify customers that the water is safe for drinking water or human consumption purposes.

Once the boil water notice is no longer in effect, the public water system will issue a notice to customers that rescinds the boil water notice in a manner similar to this notice.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions concerning this matter, you may contact Angelia Mason at: 903-633-2250 or via email: waterdept2019@gmail.com OR Colton Prothro, Operator @ 903-399-1144

EFWSC Plant 1 disinfectant residual levels are fluctuating due to the extreme heat affecting our liquid disinfection treatment chemical. While completing our required daily water disinfectant testing it was discovered that levels have fallen below 0.2 mg/l minimum. As a precaution EFWSC has issued this boil advisory until further notice. We have replaced the disinfectant supply with fresh product, increased our disinfectant dosage to increase our residuals and flushed water mains to get the extra treatment product downline. We have also added a new air conditioner to the treatment building at Plant 1 to help keep the disinfectant chemicals cooler .